

# National Electrical Safety Code®

Secretariat  
Institute of Electrical and Electronics Engineers, Inc.

Approved 20 April 2006  
Institute of Electrical and Electronics Engineers, Inc.

Approved 16 June 2006  
American National Standards Institute

2007 Edition

**Abstract:** This standard covers basic provisions for safeguarding of persons from hazards arising from the installation, operation, or maintenance of (1) conductors and equipment in electric supply stations, and (2) overhead and underground electric supply and communication lines. It also includes work rules for the construction, maintenance, and operation of electric supply and communication lines and equipment. The standard is applicable to the systems and equipment operated by utilities, or similar systems and equipment, of an industrial establishment or complex under the control of qualified persons. This standard consists of the introduction, definitions, grounding rules, list of references, and bibliographic documents, and Parts 1, 2, 3, and 4 of the 2007 Edition of the National Electrical Safety Code.

**Keywords:** communications industry safety; construction of communication lines; construction of electric supply lines; electrical safety; electric supply stations; electric utility stations; high-voltage safety; operation of communications systems; operation of electric supply systems; power station equipment; power station safety; public utility safety; safety work rules; underground communication line safety; underground electric line safety

The Institute of Electrical and Electronics Engineers, Inc.  
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2006 by the  
Institute of Electrical and Electronics Engineers, Inc.

All rights reserved. Published 2006  
Printed in the United States of America

National Electrical Safety Code and NESC are registered trademarks and service marks in the U.S. Patent & Trademark Office, owned by The Institute of Electrical and Electronics Engineers, Incorporated.

The NESC logo is a trademark in the U.S. Patent & Trademark Office, owned by  
The Institute of Electrical and Electronics Engineers, Incorporated.

National Electrical Code and NEC are registered trademarks in the U.S. Patent & Trademark Office,  
owned by the National Fire Protection Association.

ISBN 0-7381-4893-8

Public authorities are granted permission to republish the material herein in laws, regulations, administrative orders, ordinances, or similar documents. No other party may reproduce in any form, in an electronic retrieval system or otherwise, any portion of this document, without the prior written permission of the publisher.

## **Recognized as an American National Standard**

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether he has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review and users are cautioned to obtain the latest editions.

Currently in preview, click buy full version

## Foreword

This foreword is not a part of Accredited Standards Committee C2-2007, National Electrical Safety Code.

This publication consists of the parts of the National Electrical Safety Code® (NESC®) currently in effect. The former practice of designating parts by editions has not been practical for some time. In the 1977 Edition, Parts 1 and 4 were 6th editions; Part 2 was a 7th edition; Part 3 was a revision of the 6th edition; Part 2, Section 29, did not cover the same subject matter as the 5th edition; and Part 3 was withdrawn in 1970. In the 1987 Edition, revisions were made in all parts, and revisions to all parts have been made in subsequent editions. It is therefore recommended that reference to the NESC be made solely by the year of the published volume and desired part number. Separate copies of the individual parts are not available.

Work on the NESC started in 1913 at the National Bureau of Standards (NBS), resulting in the publication of NBS Circular 49. The last complete edition of the Code (the 5th edition, NBS Handbook H30) was issued in 1948, although separate portions had been available at various times starting in 1938. Part 2—Definitions, and the Grounding Rules, 6th edition, was issued as NBS Handbook H81, ANSI C2.2-1960, in November 1961, but work on other parts was not actively in process again until 1970.

In 1970 the C2 Committee decided to delete the Rules for the Installation and Maintenance of Electric Utilization Equipment (Part 3 of the 5th edition), now largely covered by the National Electrical Code® (NEC®) (NFPA 70, 2005 Edition), and the Rules for Radio Installation (Part 5 of the 5th edition) from future editions. The Discussion of the NESC, issued as NBS Handbook H4 (1970 Edition) for the 4th edition of the NESC and as NBS Handbook H39 for Part 2 of the Grounding Rules of the 5th edition, was not published for the 6th edition.

The 1981 Edition included major changes in Parts 1, 2, and 3, minor changes in Part 4, and the incorporation of the rules common to all parts into Section 1. The 1984 Edition was revised to update all references and to list those references in a new Section 3. Converted metric values, for information only, were added. Gender-related terminology was deleted. Section 1—Introduction, Section 2—Definitions, Section 3—References, and Section 9—Grounding Methods, were made applicable to each of the Parts 1, 2, 3, and 4.

The 1987 Edition was revised extensively. Definitions were changed or added. Requirements affecting grounding methods, electric supply stations, overhead line clearances and loading, underground lines, and work rules were revised.

The 1990 Edition included several major changes. General rules were revised. A significant change to the method for specifying overhead line clearances was made and the rationale added as Appendix A. Requirements for clearances of overhead lines from grain bins and an alternate method for determining the strength requirements of wood structures was added. Rules covering grounding methods, electric supply stations, underground lines, and work rules were changed.

In the 1993 Edition, changes were made in the rules applicable to emergency and temporary installations. In Section 9 and Parts 1, 2, and 3, rules were extended or clarified to include HVDC systems. The requirements for minimum separation of direct-buried supply and communications systems were modified for consistency and clarity, as was the rule in Part 4 on tagging electric supply circuits.

In the 1997 Edition, the most notable general change that took place is that numerical values in the metric (SI) system are shown in the preferred position, with customary inch-foot-pound values (inside parentheses) following. A bibliography, Appendix B, which consists of a list of resources identified in notes or recommendations, was added. Changes were made to rules affecting grounding, electric supply stations, and overhead lines, particularly with regard to clearance rules applicable to emergency and temporary installations. Strength requirements contained in Sections 24, 25, and 26 were revised completely.

Underground line requirements for random separation for underground lines of direct-buried cables were modified. The requirement for cable identification marking by means of sequentially placed logos was introduced. Work rules added a requirement that warning signs and tags comply with applicable ANSI standards, tagging requirements were clarified with regard to SCADA, and extensive requirements for fall protection were added.

In the 2002 Edition, several changes were made that affected all or several parts of the Code. Particularly, this edition clarifies interfaces between the NEC and NESC with regard to Code jurisdiction in the area of street lights and area lights. Also included is clarification for situations between utility workers and their authorized contractors and installations on industrial complexes.

The major revisions for the 2007 Edition include grounding, moving sag calculations to Section 23, moving guy and span wires insulator rules to Section 21, phasing out of the alternate method for load factors and strength factors, flammable materials transported, phase-to-phase cover-up, and minimum approach distance tables.

Subcommittee 1 concerned itself with assuring continuity between subcommittees and supervising the addition of definitions and references. Definitions included work on ducts, conduits, conduit systems raceways, overvoltage/transient conditions, shield wires/static wires, flashover/sparkover, sag creep, readily climbable/not readily climbable, and others. Inspection and work rules as related to Rule 13 were clarified. The extensive changes made by Working Group 4.10 on overhead clearances was reviewed and accepted for inclusion in Section 23 as well as in a new Appendix B to the Code. A similar review of the work by Subcommittee 5 led to creation of new Appendix C to cover application of extreme wind loading covered in Rule 250C.

Section 9—Based on extensive studies, steel poles are now permitted as grounding electrodes, and Rule 97G mandates common bonding between communication and power grounding electrodes, with additional information on common bonding given in Rule 99. Metallic water piping systems are no longer a preferred grounding electrode. Changes to Rule 96 clarify ground resistance requirements, and changes to Rule 94B clarify dimensional requirements for ground rods.

Part 1—Selected column headings have been revised for clarity, and inconsistencies in Tables 124-1 and 125-1 corrected.

Part 2—Overhead clearances. A new approach for calculating clearances is detailed in new Section 23 and Appendix B. Rules related to sag calculation for conductor sags as related to clearances were moved from Sections 25 and 26 (loading and strength) into sections covering clearances. All calculations in which both loaded and unloaded conductors involving ice and wind when used for strength calculations remain in Sections 25 and 26. Rule 215C2 was revised to require all guys regardless of exposure to be insulated or grounded. Rules related to guy and span wire insulators moved from Rule 279 to Rule 215C2 to improve subject matter retrieval from the Code. The vertical clearance of a service drop attached to a mast, porch, deck, or balcony has been increased from 2.45 to 3 m (8 to 10 ft). Rule 235G has been changed to allow multiplex line cable up to 750 V to attach to the same support bracket as neutral conductors meeting Rule 230E1.

Part 3—Strength and loading. No modifications were made to Rule 250C to remove the exemption that excludes structures of less than 18 m (60 ft) height from having to meet the extreme wind requirements. The efficacy of doing so will be considered again for the 2012 Edition. Insulator strength ratings and conductor tensions are scheduled for study with possible changes to the 2012 Edition. Specific load factors in Tables 253-1 and 253-2 have been reduced. Tables 253-2 and 261-1B covering alternate load factors and strength factors, respectively, will be phased out in July 2010. They will be replaced by Tables 253-1 and 261-1A that are applicable to all materials. Load and strength factors have been specified for fiber reinforced plastic (FRP) materials, and strength factors for FRP structures, crossarms, and braces have been added. Rules 250A, 253, and 261N have been made more specific in dealing with construction maintenance loads.

Rule 261A2e, which permitted poles of reduced strength to remain in service under the specific condition of being supported by stronger poles on each side of the pole, has been removed. In the long-term view, pole design is tending to move in the direction of Probabilistic Design (LRFD) away from Deterministic Design, a trend which is in concert with a majority of other industries.

Part 3—Rule 311C was added to permit supply and communication cables to be laid directly on grade, providing they do not obstruct traffic or pedestrians and meet other applicable rules. Rule 351C1 was clarified to better describe the limitations of where aboveground pools may be located relative to supply cable, and also state the rule that applies to aboveground pools. It is now recognized that all flammable material transported in pipelines is under some conditions considered hazardous because of location. The Code now requires the same radial separation of 300 mm (12 in) for supply and communication cables from all lines that transport flammable material, not only fuel lines. The rule now defines a flammable liquid.

Part 4—Work revolved largely around expanding guidelines for use of fire resistant (FR) clothing and other safety equipment such as voltage protection devices. These guidelines include arc hazard analysis and reference tables. A new rule was introduced to address high-frequency radiation effects on workers in both the supply and communications spaces arising from communication antennas mounted in those spaces. A new rule requiring phase-to-phase cover-up when guarding against phase-to-phase contact was added. Changes were made to existing minimum approach distance tables. These distances agree with those published in IEEE Std IEEE 516™.<sup>①</sup>

Substantive changes in the 2007 Edition are identified by a bar in the left-hand margin. In several cases, rules have been relocated without substantive changes in the wording. In these cases, only the rule numbers have been indicated as having been changed.

The Institute of Electrical and Electronics Engineers, Inc., was designated as the administrative secretariat for C2 in January 1973, assuming the functions formerly performed by the National Bureau of Standards.

Comments on the rules and suggestions for their improvement are invited, especially from those who have experience in their practical application. In future editions every effort will be made to improve the rules, both in the adequacy of coverage and in the clarification of requirements. Comments should be addressed to:

Secretary  
National Electrical Safety Code Committee  
Institute of Electrical and Electronics Engineers, Inc.  
445 Hoes Lane  
P.O. Box 1331  
Piscataway, NJ 08854-1331

A representative Interpretations Subcommittee has been established to prepare replies to requests for interpretation of the rules contained in the Code. Requests for interpretation should state the rule in question, as well as the conditions under which it is being applied. Interpretations are intended to clarify the intent of specific rules and are not intended to supply consulting information on the application of the Code. Requests for interpretation should be sent to the address above.

If a request is suitable for processing, it will be sent to the Interpretations Subcommittee. After consideration by the committee, which may involve many exchanges of correspondence, the inquirer will be notified of its decision. Decisions are published regularly and may be ordered or accessed online at no cost at <http://standards.ieee.org/nsec>.

The NESC as written is a voluntary standard. However, some editions and some parts of the Code have been adopted, with and without changes, by some state and local jurisdictional authorities. To determine the legal

<sup>①</sup>Information on references can be found in Section 3.

status of the NESC in any particular state or locality within a state, the authority having jurisdiction should be contacted.

The revision cycle for the 2012 Edition of the NESC will be fully electronic. Change proposals and comments will be submitted to the NESC Secretary online via the Internet. For information on how this electronic revision process will take place and for updates and complete information on the NESC, please visit the National Electrical Safety Code Zone on the IEEE Standards Web site at <http://standards.ieee.org/nesc>.

Currently in preview, click buy full version

## Standards Committee Membership

At the time this Code was approved, Accredited Standards Committee C2 had the following membership:

**O. Chuck Amrhyn, Chair**                      **Frank A. Denbrock, Vice Chair**  
**William A. Ash, Secretary**

<i>Organization Represented</i>	<i>Name</i>
Alliance for Telephone Industry Solutions .....	Lawrence M. Slavin
American Insurance Services Group, Inc. ....	Vacant
American Public Power Association .....	Michael J. Hyland Nathan Mitner ( <i>Alt.</i> )
American Public Transit Association .....	Vacant
Association of American Railroads .....	Vacant
Association of Edison Illuminating Companies .....	Doug Mader Billy Maley ( <i>Alt.</i> )
Bonneville Power Administration, US Department of Energy .....	Jerry L. Reding
Canadian Standards Association Liaison Representative .....	David Singleton
Edison Electric Institute .....	David G. Komassa John W. Troglia ( <i>Alt.</i> )
Electronic Industries Association .....	Percy E. Pool Joseph Muccilo ( <i>Alt.</i> )
Independent Electrical Contractors .....	James C. Tuggle Robert W. Baird ( <i>Alt.</i> )
Institute of Electrical and Electronics Engineers, Inc. ....	Frank A. Denbrock Vernon R. Lawson ( <i>Alt.</i> )
International Association of Government Labor Officials .....	Vacant
International Brotherhood of Electrical Workers .....	James R. Tomaseski
International Municipal Signal Association .....	Warren Farrell
National Association of Regulatory Utility Commissioners .....	Vacant
National Cable & Telecommunication Association .....	Rex Bullinger Christopher Austin ( <i>Alt.</i> ) Steve Mace ( <i>Alt.</i> )
National Electrical Contractors Association .....	O. L. Davis Brooke H. Stauffer ( <i>Alt.</i> )
National Electrical Manufacturers Association .....	Vincent Baclawski
National Rural Electric Cooperative Association .....	Robert D. Saint Michael C. Pehosh ( <i>Alt.</i> )
National Safety Council .....	Jeff Clark
National Society of Professional Engineers .....	William F. Fuller
Rural Utilities Service, US Department of Agriculture .....	Robert Lash
Society of Cable Telecommunications Engineers .....	Alan Amato Timothy Cooke ( <i>Alt.</i> )
Tennessee Valley Authority .....	Clayton L. Clem Stephen Cantrell ( <i>Alt.</i> )
Western Area Power Administration, US Department of Energy .....	Vacant
Individual Member .....	O. Chuck Amrhyn
Individual Member .....	Allen L. Clapp
Liaison Representative to Canadian Electrical Code .....	Susan L. Vogel

**Subcommittee 1**  
**Purpose, Scope, Application, Definitions, and References**  
**(Sections 1, 2, and 3)**

**Allen L. Clapp, Chair**

**Charles C. Bleakley, Secretary**

O. Chuck Amrhyn	(Main)	Frank A. Denbrock	(SC5)
Charles C. Bleakley	(SC7)	Allen L. Clapp	(Alt.)
John C. Spence	(Alt.)	Donald E. Hooper	(Interpretations)
D. J. Christofersen	(SC3)	David G. Komassa	(SC4)
Gary R. Engmann	(Alt.)	Eric K. Engdahl	(Alt.)
John B. Dagenhart	(SC2)	James R. Tomaseski	(SC8)
Ewell T. Robeson	(Alt.)	J. David Mitchell	(Alt.)

**Subcommittee 2**  
**Grounding Methods**  
**(Section 9)**

**John B. Dagenhart, Chair**

**Ewell T. Robeson, Secretary**

J. Boksiner	ATIS	Robert Molde	EI
Harvey L. Bowles	RUS	Michael A. Moore	APPA
A. C. Channaiah	SEEX	Percy E. Pool	EIA
Keith Reese	(Alt.)	Joseph Muccillo	(Alt.)
John B. Dagenhart	IEEE	Ewell T. Robeson	EI
M. M. Dixon	EI	Robert D. Saint	NRECA
L. E. Gaunt	(Alt.)	Michael C. Enosh	(Alt.)
William J. Turner	(Alt.)	James R. Tomaseski	IBEW
N. Maxwell	NARUC	Donald W. Zipse	IEEE

**Subcommittee 3**  
**Electric Supply Stations**  
**(Sections 10–19)**

**D. J. Christofersen, Chair**

**Gary R. Engmann, Secretary**

D. J. Christofersen	IEEE	Mark A. Konz	SEEX
A. L. Comans	AEIC	Christopher A. Carson	(Alt.)
W. Bruce Dietzman	IEEE	Robert E. Sipler, Jr.	NARUC
Gary R. Engmann	IEEE	James R. Tomaseski	IBEW
Keith C. Harrison	NRECA	Philip Young	EI
Robert D. Saint	(Alt.)	George Zaczek	APPA
S. J. Kollmann	EI		
Brian Winick	(Alt.)		

AAR—Association of American Railroads  
 AEIC—Association of Edison Illuminating Companies  
 AIG—American Insurance Services Group, Inc.  
 AISI—American Iron and Steel Institute  
 APPA—American Public Power Association  
 APWA—American Public Transit Association  
 ATIS—Alliance for Telephone Industry Solutions  
 AWWA—American Wood Preserves Association  
 BPA—Bonneville Power Admin., US Dept. of Energy  
 EEI—Edison Electric Institute  
 EIA—Electronic Industries Association  
 IAGLO—Int'l. Assoc. of Government Labor Officials

IBEW—International Brotherhood of Electrical Workers  
 IEEE—Institute of Electrical and Electronics Engineers, Inc.  
 IMSA—International Municipal Signal Association  
 NARUC—National Association of Regulatory Utility Commissioners  
 NCTA—National Cable Television Association  
 NECA—National Electrical Contractors Association  
 NEMA—National Electrical Manufacturers Association  
 NSC—National Safety Council  
 NSPE—National Society of Professional Engineers  
 RUS—Rural Utilities Services, US Dept. of Agriculture  
 SEEX—Southeastern Electric Exchange  
 TVA—Tennessee Valley Authority  
 WAPA—Western Area Power Administration, US Dept. of Energy

**Subcommittee 4**  
**Overhead Lines—Clearances**  
**(Section 20, 21, 22, and 23)**

**David G. Komassa, Chair**

O. Chuck Amrhyh	Self
Chris Austin	NCTA
Rex Bullinger	(Alt.)
Steve Mace	(Alt.)
R. J. Bednarz	Self
Charles C. Bleakley	AEIC
Keith Reese	(Alt.)
James. L. Bohlk	RUS
Allen L. Clapp	Self
Charles Crawford	NSPE
Thomas R. Crowell	EI
Phillip S. Givens	(Alt.)
Kevin Drzewiecki	EI
Chris Ann Sheller	(Alt.)
Eric K. Engdahl	EI
Tracy Dencker	(Alt.)
Mickey B. Gunter	EI
Andrew Metrick	(Alt.)
Dennis Henry	ATIS
Trevor Bowmer	(Alt.)
Donald E. Hooper	Self

**Eric K. Engdahl, Secretary**

Jan Howard	APPA
H. N. Johnson, Jr.	SEEX
Joseph J. White	(Alt.)
David G. Komassa	EI
David J. Marne	NSPE
Ernest H. Neubauer	NREC
Michael C. Pehosh	(Alt.)
Robert G. Oswald	IEE
Oliver W. Perkins	WAPA
Jerry L. Reding	BP
Joseph Renowden	Emeritus
James Ruehl	NARUC
Mathew C. Schwarz	IEEE
Lawrence M. Slavin	ATIS
R. H. Stevens	Self
James R. Tomaseski	IBEW
B. J. Washburn	NARUC
Alan T. Young	EIA
Joseph Muccilo	(Alt.)
David C. Young	EI

**Subcommittee 5**  
**Overhead Lines—Strength and Loading**  
**(Sections 24, 25, 26, and 27)**

**Frank A. Denbrock, Chair**

Julian Ajello	NARUC
Alan J. Amato	SCITE
Ted S. Woo	(Alt.)
Nelson G. Bingel	AWPA
Rex Bullinger	NCTA
Chris Austin	(Alt.)
Steve Mace	(Alt.)
John Busel	ACMA
Brian Lacoursiere	(Alt.)
Daniel Lonergan	(Alt.)
Jim Byrne	NRECA
Michael C. Pehosh	(Alt.)
Helen Chen	AISI
Richard A. Clapper	(Alt.)
Allen L. Clapp	Self
Clayton L. Clem	TVA
Frank A. Denbrock	IEEE
Bruce Freeman	EI
Robert S. Fuller	NSPE
Douglas Hanson	WAPA
Terry Burley	(Alt.)

**Allen L. Clapp, Secretary**

Edward Harrel	EI
Donald G. Heald	RUS
Robert Lash	(Alt.)
Richard W. Hensel	IEEE
Walter D. Jones	IEEE
Leon Kempner, Jr.	BPA
Jim Kinghorn	NCEMC
Jacob Joplin	(Alt.)
Robert O. Kluge	EI
Joseph Muccilo	EIA
Alan T. Young	(Alt.)
Robert C. Peters	IEEE
Joseph Rempé	APPA
Andrew Schwalm	IEEE
Wade Shultz	SEEX
Ron Corzine	(Alt.)
Lawrence M. Slavin	ATIS
Richard J. Standford	EI
Jose L. Vivas	EI
Jerry C. Wong	EI

**Subcommittee 7  
Underground Lines  
(Sections 30–39)**

**Charles C. Bleakley, Chair**

Alan J. Amato  
O. Chuck Amrhyn  
Chris Austin  
    Steve Mace  
    Rex Bullinger  
Charles C. Bleakley  
Mickey B. Gunter  
Michael L. Dyer  
R. A. Fernandez  
    Percy E. Pool  
Lauren E. Gaunt  
Dennis Henry  
    Trevor Bowmer  
Trung Hiu

SCTE  
    Self  
NCTA  
    (Alt.)  
    (Alt.)  
SEEX  
    (Alt.)  
APPA  
    EIA  
    (Alt.)  
    EEI  
ATIS  
    (Alt.)  
RUS

David H. Kendall  
James D. Mars  
Andrew Metrick  
Dennis B. Miller  
Michael C. Pehosh  
    Robert D. Saint  
George S. Pristach  
Ewell T. Robeson  
Lawrence M. Slavin  
John C. Spence  
Monte Szendre  
James R. Tomaseski  
Richard Vencus  
Ted S. Woo

**John C. Spence, Secretary**

NEMA  
    Self  
    EEI  
    EEI  
NRECA  
    (Alt.)  
AFTA  
IEE  
ATIS  
EEI  
NEMA  
IBEW  
IEEE  
SCTE

**Subcommittee 8  
Work Rules  
(Sections 40–44)**

**James R. Tomaseski, Chair**

Wayne P. Blackley  
F. M. Brooks  
Kenneth Brubaker  
    Mark Zavislan  
J. F. Doering  
Brian Erga  
Robert A. Fass  
    Maury Dunn  
Michael Granata  
C. W. Grose  
Dennis Henry  
    Trevor Bowmer  
Edward Hunt  
Henry J. Kientz  
    Jeffrey Wild  
Brent McKinney  
J. D. Mitchell  
    Thomas Verdecchia

ATC  
NSPE  
NRECA  
    (Alt.)  
    Self  
NWPPA  
    EIA  
    (Alt.)  
    EEI  
    Self  
ATIS  
    (Alt.)  
WAPA  
    Self  
    (Alt.)  
APPA  
IEEE  
    (Alt.)

Stephen Pouloski  
Thomas Under  
Lawrence Schweitzer  
Albert Smoak  
Samuel Stonerock  
Steven Theis  
James R. Tomaseski  
Gene Tootle  
    David J. Nagy  
D. M. Wallis  
Jeffery A. White  
    William C. Weintritt  
Chuck Woodings  
    James C. Tuggle  
    Robert W. Baird

**J. David Mitchell, Secretary**

NECA  
    EIA  
    IEEE  
    NSPE  
    EEI  
NUCA  
IBEW  
SEEX  
    (Alt.)  
OSHA  
AEIC  
    (Alt.)  
IEC  
    (Alt.)  
    (Alt.)

**Executive Subcommittee**

**O. Chuck Amrhyn, Chair**

O. Chuck Amrhyn  
Frank A. Denbrock  
Michael J. Hyland

Self  
IEEE  
APPA

Leon Kempner  
Lawrence M. Slavin  
James R. Tomaseski

**Frank A. Denbrock, Vice Chair**

BPA  
ATIS  
IBEW

Jennie M. Steinhagen  
*IEEE Standards Project Editor*

## Interpretations Subcommittee

### Donald E. Hooper, *Chair*

O. Chuck Amrhyn	A	Mickey B. Gunter	P2, P3
R. J. Bednarz	A	Donald E. Hooper	A
Charles C. Bleakley	A	Herman N. Johnson, Jr.	A
D. J. Christofersen	P1	Henry J. Kientz	P4
Allen L. Clapp	A	Robert G. Oswald	P2
John B. Dagenhart	P2, S9	Percy E. Pool	P3, S9
O. L. Davis	P3	Wayne B. Roelle	P2
Frank A. Denbrock	A	Lanny L. Smith	A
Gary R. Engmann	P1	James R. Tomaseski	A
Emerson W. Glancy	A	David C. Young	A
Charles W. Grose	P4		

A = All areas, P1 = Part 1, P2 = Part 2, P3 = Part 3, P4 = Part 4, S9 = Section 9

# Contents

<i>Section</i>	<i>Page</i>
Letter symbols for units .....	xxxiii
Sec. 1. Introduction to the National Electrical Safety Code	
010. Purpose.....	1
011. Scope.....	1
012. General rules .....	1
013. Application.....	1
A. New installations and extensions .....	1
B. Existing installations .....	2
014. Waiver.....	2
A. Emergency installations.....	2
B. Temporary overhead installations .....	2
015. Intent .....	2
016. Effective date .....	3
017. Units of measure .....	3
018. Method of calculation .....	4
Sec. 2. Definitions of special terms .....	5
Sec. 3. References .....	5
Sec. 9. Grounding methods for electric supply and communications facilities	
090. Purpose.....	17
091. Scope.....	17
092. Point of connection of grounding conductor .....	17
A. Direct-current systems that are to be grounded .....	17
1. 750 V and below .....	17
2. Over 750 V.....	17
B. Alternating current systems that are to be grounded .....	17
1. 750 V and below .....	17
2. Over 750 V .....	17
3. Separate grounding conductor .....	18
C. Messenger wires and guys .....	18
1. Messenger wires .....	18
2. Guys.....	18
3. Common grounding of messengers and guys on the same supporting structure .....	18
D. Current in grounding conductor .....	19
E. Fences .....	19
093. Grounding conductor and means of connection .....	20
A. Composition of grounding conductors .....	20
B. Connection of grounding conductors .....	20
C. Ampacity and strength .....	20
1. System grounding conductors for single-grounded systems .....	20
2. System grounding conductors for multi-grounded alternating current systems .....	20
3. Grounding conductors for instrument transformers .....	20
4. Grounding conductors for primary surge arresters .....	21
5. Grounding conductors for equipment, messenger wires, and guys .....	21
6. Fences .....	21
7. Bonding of equipment frames and enclosures .....	21
8. Ampacity limit.....	21

## Contents

<i>Section</i>	<i>Page</i>
9. Strength.....	21
D. Guarding and protection .....	21
E. Underground .....	22
F. Common grounding conductor for circuits, metal raceways, and equipment .....	22
094. Grounding electrodes .....	22
A. Existing electrodes .....	22
1. Metallic water piping system .....	23
2. Local systems .....	23
3. Steel reinforcing bars in concrete foundations and footings .....	23
B. Made electrodes .....	23
1. General .....	23
2. Driven rods .....	23
3. Buried wire, strips, or plates .....	24
4. Pole-butt plates and wire wraps .....	24
5. Concentric neutral cable .....	24
6. Concrete-encased electrodes .....	25
7. Directly embedded metal poles .....	25
095. Method of connection to electrode .....	25
A. Ground connections .....	25
B. Point of connection to piping systems .....	26
C. Contact surfaces .....	26
096. Ground resistance requirements.....	26
A. General .....	26
B. Supply stations .....	26
C. Multi-grounded systems .....	27
D. Single-grounded (unigrounded or delta) systems .....	27
097. Separation of grounding conductors .....	27
098. Number 098 not used in this edition.....	28
099. Additional requirements for grounding and bonding of communication apparatus .....	28
A. Electrode .....	28
B. Electrode connection .....	29
C. Bonding of electrodes .....	29

### **Part 1. Rules for the Installation and Maintenance of Electric Supply Stations and Equipment**

Sec. 10. Purpose and scope of rules.....	31
100. Purpose .....	31
101. Scope .....	31
102. Application of rules .....	31
103. Referenced sections .....	31
Sec. 11. Protective arrangements in electric supply stations .....	32
110. General requirements .....	32
A. Enclosure of equipment .....	32
1. Types of enclosures .....	32
2. Safety clearance zone .....	32
B. Rooms and spaces .....	32
1. Construction .....	32
2. Use .....	32
3. Ventilation .....	33
4. Moisture and weather .....	33
C. Electric equipment .....	33

## Contents

<i>Section</i>	<i>Page</i>
111. Illumination.....	34
A. Under normal conditions .....	34
B. Emergency lighting .....	34
C. Fixtures .....	34
D. Attachment plugs and receptacles for general use .....	35
E. Receptacles in damp or wet locations .....	35
112. Floors, floor openings, passageways, and stairs .....	37
A. Floors .....	37
B. Passageways .....	37
C. Railings .....	37
D. Stair guards .....	37
E. Top rails .....	37
113. Exits .....	37
A. Clear exits.....	37
B. Double exits.....	37
C. Exit doors .....	38
114. Fire-extinguishing equipment .....	38
Sec. 12. Installation and maintenance of equipment.....	39
120. General requirements .....	39
121. Inspections .....	39
A. In-service equipment .....	39
B. Idle equipment .....	39
C. Emergency equipment .....	39
D. New equipment .....	39
122. Guarding shaft ends, pulleys, belts, and suddenly moving parts .....	39
A. Mechanical transmission machinery .....	39
B. Suddenly moving parts .....	39
123. Protective grounding.....	39
A. Protective grounding or physical isolation of non-current-carrying metal parts .....	39
B. Grounding method .....	40
C. Provision for grounding equipment during maintenance .....	40
D. Grounding methods for direct-current systems over 750 V .....	40
124. Guarding live parts.....	40
A. Where required .....	40
B. Strength of guards .....	40
C. Types of guards .....	40
1. Location or physical isolation .....	40
2. Shields or enclosures .....	41
3. Supplemental barriers or guards within electric supply stations .....	41
4. Mats .....	41
5. Live parts below supporting surfaces for persons .....	41
6. Insulating covering on conductors or parts .....	41
125. Working space about electric equipment.....	51
A. Working space (600 V or less) .....	51
1. Clear spaces .....	51
2. Access and entrance to working space .....	51
3. Working space .....	52
4. Headroom working space .....	52
5. Front working space .....	52
B. Working space over 600 V .....	52
126. Equipment for work on energized parts.....	52
127. Classified locations .....	52
A. Coal-handling areas .....	53

## Contents

<i>Section</i>	<i>Page</i>
B. Flammable and combustible liquids .....	53
C. Flammable liquid storage area.....	54
D. Loading and unloading facilities for flammable and combustible liquids .....	54
E. Gasoline-dispensing stations .....	54
F. Boilers .....	54
G. Gaseous hydrogen systems for supply equipment .....	54
H. Liquid hydrogen systems .....	54
I. Sulfur .....	55
J. Oxygen .....	55
K. Liquefied petroleum gas (LPG) .....	55
L. Natural gas (methane) .....	55
128. Identification .....	55
129. Mobile hydrogen equipment.....	55
Sec. 13. Rotating equipment .....	56
130. Speed control and stopping devices.....	56
A. Automatic overspeed trip device for prime movers .....	56
B. Manual stopping devices .....	56
C. Speed limit for motors .....	56
D. Number 130D not used in this edition .....	56
E. Adjustable-speed motors .....	56
F. Protection of control circuits .....	56
131. Motor control .....	56
132. Number 132 not used in this edition.....	57
133. Short-circuit protection .....	57
Sec. 14. Storage batteries .....	58
140. General.....	58
141. Location .....	58
142. Ventilation.....	58
143. Racks.....	58
144. Floors in battery areas.....	58
145. Illumination for battery areas.....	58
146. Service facilities.....	58
Sec. 15. Transformers and regulators .....	60
150. Current-transformer secondary circuits protection when exceeding 600 V .....	60
151. Grounding secondary circuits of instrument transformers.....	60
152. Location and arrangement of power transformers and regulators .....	60
A. Outdoor installations .....	60
B. Indoor installations .....	60
153. Short-circuit protection of power transformers.....	61
Sec. 16. Conductors .....	62
160. Application.....	62
161. Electrical protection .....	62
A. Overcurrent protection required .....	62
B. Grounded conductors .....	62
C. Insulated power cables .....	62
162. Mechanical protection and support.....	62
163. Isolation.....	62
164. Conductor terminations.....	62
A. Insulation .....	62
B. Metal-sheathed or shielded cable .....	62

## Contents

<i>Section</i>	<i>Page</i>
Sec. 17. Circuit breakers, reclosers, switches, and fuses .....	63
170. Arrangement .....	63
171. Application.....	63
172. Circuit breakers, reclosers, and switches containing oil .....	63
173. Switches and disconnecting devices .....	63
A. Capacity .....	63
B. Provisions for disconnecting .....	63
174. Disconnection of fuses.....	63
Sec. 18. Switchgear and metal-enclosed bus .....	65
180. Switchgear assemblies .....	65
A. General requirements for all switchgear .....	65
B. Metal-enclosed power switchgear .....	65
C. Dead-front power switchboards .....	66
D. Motor control centers .....	66
E. Control switchboards.....	66
181. Metal-enclosed bus .....	66
A. General requirements for all types of bus .....	66
B. Isolated-phase bus .....	67
Sec. 19. Surge arresters.....	68
190. General requirements.....	68
191. Indoor locations .....	68
192. Grounding conductors.....	68
193. Installation.....	68
<b>Part 2. Safety Rules for the Installation and Maintenance of Overhead Electric Supply and Communication Lines</b>	
Sec. 20. Purpose, scope, and application of rules .....	69
200. Purpose.....	69
201. Scope.....	69
202. Application of rules.....	69
Sec. 21. General requirements .....	70
210. Referenced sections .....	70
211. Number 211 not used in this edition. ....	70
212. Induced voltages .....	70
213. Accessibility.....	70
214. Inspection and tests of lines and equipment .....	70
A. When in service .....	70
1. Initial compliance with rules .....	70
2. Inspection .....	70
3. Tests .....	70
4. Record of defects .....	70
5. Remedying defects .....	70
B. When out of service.....	71
1. Lines infrequently used .....	71
2. Lines temporarily out of service .....	71
3. Lines permanently abandoned .....	71
215. Grounding of circuits, supporting structures, and equipment.....	71
A. Methods .....	71
B. Circuits .....	71
1. Common neutral .....	71

## Contents

<i>Section</i>	<i>Page</i>
2. Other neutrals .....	71
3. Other conductors.....	71
4. Surge arresters .....	71
5. Use of earth as part of circuit .....	71
C. Non-current-carrying parts .....	71
1. General .....	71
2. Anchor guys and span guys .....	72
3. Span wires carrying luminaires or traffic signals .....	72
4. Span wires carrying trolley or electric railway contact conductors .....	72
5. Use of insulators in anchor guys, span guys, and span wires supporting luminaires or traffic signals .....	72
6. Use of insulators in span wires supporting trolley or electric railroad contact conductors .....	72
7. Insulators used to limit galvanic corrosion .....	72
8. Multiple messengers on the same structure .....	73
216. Arrangement of switches .....	73
A. Accessibility .....	73
B. Indicating open or closed position .....	73
C. Locking .....	73
D. Uniform position .....	73
E. Remotely controlled, automatic transmission, or distribution overhead line switching devices.....	73
217. General.....	73
A. Supporting structures .....	73
1. Protection of structures.....	73
2. Readily climbable supporting structures .....	73
3. Identification .....	74
4. Obstructions .....	74
5. Decorative lighting .....	74
B. Unusual conductor supports .....	74
C. Protection and marking of guys .....	74
218. Vegetation management.....	75
A. General .....	75
B. At line crossings, railroad crossings and limited-access highway crossings.....	75
Sec. 22. Relations between various classes of lines and equipment.....	76
220. Relative levels.....	76
A. Standardization of levels .....	76
B. Relative levels: supply and communication conductors .....	76
1. Preferred levels .....	76
2. Special construction for supply circuits, the voltage of which is 600 V or less and carrying power not in excess of 5 kW .....	76
C. Relative levels: Supply lines of different voltage classifications (0 to 750 V, over 750 V to 8.7 kV, over 8.7 kV to 22 kV, and over 22 kV to 50 kV) .....	77
1. At crossings or conflicts .....	77
2. On structures used only by supply conductors .....	77
D. Identification of overhead conductors .....	77
E. Identification of equipment on supporting structures.....	77
221. Avoidance of conflict.....	77
222. Joint use of structures.....	77
223. Communications protective requirements .....	78
A. Where required .....	78
B. Means of protection .....	78

## Contents

Section	Page
224. Communication circuits located within the supply space and supply circuits	
located within the communication space.....	78
A. Communication circuits located in the supply space .....	78
B. Supply circuits used exclusively in the operation of communication circuits .....	79
225. Electric railway construction .....	79
A. Trolley-contact conductor fastenings .....	79
B. High-voltage contact conductors .....	80
C. Third rails .....	80
D. Prevention of loss of contact at railroad crossings at grade .....	80
E. Guards under bridges .....	80
Sec. 23. Clearances .....	81
230. General.....	81
A. Application .....	81
1. Permanent and temporary installations .....	81
2. Emergency installations .....	81
3. Measurement of clearance and spacing .....	81
4. Rounding of calculation results .....	82
B. Ice and wind loading for clearances .....	82
C. Supply cables.....	83
D. Covered conductors .....	83
E. Neutral conductors .....	83
F. Fiber-optic cable .....	83
1. Fiber-optic—supply cable .....	83
2. Fiber-optic—communication cable .....	84
G. Alternating- and direct-current circuits .....	84
H. Constant-current circuits .....	84
I. Maintenance of clearances and spacings .....	84
231. Clearances of supporting structures from other objects.....	85
A. From fire hydrants .....	85
B. From streets, roads, and highways .....	86
C. From railroad tracks .....	86
232. Vertical clearances of wires, conductors, cables, and equipment	
above ground, roadway, rail, or water surfaces.....	86
A. Application .....	86
B. Clearance of wires, conductors, cables, equipment, and support arms	
mounted on supporting structures .....	87
1. Clearance to wires, conductors, and cables .....	87
2. Clearance to unguarded rigid live parts of equipment .....	87
3. Clearance to support arms, switch handles, and equipment cases.....	87
4. Street and area lighting .....	87
C. Additional clearances for wires, conductors, cables, and unguarded rigid live parts	
of equipment .....	87
1. Voltages exceeding 22 kV .....	87
D. Alternate clearances for voltages exceeding 98 kV ac to ground or	
139 kV dc to ground .....	88
1. Sag conditions of line conductors .....	88
2. Reference heights .....	88
3. Electrical component of clearance .....	88
4. Limit .....	88
233. Clearances between wires, conductors, and cables carried on	
different supporting structures .....	98
A. General .....	98
1. Conductor movement envelope .....	99

## Contents

<i>Section</i>	<i>Page</i>
2. Clearance envelope .....	99
B. Horizontal clearance .....	99
1. Clearance requirements .....	99
2. Alternate clearances for voltages exceeding 98 kV ac to ground or 139 kV dc to ground .....	99
C. Vertical clearance .....	99
1. Clearance requirements .....	99
2. Voltages exceeding 22 kV .....	100
3. Alternate clearances for voltage exceeding 98 kV ac to ground or 139 kV dc to ground.....	100
234. Clearance of wires, conductors, cables, and equipment from buildings, bridges, rail cars, swimming pools, and other installations.....	109
A. Application .....	109
1. Vertical and horizontal clearances (no wind displacement).....	109
2. Horizontal clearances (with wind displacement) .....	110
3. Transition between horizontal and vertical clearances .....	110
B. Clearances of wires, conductors, and cables from other supporting structures .....	110
1. Horizontal clearances .....	110
2. Vertical clearances .....	111
C. Clearances of wires, conductors, cables, and rigid live parts from buildings, signs, billboards, chimneys, radio and television antennas, tanks, and other installations except bridges .....	111
1. Vertical and horizontal clearances .....	111
2. Guarding of supply conductors and rigid live parts.....	112
3. Supply conductors attached to buildings or other installations .....	112
4. Communication conductors attached to buildings or other installations .....	113
5. Ladder space .....	113
D. Clearance of wires, conductors, cables, and unguarded rigid live parts from bridges .....	113
1. Vertical and horizontal clearances .....	113
2. Guarding trolley-contact conductors located under bridges.....	114
E. Clearance of wires, conductors, cables, or unguarded rigid live parts installed over or near swimming areas with no wind displacement.....	114
1. Swimming pools .....	114
2. Beaches and waterways restricted to swimming .....	114
3. Waterways subject to water skiing .....	114
F. Clearances of wires, conductors, cables, and rigid live parts from grain bins .....	114
1. Grain bins loaded by permanently installed augers, conveyers, or elevator systems.....	114
2. Grain bins loaded by portable augers, conveyers, or elevators (with no wind displacement) .....	114
G. Additional clearances for voltages exceeding 22 kV for wires, conductors, cables, and unguarded rigid live parts of equipment .....	115
H. Alternate clearances for voltages exceeding 98 kV ac to ground or 139 kV dc to ground .....	115
1. Sag conditions of line conductors .....	115
2. Reference distances .....	115
3. Electrical component of clearance .....	115
4. Limit .....	116
I. Clearance of wires, conductors, and cables to rail cars .....	116
J. Clearance of equipment mounted on supporting structures .....	116
1. Clearance to unguarded rigid live parts of equipment .....	116
2. Clearance to equipment cases .....	116
235. Clearance for wires, conductors, or cables carried on the same supporting structure.....	134
A. Application of rule .....	134

## Contents

<i>Section</i>	<i>Page</i>
1. Multiconductor wires or cables .....	134
2. Conductors supported by messengers or span wires .....	134
3. Line conductors of different circuits.....	134
B. Horizontal clearance between line conductors .....	135
1. Fixed supports .....	135
2. Suspension insulators .....	136
3. Alternate clearances for different circuits where one or both circuits exceed 98 kV ac to ground or 139 kV dc to ground .....	136
C. Vertical clearance between line conductors .....	137
1. Basic clearance for conductors of same or different circuits .....	137
2. Additional clearances .....	137
3. Alternate clearances for different circuits where one or both exceed 98 kV ac, or 139 kV dc to ground .....	139
4. Communication worker safety zone .....	139
D. Diagonal clearance between line wires, conductors, and cables located at different levels on the same supporting structure .....	140
E. Clearances in any direction from line conductors to supports, and to vertical or lateral conductors, span, or guy wires attached to the same support .....	140
1. Fixed supports .....	140
2. Suspension insulators .....	140
3. Alternate clearances for voltages exceeding 98 kV ac to ground or 139 kV dc to ground .....	140
F. Clearances between circuits of different voltage classifications located in the supply space on the same support arm .....	141
G. Conductor spacing: vertical racks or separate brackets .....	141
H. Clearance and spacing between communication conductors, cables, and equipment .....	142
I. Clearances in any direction from supply line conductors to communication antennas in the supply space attached to the same supporting structure .....	142
1. General .....	142
2. Communication antenna.....	142
3. Equipment case that supports a communication antenna .....	142
4. Vertical or lateral communication conductors and cables attached to a communication antenna.....	142
236. Climbing space.....	158
A. Location and dimensions.....	158
B. Portions of supporting structures in climbing space.....	158
C. Support arm location relative to climbing space .....	158
D. Location of equipment relative to climbing space .....	158
E. Climbing space between conductors .....	159
F. Climbing space on buckarm construction .....	159
G. Climbing space past longitudinal runs not on support arms .....	159
H. Climbing space past vertical conductors .....	160
I. Climbing space near ridge-pin conductors .....	160
237. Working space .....	162
A. Location of working spaces.....	162
B. Dimensions of working spaces .....	162
1. Along the support arm .....	162
2. At right angles to the support arm .....	162
3. Vertically .....	162
C. Location of vertical and lateral conductors relative to working spaces .....	162
D. Location of buckarms relative to working spaces .....	162
1. Standard height of working space .....	162
2. Reduced height of working space.....	162
E. Guarding of energized equipment .....	162

## Contents

<i>Section</i>	<i>Page</i>
F. Working clearances from energized equipment .....	163
238. Vertical clearance between certain communications and supply facilities located on the same structure .....	163
A. Equipment .....	163
B. Clearances in general.....	163
C. Clearances for span wires or brackets .....	163
D. Clearance of drip loops of luminaire or traffic signal brackets .....	163
E. Communication worker safety zone .....	163
239. Clearance of vertical and lateral facilities from other facilities and surfaces on the same supporting structure .....	165
A. General .....	165
B. Location of vertical or lateral conductors relative to climbing spaces, working spaces, and pole steps.....	165
C. Conductors not in conduit .....	165
D. Guarding and protection near ground .....	166
E. Requirements for vertical and lateral supply conductors on supply line structures or within supply space on jointly used structures .....	166
1. General clearances .....	166
2. Special cases .....	166
F. Requirements for vertical and lateral communication conductors on communication line structures or within the communication space on jointly used structures .....	166
1. Clearances from communication conductors .....	166
2. Clearances from supply conductors.....	166
G. Requirements for vertical supply conductors and cables passing through communication space on jointly used line structures .....	167
1. Guarding—General .....	167
2. Cables and conductors in conduit or covering.....	167
3. Protection near trolley, ungrounded traffic signal, or ungrounded luminaire attachments.....	167
4. Aerial services .....	167
5. Clearance from through bolts and other metal objects .....	167
H. Requirements for vertical communication conductors passing through supply space on jointly used structures .....	168
1. Metal-sheathed communication cables .....	168
2. Communication conductors .....	168
3. Communication grounding conductors .....	168
4. Clearance from through bolts and other metal objects .....	168
I. Operating rods.....	168
J. Additional rules for standoff brackets .....	168
Sec. 24. Grades of construction .....	171
240. General.....	171
241. Application of grades of construction to different situations.....	171
A. Supply cables .....	171
B. Order of grades .....	171
C. At crossings .....	171
1. Grade of upper line .....	171
2. Grade of lower line .....	171
3. Multiple crossings.....	171
D. Conflicts .....	171
242. Grades of construction for conductors.....	172
A. Constant-current circuit conductors .....	172
B. Railway feeder and trolley-contact circuit conductors.....	172
C. Communication circuit conductors located in the supply space .....	172

## Contents

<i>Section</i>	<i>Page</i>
D. Fire-alarm circuit conductors .....	172
E. Neutral conductors of supply circuits .....	172
F. Surge-protection wires .....	172
243. Grades of construction for line supports .....	176
A. Structures .....	176
B. Crossarms and support arms .....	176
C. Pins, armless construction brackets, insulators, and conductor fastenings .....	176
Sec. 25. Loadings for Grades B and C .....	177
250. General loading requirements and maps .....	177
A. General .....	177
B. Combined ice and wind district loading .....	177
C. Extreme wind loading .....	177
1. Velocity pressure exposure coefficient, $k_z$ .....	178
2. Gust response factor, $G_{RF}$ .....	178
D. Extreme ice with concurrent wind loading .....	179
251. Conductor loading .....	193
A. General .....	193
B. Load components .....	193
1. Vertical load component .....	193
2. Horizontal load component .....	193
3. Total load .....	194
252. Loads on line supports .....	194
A. Assumed vertical loads .....	194
B. Assumed transverse loads .....	194
1. Transverse loads from conductors and messengers .....	194
2. Wind loads on structures .....	194
3. At angles .....	195
4. Span lengths .....	195
C. Assumed longitudinal loading .....	195
1. Change in grade of construction .....	195
2. Jointly used poles at crossings over railroads, communication lines, or limited access highways .....	195
3. Deadends .....	195
4. Unequal spans and unequal vertical loads .....	196
5. Stringing loads .....	196
6. Longitudinal capability .....	196
7. Communication conductors on unguyed supports at railroad and limited access highway crossings .....	196
D. Simultaneous application of loads .....	196
253. Load factors for structures, crossarms, support hardware, guys, foundations, and anchors .....	196
Sec. 26. Strength requirements .....	199
260. General .....	199
A. Preliminary assumptions .....	199
B. Application of strength factors .....	199
261. Grades B and C construction .....	199
A. Supporting structures .....	199
1. Metal, prestressed-, and reinforced-concrete structures .....	200
2. Wood structures .....	200
3. Fiber-reinforced polymer structures .....	201
4. Transverse strength requirements for structures where side guying is required, but can be installed only at a distance .....	201

## Contents

<i>Section</i>	<i>Page</i>
5. Longitudinal strength requirements for sections of higher grade in lines of a lower grade construction.....	201
B. Strength of foundations, settings, and guy anchors.....	202
C. Strength of guys and guy insulators .....	202
1. Metal and prestressed-concrete structures .....	202
2. Wood and reinforced-concrete structures.....	202
3. Fiber-reinforced polymer structures .....	202
D. Crossarms and braces.....	202
1. Concrete and metal crossarms and braces .....	202
2. Wood crossarms and braces.....	202
3. Fiber-reinforced polymer crossarms and braces .....	203
4. Crossarms and braces of other materials .....	203
5. Additional requirements.....	203
E. Insulators .....	203
F. Strength of pin-type or similar construction and conductor fastenings .....	204
1. Longitudinal strength .....	204
2. Double pins and conductor fastenings .....	204
3. Single supports used in lieu of double wood pins .....	204
G. Armless construction .....	204
1. General .....	204
2. Insulating material .....	204
3. Other components .....	204
H. Open supply conductors and overhead shield wires .....	204
1. Tensions .....	204
2. Splices, taps, dead-end fittings, and associated attachment hardware .....	205
3. Trolley-contact conductors .....	205
I. Supply cable messengers .....	205
J. Open-wire communication conductors.....	205
K. Communication cables .....	205
1. Communication cables .....	205
2. Messenger.....	205
L. Paired communication conductors.....	206
1. Paired conductors supported on messenger .....	206
2. Paired conductors not supported on messenger .....	206
M. Support and attachment hardware .....	206
N. Climbing and working steps and their attachments to the structure .....	206
262. Number 262 not used in this edition.....	209
263. Grade N construction .....	209
A. Poles .....	209
B. Guys.....	209
C. Crossarm strength.....	209
D. Supply-line conductors .....	209
1. Size .....	209
E. Service drops .....	209
1. Size of open-wire service drops.....	209
2. Tension of open-wire service drops .....	209
3. Cabled service drops .....	209
F. Trolley-contact conductors .....	210
G. Communication conductors .....	210
H. Street and area lighting equipment .....	210
I. Insulators.....	210
264. Guying and bracing.....	211
A. Where used .....	211
B. Strength .....	211

## Contents

<i>Section</i>	<i>Page</i>
C. Point of attachment.....	211
D. Guy fastenings .....	212
E. Electrolysis .....	212
F. Anchor rods.....	212
Sec. 27. Line insulation.....	213
270. Application of rule .....	213
271. Material and marking.....	213
272. Ratio of flashover to puncture voltage.....	213
273. Insulation level.....	213
274. Factory tests .....	214
275. Special insulator applications .....	214
A. Insulators for constant-current circuits.....	214
B. Insulators for single-phase circuits directly connected to three-phase circuits .....	214
276. Number 276 not used in this edition. ....	214
277. Mechanical strength of insulators .....	214
278. Aerial cable systems .....	215
A. Electrical requirements.....	215
B. Mechanical requirements .....	215
279. Guy and span insulators .....	215
A. Insulators .....	215
1. Properties of guy insulators .....	215
2. Galvanic corrosion and BIL insulation.....	216
B. Properties of span-wire insulators .....	216
1. Material.....	216
2. Insulation level .....	216
3. Mechanical strength.....	216
Sec. 28. Section number 28 not used in this edition. ....	217
Sec. 29. Section number 29 not used in this edition. ....	217
 <b>Part 3. Safety Rules for the Installation and Maintenance of Underground Electric Supply and Communication Lines</b>	
Sec. 30. Purpose, scope, and application of rules .....	219
300. Purpose.....	219
301. Scope.....	219
302. Application of rules.....	219
Sec. 31. General requirements applying to underground lines .....	220
310. Referenced sections .....	220
311. Installation and maintenance.....	220
312. Accessibility.....	220
313. Inspection and tests of lines and equipment .....	220
A. When in service .....	220
1. Initial compliance with safety rules.....	220
2. Inspection .....	220
3. Tests .....	220
4. Record of defects .....	220
5. Remedying defects .....	220
B. When out of service .....	220
1. Lines infrequently used .....	220
2. Lines temporarily out of service.....	220
3. Lines permanently abandoned .....	221
314. Grounding of circuits and equipment .....	221

## Contents

<i>Section</i>	<i>Page</i>
A. Methods .....	221
B. Conductive parts to be grounded .....	221
C. Circuits .....	221
1. Neutrals.....	221
2. Other conductors .....	221
3. Surge arresters .....	221
4. Use of earth as part of circuit.....	221
315. Communications protective requirements .....	221
A. Where required .....	221
B. Means of protection .....	221
316. Induced voltage.....	222
Sec. 32. Underground conduit systems.....	223
320. Location .....	223
A. Routing .....	223
1. General .....	223
2. Natural hazards.....	223
3. Highways and streets.....	223
4. Bridges and tunnels .....	223
5. Crossing railroad tracks .....	223
6. Submarine crossing .....	223
B. Separation from other underground installations .....	224
1. General .....	224
2. Separations between supply and communication conduit systems .....	224
3. Sewers, sanitary and storm.....	224
4. Water lines .....	224
5. Gas and other lines that transport flammable material .....	224
6. Steam lines .....	224
321. Excavation and backfill.....	224
A. Trench .....	224
B. Quality of backfill .....	224
322. Ducts and joints.....	225
A. General .....	225
B. Installation .....	225
1. Restraint .....	225
2. Joints .....	225
3. Externally coated pipe .....	225
4. Building walls .....	225
5. Bridges.....	225
323. Manholes, handholes, and vaults .....	225
A. Strength.....	225
B. Dimensions .....	226
C. Manhole access .....	226
D. Covers .....	227
E. Vault and utility tunnel access.....	227
F. Ladder requirements .....	227
G. Drainage .....	227
H. Ventilation .....	227
I. Mechanical protection.....	227
J. Identification.....	227
Sec. 33. Supply cable.....	229
330. General.....	229
331. Sheaths and jackets .....	229

## Contents

<i>Section</i>	<i>Page</i>
332. Shielding .....	229
A. General .....	229
B. Material .....	229
333. Cable accessories and joints.....	229
Sec. 34. Cable in underground structures .....	231
340. General.....	231
341. Installation.....	231
A. General .....	231
B. Cable in manholes and vaults .....	231
1. Supports.....	231
2. Clearance .....	231
3. Identification .....	232
342. Grounding and bonding .....	232
343. Fireproofing .....	232
344. Communication cables containing special supply circuits .....	233
Sec. 35. Direct-buried cable.....	234
350. General.....	234
351. Location and routing.....	235
A. General .....	235
B. Natural hazards .....	235
C. Other conditions.....	235
1. Swimming pools (in-ground) .....	235
2. Buildings and other structures.....	235
3. Railroad tracks .....	235
4. Highways and streets .....	235
5. Submarine crossings.....	235
352. Installation.....	236
A. Trenching .....	236
B. Plowing.....	236
C. Boring.....	236
D. Depth of burial .....	236
353. Deliberate separations—Equal to or greater than 300 mm (12 in) from underground structures or other cables.....	237
A. General .....	237
B. Crossings .....	237
C. Parallel facilities .....	237
D. Thermal protection .....	237
354. Random separation—Separation less than 300 mm (12 in) from underground structures or other cables .....	237
A. General .....	237
B. Supply cables or conductors.....	237
C. Communication cables or conductors .....	238
D. Supply and communication cables or conductors .....	238
1. General.....	238
2. Grounded bare or semiconducting jacketed neutral supply cables .....	238
3. Insulating jacketed grounded neutral supply cables .....	239
4. Insulating jacketed grounded neutral supply cables in nonmetallic duct .....	239
E. Supply and communication cables or conductors and non-metallic water and sewer lines .....	239
Sec. 36. Risers.....	240
360. General.....	240

## Contents

<i>Section</i>	<i>Page</i>
361. Installation.....	240
362. Pole risers—Additional requirements.....	240
363. Pad-mounted installations.....	240
Sec. 37. Supply cable terminations.....	241
370. General.....	241
371. Support at terminations.....	241
372. Identification.....	241
373. Clearances in enclosures or vaults.....	241
374. Grounding.....	241
Sec. 38. Equipment.....	242
380. General.....	242
381. Design.....	242
382. Location in underground structures.....	243
383. Installation.....	243
384. Grounding and bonding.....	243
385. Identification.....	243
Sec. 39. Installation in tunnels.....	244
390. General.....	244
391. Environment.....	244
<b>Part 4. Rules for the Operation of Electric Supply and Communications Lines and Equipment</b>	
Sec. 40. Purpose and scope.....	245
400. Purpose.....	245
401. Scope.....	245
402. Referenced Sections.....	245
Sec. 41. Supply and communications systems—Rules for employers.....	246
410. General requirements.....	246
A. General.....	246
B. Emergency procedures and first aid rules.....	247
C. Responsibility.....	247
411. Protective methods and devices.....	250
A. Methods.....	250
B. Devices and equipment.....	250
C. Inspection and testing of protective devices.....	250
D. Signs and tags for employee safety.....	250
E. Identification and location.....	250
F. Fall protection.....	251
Sec. 42. General rules for employees.....	252
420. Personal general precautions.....	252
A. Rules and emergency methods.....	252
B. Qualifications of employees.....	252
C. Safeguarding oneself and others.....	252
D. Energized or unknown conditions.....	252
E. Ungrounded metal parts.....	253
F. Arcing conditions.....	253
G. Liquid-cell batteries.....	253
H. Tools and protective equipment.....	253
I. Clothing.....	253

## Contents

<i>Section</i>	<i>Page</i>
J. Ladders and supports .....	253
K. Fall protection.....	253
L. Fire extinguishers.....	254
M. Machines or moving parts .....	254
N. Fuses .....	254
O. Cable reels .....	255
P. Street and area lighting .....	255
Q. Communication antennas .....	255
421. General operating routines.....	255
A. Duties of a first-level supervisor or person in charge.....	255
B. Area protection .....	255
1. Areas accessible to vehicular and pedestrian traffic .....	255
2. Areas accessible to employees only .....	255
3. Locations with crossed or fallen wires .....	256
C. Escort .....	256
422. Overhead line operating procedures .....	256
A. Setting, moving, or removing poles in or near energized electric supply lines .....	256
B. Checking structures before climbing.....	256
C. Installing and removing wires or cables.....	256
423. Underground line operating procedures.....	257
A. Guarding manhole and street openings .....	257
B. Testing for gas in manholes and unventilated vaults .....	257
C. Flames .....	257
D. Excavation .....	257
E. Identification.....	257
F. Operation of power-driven equipment.....	258
Sec. 43. Additional rules for communications employees.....	259
430. General.....	259
431. Approach to energized conductors or parts .....	259
432. Joint-use structures.....	260
433. Attendant on surface at joint-use manhole.....	260
434. Sheath continuity .....	261
Sec. 44. Additional rules for supply employees .....	262
440. General.....	262
441. Energized conductors or parts.....	262
A. Minimum approach distance to live parts .....	262
1. General.....	262
2. Precautions for approach—Voltages from 51 V to 300 V .....	262
3. Precautions for approach—Voltages from 301 V to 72.5 kV .....	262
4. Precautions for approach above 72.5 kV .....	263
5. Temporary (transient) overvoltage control device (TTOCD) .....	264
6. Altitude correction .....	264
7. Determining the minimum approach distances (distances to employee) .....	264
B. Additional approach requirements .....	264
C. Live-line tool clear insulation length.....	265
1. Clear live-line tool length .....	265
2. Live-line conductor support tool length .....	265
442. Switching control procedures .....	273
A. Designated person .....	273
B. Specific work.....	273
C. Operations at stations .....	273
D. Re-energizing after work .....	273
E. Tagging electric supply circuits associated with work activities .....	273
F. Restoration of service after automatic trip .....	274

## Contents

<i>Section</i>	<i>Page</i>
G. Repeating oral messages .....	274
443. Work on energized lines and equipment.....	274
A. General requirements .....	274
B. Requirement for assisting employee .....	275
C. Opening and closing switches .....	275
D. Working position.....	275
E. Protecting employees by switches and disconnectors .....	275
F. Making connections.....	275
G. Switchgear .....	275
H. Current transformer secondaries .....	275
I. Capacitors .....	275
J. Gas-insulated equipment .....	276
K. Attendant on surface .....	276
L. Unintentional grounds on delta circuits.....	276
444. De-energizing equipment or lines to protect employees.....	276
A. Application of rule .....	276
B. Employee's request .....	276
C. Operating switches, disconnectors, and tagging.....	276
D. Employee's protective grounds .....	276
E. Proceeding with work .....	277
F. Reporting clear—Transferring responsibility .....	277
G. Removal of tags.....	277
H. Sequence of re-energizing .....	277
445. Protective grounds .....	277
A. Installing grounds .....	277
1. Current-carrying capacity of grounds.....	278
2. Initial connections.....	278
3. Test for voltage.....	278
4. Completing grounds .....	278
B. Removing grounds .....	278
446. Live work.....	278
447. Protection against arcing and other damage while installing and maintaining insulators and conductors.....	279
Appendix A—Uniform system of clearances (Adopted in the 1990 Edition).....	281
Appendix B—Uniform clearance calculations for conductors under ice and wind conditions (Adopted in the 2007 Edition).....	287
Appendix C—Example applications for Rule 250C Tables 250-2 and 250-3.....	290
Appendix D—Determining maximum anticipated per-unit overvoltage factor (T) at the worksite.....	301
Appendix E—Bibliography .....	302
Index .....	307
Procedure for revising the National Electrical Safety Code .....	329
Time schedule for the next revision of the National Electrical Safety Code.....	331
Working Group assignments and activities for the 2012 Edition .....	332

## Contents

<i>Figure</i>	<i>Rule</i>	<i>Page</i>
Figure D-1	Sag and apparent sag .....	11
Figure 110-1	Safety clearance to electric supply station fences .....	33
Figure 124-1	Clearance from live parts .....	42
Figure 124-2	Railings or fences used as guards.....	42
Figure 230-1	Clearance zone map of the United States.....	84
Figure 233-1	Use of clearance envelope and conductor movement envelopes to determine applicable clearance .....	101
Figure 233-2	Conductor movement envelope (m).....	102
Figure 233-2	Conductor movement envelope (ft) .....	103
Figure 233-3	Clearance envelope.....	104
Figure 234-1(a)	Clearance diagram for building.....	117
Figure 234-1(b)	Clearance diagram for other structures .....	118
Figure 234-1(c)	Transitional clearance when H is greater than V .....	118
Figure 234-2	Clearances of service drop terminating on support mast .....	119
Figure 234-3	Swimming pool clearances .....	119
Figure 234-4(a)	Clearance envelope for grain bins filled by permanently installed augers, conveyors, or elevators .....	120
Figure 234-4(b)	Clearance envelope for grain bins filled by portable augers, conveyors, or elevators.....	120
Figure 234-5	Rail car clearances.....	121
Figure 235-1	Clearance diagram for energized conductor .....	142
Figure 236-1	Rule 236G, <i>Exception 3</i> .....	160
Figure 237-1	Obstruction of working space by buckarm .....	163
Figure 250-1	General loading map of United States with respect to loading of overhead lines .....	179
Figure 250-2(a)	Basic wind speeds .....	180
Figure 250-2(b)	Basic wind speeds .....	181
Figure 250-2(c)	Western Gulf of Mexico hurricane coastline .....	182
Figure 250-2(d)	Eastern Gulf of Mexico and southeastern US hurricane coastline...	182
Figure 250-2(e)	Mid and northern Atlantic hurricane coastline.....	183
Figure 250-3(a)	Uniform ice thickness with concurrent wind .....	184
Figure 250-3(b)	Uniform ice thickness with concurrent wind .....	185
Figure 250-3(c)	Uniform ice thickness with concurrent wind .....	186
Figure 250-3(d)	Uniform ice thickness with concurrent wind .....	186
Figure 250-3(e)	Uniform ice thickness with concurrent wind .....	187
Figure 250-3(f)	Uniform ice thickness with concurrent wind .....	188
Figure 279-1	Insulator used for BIL insulation .....	217
Figure 323-1	Roadway vehicle load .....	228
Figure 323-2	Wheel load area.....	228
Figure 350-1	Symbols for identification of buried cables .....	234
 <i>Appendix figure</i>		
Figure A-1	Clearance at maximum sag .....	286

## Contents

<i>Table</i>	<i>Rule</i>	<i>Page</i>
Table 110-1	Values for use with Figure 110-1 .....	11B2 34
Table 111-1	Illumination levels .....	111A 35
Table 124-1	Clearances from live parts.....	124A1 43
Table 125-1	Working space.....	125A3 52
Table 230-1	Ice thickness for purposes of calculating clearances.....	230B 85
Table 230-2	Ice, wind pressures, temperatures, and additive constants for purposes of calculating final inelastic deformation .....	230B 85
Table 232-1	Vertical clearance of wires, conductors, and cables above ground, roadway, rail, or water surfaces .....	232B1 89
Table 232-2	Vertical clearance of equipment cases, support arms, platforms, braces and unguarded rigid live parts above ground, roadway, or water surfaces .....	232B2 95
Table 232-3	Reference heights .....	232D2 97
Table 232-4	Electrical component of clearance in Rule 232D3a .....	232D3a 98
Table 233-1	Vertical clearance between wires, conductors, and cables carried on different supporting structures .....	233C1 104
Table 233-2	Clearance between supply wires, conductors, and cables in Rule 233C3b(1).....	233C3b(1) 107
Table 233-3	Reference heights .....	233C3a 109
Table 234-1	Clearance of wires, conductors, cables, and unguarded rigid live parts adjacent but not attached to buildings and other installations except bridges .....	234C1a 122
Table 234-2	Clearance of wires, conductors, cables, and unguarded rigid live parts from bridges .....	234D1a 128
Table 234-3	Clearance of wires, conductors, cables, or unguarded rigid live parts over or near swimming pools .....	234E1 131
Table 234-4	Electrical component of clearance of buildings, bridges, and other installations .....	234H3a 133
Table 234-5	Reference distances .....	234H2 134
Table 235-1	Horizontal clearance between wires, conductors, or cables at supports .....	235B1a 143
Table 235-2	Horizontal clearances between line conductors smaller than AWG No. 2 at supports, based on sags .....	235B1b(1) 144
Table 235-3	Horizontal clearances between line conductors AWG No. 2 or larger at supports, based on sags .....	235B1b(2) 146
Table 235-4	Electrical clearances in Rule 235B3a(1) .....	235B3a(1) 148
Table 235-5	Vertical clearance between conductors at supports .....	235C1 149
Table 235-6	Clearance in any direction from line conductors to supports and to vertical or lateral conductors, span, or guy wires attached to the same support .....	235E1 153
Table 235-7	Clearance in any direction from line conductors to supports .....	235E3b 157
Table 235-8	Vertical spacing between conductors supported on vertical racks or separate brackets.....	235 158
Table 236-1	Horizontal clearance between conductors bounding the climbing space.....	236E 161
Table 238-1	Vertical clearance between supply conductors and communications equipment, between communication conductors and supply equipment, and between supply and communications equipment .....	238B 164
Table 238-2	Vertical clearance of span wires and brackets from communication lines .....	238C 164
Table 239-1	Clearance of open vertical and lateral conductors .....	239E1 169
Table 239-2	Clearance between open vertical conductors and pole surface .....	239E2a(1) 170

## Contents

<i>Table</i>	<i>Rule</i>	<i>Page</i>
Table 242-1	Grades of construction for supply conductors alone, at crossing, or on the same structures with other conductors .....242	173
Table 242-2	Grades of construction for communication conductors alone or in upper position of crossing or on joint poles.....242	175
Table 250-1	Ice, wind, and temperature .....250C	189
Table 250-2	Velocity pressure exposure coefficient $k_z$ , structure, structure location, component, and wire .....250C	190
Table 250-3	Structure and wire gust response factors, $G_{RF}$ .....250C	191
Table 250-4	Wind speed conversions to pressure .....250D	193
Table 251-1	Temperatures and constants .....251B3	194
Table 253-1	Load factors for structures, crossarms, support hardware, guys, foundations, and anchors to be used with the strength factors of Table 261-1A .....253	197
Table 253-2	Alternate load factors for wood and reinforced (not prestressed) concrete structures to be used with the strength factors of Table 261-1B.....253	198
Table 261-1A	Strength factors for structures, crossarms, braces, support hardware, guys, foundations, and anchors for use with load factors of Table 253-1 .....261M	207
Table 261-1B	Strength factors for structures, crossarms, and braces for use with load factors of Table 253-2 .....261D2	208
Table 261-2	Dimensions of crossarm cross section of select Southern Pine and Douglas Fir .....261D2	208
Table 263-1	Sizes for Grade N supply line conductors.....263D1	210
Table 263-2	Sizes of service drops of 750 V or less .....263E1a(1)	211
Table 273-1	Insulation level requirements .....273	214
Table 277-1	Allowed percentages of strength ratings .....277	215
Table 341-1	Clearance between supply and communications facilities in joint-use manholes and vaults .....341B2b(5)	232
Table 352-1	Supply cable or conductor burial depth .....352D2	236
Table 410-1	Clothing and clothing systems—voltage, fault current, and maximum clearing time for voltages 1 to 46 kV.....410A3	247
Table 410-2	Live-line tool work clothing and clothing systems—voltage, fault current, and maximum clearing time for voltages 46.1 to 800 kV .....410A3	248
Table 431-1	Communication work minimum approach distances .....431	259
Table 441-1	AC live work minimum approach distance .....441A4	266
Table 441-2	AC live work minimum approach distances for altitudes less than 900 m above sea level, where T has been determined according to Rule 441A5 .....441A4	267
Table 441-3	AC live work minimum approach distances for altitudes less than 3000 ft above sea level, where the T has been determined according to Rule 441A5 .....441A4	269
Table 441-4	DC live work minimum approach distance for altitudes less than 900 m above sea level .....441A1	271
Table 441-5	Altitude correction factor .....441A4	272
Table 441-6	Maximum use voltage for rubber insulating equipment .....441A4	272
 <i>Appendix tables</i>		
Table A-1	.....282	282
Table A-2a—Reference components of Rule 232	.....283	283
Table A-2b—Reference components of Rule 234	.....285	285

## Letter symbols for units

This Code uses standard symbols for units. They have the following meanings:

A	ampere
C	degree Celsius
ft	foot
ft <sup>2</sup>	square foot
ft <sup>3</sup>	cubic foot
F	degree Fahrenheit
g	gram
Hz	hertz
h	hour
in	inch
in <sup>2</sup>	square inch
k	kilo (10 <sup>3</sup> )
kg	kilogram
kPa	kilopascal
km <sup>2</sup>	square kilometer
kV	kilovolt (1000 volts)
kVA	kilovoltampere
kW	kilowatt
m	meter
m <sup>2</sup>	square meter
m <sup>3</sup>	cubic meter
m	milli (10 <sup>-3</sup> )
mA	milliampere
mi	mile (international)
mm	millimeter
min	minute (time)
N	newton
Pa	pascal
lb	pound
s	second (time)
V	volt
W	watt



# ***Errata to*** **2007 Edition** **National Electrical Safety Code®**

*Correction Sheet*  
**Issued 14 May 2007**

Copyright © 2007 by the Institute of Electrical and Electronics Engineers, Inc.  
All rights reserved. Published 2007. Printed in the United States of America.

This correction sheet may be freely reproduced and distributed in order to maintain the utility and currency of the underlying Standard. This correction sheet may not be sold, licensed, or otherwise distributed for any commercial purposes whatsoever. The content of this correction sheet may not be modified.

The following corrections should be made:

**Page 92:** There is an error in Table 232-1 (ft). The footnote that appears in the first column of the fourth row should be “Ⓔ” and not “Ⓓ.”

**Table 232-1—Vertical clearance of wires, conductors, and cables above ground,  
roadway, rail, or water surfaces**

4. Other land traversed by vehicles, such as cultivated, grazing, forest, orchards, etc. Ⓔ	15.5	16.0	16.5	18.5	—	—
--	------	------	------	------	---	---

**Page 101:** There is an error in one of the arrow descriptions in Figure 233-1. The arrow description associated with the double arrows located to the top and right of the figure should read “CONDUCTOR MOVEMENT ENVELOPES DEVELOPED UNDER RULE 233A1...” and not “CONDUCTOR MOVEMENT ENVELOPES DEVELOPED UNDER RULE 233A1...”

## Section 1. Introduction to the National Electrical Safety Code®

### 010. Purpose

The purpose of these rules is the practical safeguarding of persons during the installation, operation, or maintenance of electric supply and communication lines and associated equipment.

These rules contain the basic provisions that are considered necessary for the safety of employees and the public under the specified conditions. This Code is not intended as a design specification or as an instruction manual.

### 011. Scope

- A. These rules cover supply and communication lines, equipment, and associated work practices employed by a public or private electric supply, communications, railway, or similar utility in the exercise of its function as a utility. They cover similar systems under the control of qualified persons, such as those associated with an industrial complex or utility interactive system.
- B. The NESC covers utility facilities and functions up to the service point.  
*NOTE:* The National Electrical Code® (NEC®) (NFPA 70, 2005 Edition)<sup>①</sup> covers utilization wiring requirements beyond the service point.
- C. NESC rules cover street and area lights (supplied by underground or overhead conductors) under the exclusive control of utilities (including their authorized contractors) or other qualified persons (such as those associated with an industrial complex).  
*NOTE:* Luminaires not under such exclusive control are governed by the requirements of the NEC.
- D. NESC rules do not cover installations in mines, ships, railway rolling equipment, aircraft, or automotive equipment, or utilization wiring except as covered in Parts 1 and 3.

### 012. General rules

- A. All electric supply and communication lines and equipment shall be designed, constructed, operated, and maintained to meet the requirements of these rules.
- B. The utilities, authorized contractors, or other entities, as applicable, performing design, construction, operation, or maintenance tasks for electric supply or communication lines or equipment covered by this Code shall be responsible for meeting applicable requirements.
- C. For all particulars not specified in these rules, construction and maintenance should be done in accordance with accepted good practice for the given local conditions known at the time by those responsible for the construction or maintenance of the communication or supply lines and equipment.

### 013. Application

- A. New installations and extensions
  - 1. These rules shall apply to all new installations and extensions, except that they may be waived or modified by the administrative authority. When so waived or modified, safety shall be provided in other ways.

---

<sup>①</sup>Information on references can be found in Section 3.