

IEEE STANDARDS ASSOCIATION



National Electrical Safety Code®

C2-2012



3 Park Avenue, New York, NY 10016-5997, USA

National Electrical Safety Code®

Secretariat
Institute of Electrical and Electronics Engineers, Inc.

Approved 14 April 2011
Institute of Electrical and Electronics Engineers, Inc.

Approved 3 June 2011
American National Standards Institute

2012 Edition

Abstract: This Code covers basic provisions for safeguarding of persons from hazards arising from the installation, operation, or maintenance of (1) conductors and equipment in electric supply stations, and (2) overhead and underground electric supply and communication lines. It also includes work rules for the construction, maintenance, and operation of electric supply and communication lines and equipment. The Code is applicable to the systems and equipment operated by utilities, or similar systems and equipment, of an industrial establishment or complex under the control of qualified persons. This Code consists of the introduction, definitions, grounding rules, list of references, and bibliographic documents, and Parts 1, 2, 3, and 4 of the 2012 Edition of the National Electrical Safety Code.

Keywords: communications industry safety; construction of communication lines; construction of electric supply lines; electrical safety; electric supply stations; electric utility stations; high-voltage safety; operation of communications systems; operation of electric supply systems; power station equipment; power station safety; public utility safety; safety work rules; underground communication line safety; underground electric line safety

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2011 by the
Institute of Electrical and Electronics Engineers, Inc.

All rights reserved. Published 2011
Printed in the United States of America

National Electrical Safety Code and NESC are registered trademarks and service marks in the
U.S. Patent & Trademark Office, owned by
The Institute of Electrical and Electronics Engineers, Incorporated.

The NESC logo is a registered trademark in the U.S. Patent & Trademark Office, owned by
The Institute of Electrical and Electronics Engineers, Incorporated.

National Electrical Code, NEC, and NFPA 70 are registered trademarks in the
U.S. Patent & Trademark Office, owned by the
National Fire Protection Association.

ISBN 978-0-7381-6588-2

Public authorities are granted permission to republish the material
herein in laws, regulations, administrative orders, ordinances, or
similar documents. No other party may reproduce in any form, in an
electronic retrieval system or otherwise, any portion of this document,
without the prior written permission of the publisher.

Recognized as an American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether he has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review and users are cautioned to obtain the latest editions.

Currently in preview, click buy full version

Foreword

This foreword is not a part of Accredited Standards Committee C2-2012, National Electrical Safety Code.

This publication consists of the parts of the National Electrical Safety Code[®] (NESC[®]) (Accredited Standards Committee C2) currently in effect. The former practice of designating parts by editions has not been practical for some time. In the 1977 Edition, Parts 1 and 4 were 6th editions; Part 2 was a 7th edition; Part 3 was a revision of the 6th edition; Part 2, Section 29, did not cover the same subject matter as the 5th edition; and Part 3 was withdrawn in 1970. In the 1987 Edition, revisions were made in all parts, and revisions to all parts have been made in subsequent editions. It is therefore recommended that reference to the NESC be made solely by the year of the published volume and desired part number. Separate copies of the individual parts are not available.

Work on the NESC started in 1913 at the National Bureau of Standards (NBS), resulting in the publication of NBS Circular 49. The last complete edition of the Code (the 5th edition, NBS Handbook H30) was issued in 1948, although separate portions had been available at various times starting in 1938. Part 2—Definitions and the Grounding Rules, 6th edition, were issued as NBS Handbook H81, ANSI C2... 1960, in November 1961, but work on other parts was not actively in process again until 1970.

In 1970 the C2 Committee decided to delete the Rules for the Installation and Maintenance of Electric Utilization Equipment (Part 3 of the 5th edition), now largely covered by the National Electrical Code[®] (NEC[®]) (NFPA 70[®], 2011 Edition), and the Rules for Radio Installation (Part 5 of the 5th edition) from future editions.^① The Discussion of the NESC, issued as NBS Handbook H4 (1928 Edition) for the 4th edition of the NESC and as NBS Handbook H39 for Part 2 of the Grounding Rules of the 5th edition, was not published for the 6th edition.

The 1981 Edition included major changes in Parts 1, 2, and 3, minor changes in Part 4, and the incorporation of the rules common to all parts into Section 1. The 1984 Edition was revised to update all references and to list those references in a new Section 3. Converted metric values, for information only, were added. Gender-related terminology was deleted. Section 1—Introduction, Section 2—Definitions, Section 3—References, and Section 9—Grounding Methods, were made applicable to each of the Parts 1, 2, 3, and 4.

The 1987 Edition was revised extensively. Definitions were changed or added. Requirements affecting grounding methods, electric supply stations, overhead line clearances and loading, underground lines, and work rules were revised.

The 1990 Edition included several major changes. General rules were revised. A significant change to the method for specifying overhead line clearances was made and the rationale added as Appendix A. Requirements for clearances of overhead lines from grain bins and an alternate method for determining the strength requirements for wood structures was added. Rules covering grounding methods, electric supply stations, underground lines, and work rules were changed.

In the 1993 Edition, changes were made in the rules applicable to emergency and temporary installations. In Section 9 and Parts 1, 2, and 3, rules were extended or clarified to include HVDC systems. The requirements to maintain separation of direct-buried supply and communications systems were modified for consistency and clarity, as was the rule in Part 4 on tagging electric supply circuits.

In the 1997 Edition, the most notable general change that took place is that numerical values in the metric (SI) system are shown in the preferred position, with customary inch-foot-pound values (inside parentheses)

^① Information on references can be found in Section 3.

following. A bibliography, Appendix B, which consists of a list of resources identified in notes or recommendations, was added. Changes were made to rules affecting grounding, electric supply stations, and overhead lines, particularly with regard to clearance rules applicable to emergency and temporary installations. Strength requirements contained in Sections 24, 25, and 26 were revised completely. Underground line requirements for random separation for underground lines of direct-buried cables were modified. The requirement for cable identification marking by means of sequentially placed logos was introduced. Work rules added a requirement that warning signs and tags comply with applicable ANSI standards, tagging requirements were clarified with regard to SCADA, and extensive requirements for fall protection were added.

In the 2002 Edition, several changes were made that affected all or several parts of the Code. Particularly, this edition clarifies interfaces between the NEC and NESC with regard to Code jurisdiction in the area of street lights and area lights. Also included is clarification for situations between utility workers and their authorized contractors and installations on industrial complexes.

The major revisions for the 2007 Edition included grounding, moving sag calculations to Section 23, moving guy and span wires insulator rules to Section 21, phasing out of the alternate method for load factors and strength factors, flammable materials transported, phase-to-phase cover-up, and minimum approach distance tables.

In the 2012 Edition, major changes include an updated scope, application, and definitions; greatly simplified minimum approach tables and voltage exposure for arc flash; the addition of K factor for wire attention; and added clarification of the ungrounded portions of guys and swimming pools.

The Scope, Application, and Definition rules were extensively revised in 2012 to better reflect the historical application of the NESC—in large measure to clarify the relative applicability of the NESC versus the NEC. The changes in language in Rules 010—Purpose and 011—Scope are not changes in either scope or purpose; they are clear statements of the almost 100-year application of the requirements of the NESC to the specified circumstances. Additional rules were changed for clarity or to support changes made in other sections of the Code.

In Rule 091, revisions were made to clarify where rules require conductors or equipment to be effectively grounded, meeting the requirements of Section 9, plus the definition of *effectively grounded* must be met.

In Rule 094B7, the length and thickness requirements for using a directly embedded metal pole as an acceptable grounding electrode were deleted. Text was added to specify the distance required for a supplemental ground electrode to be installed with an embedded metal pole. Also, the Exception within the Rule added the words “or type metal” that recognize other length, configuration, and material may be allowed if supported by a qualified engineering study.

In Rule 099B, the grounding electrode conductor for grounding communication apparatus was changed from an AWG No. 10 to AWG No. 6.

The revisions in Part 1 consisted of improving Rule 110A2 to reduce clearance to live parts for an impenetrable fence and simplifying the Table 111-1 list of illumination levels for generating stations and substations.

Additional revisions were also made as follows:

- Updating the standard revision dates that contain information regarding safety signs.
- Storing material, equipment, and vehicles in supply stations.
- Outdoor lighting at unattended stations (not required).

- Noting that permanently installed fire-extinguishing equipment is not a requirement.
- Use of “taut-string distance” measurements for vertical clearances to energized part.

Rule 214A5 was revised; multiple change proposals attempted to add consistency to the application of the terms *grounded* and *effectively grounded*. Subcommittee 4 retained both terms and retained the requirement that guys be effectively grounded. Subcommittee 4 also revised Rules 215B1 and 215B2, applied a revision to the application of guy insulators, and clarified the voltage between line conductors.

A footnote to Table 251-1 was inserted to clarify the application of the K factor for wire tensions when a messenger supports multiple conductors using splices. It states that when each conductor is separately loaded with ice and wind as described in Rule 251A3b, the K factor should be applied to all cables.

Rule 261H1 addresses tensions of overhead supply conductors and shield wires. One change proposal added tension limits when Rule 250C and Rule 250D loads apply. Similar to what already existed for splices and deadend fittings, conductors and shield wires will now be limited to 80% of the rated breaking strength when those extreme load conditions are applied along with a load factor of 1.0. Another change in the same rule modified the application of the secondary conductor tension limits from 16 °C (60 °F) to the applicable temperature listed in Table 250-1 for Rule 250B district loads. Reducing the temperatures at which tension limits are applied is in line with recommendations from conductor manufacturers and will reduce the risk of conductor damage due to aeolian vibration.

Rule 313 was reworded to include the recording and correction of conditions, not just defects, that affect compliance with the Code. In Rule 314B, the voltage level for grounding surge guards and ducts was deleted. Rule 320B5 now requires not less than 300 mm (12 in) separation from gas and other lines that transport flammable materials. New Rule 323E5 requires clearances based on Rule 110A2 for aboveground vaults with ventilation opening not protected with baffles or louvers. Figure 323-1 and Figure 323-2 were revised to comply with the latest figures in ASTM C857. The title for Section 35 was revised to include cable in duct not part of a conduit system. Recommendations concerning color coding for direct-buried cables and duct not part of a conduit system were added to Rules 350F and 350G. Installation rules for cable in duct were included in Rule 352. An Exception was added to Rule 354A2 to allow less than 300 mm (12 in) separation between supply conductors operating at not more than 300 V between conductors and gas and other lines that transport flammable materials where supplemental mechanical protection is provided. New Rule 355 contains rules for duct not part of a conduit system. Rule 384 was rewritten to require bonding between aboveground metallic communication and supply enclosures only.

Two significant changes were made to the work rules in Part 4, specifically in the Rule 441 minimum approach distanced tables and also in Rule 410A3 on arc flash exposure. Revisions to IEEE Std 516™-2009 (NESC’s source for calculated minimum approach distances) required changes to be made to the minimum approach distances in Part 4. Prior NESC editions included several tables containing minimum approach distances based on voltage levels and overvoltage levels. In the 2012 Edition, the minimum approach tables have been greatly simplified (accurate to the current IEEE 516 calculations) providing distances at the accepted historic maximum overvoltage levels. An engineering study of circuit overvoltage will have to be completed to use a reduced minimum approach distance.

Rule 410A3 was revised to recognize exposures at less than 1000 V. Significant testing was conducted by two separate major utilities and a research institute, providing the opportunity to establish appropriate incident energy levels for many common industry applications. The result of the review of the testing supported the development of new Table 410-1 that establishes arc energy thresholds for different equipment/exposures at voltage levels below 1000 V.

Table A-1 of Appendix A was revised only in the manner of presentation by the Overhead Clearances Subcommittee. However, the extreme wind calculations of Appendix C were revised by the Overhead Strengths and Loadings Subcommittee to reflect changes in Rule 250C.

Substantive changes in the 2012 Edition are identified by a bar in the left-hand margin. In several cases, rules have been relocated without substantive changes in the wording. In these cases, only the rule numbers have been indicated as having been changed.

The Institute of Electrical and Electronics Engineers, Inc., was designated as the administrative secretariat for C2 in January 1973, assuming the functions formerly performed by the NBS. Comments should be sent to the Secretary, National Electrical Safety Code Committee, through the following Contact Form:

Secretary
National Electrical Safety Code Committee
Institute of Electrical and Electronics Engineers, Inc.
<http://standards.ieee.org/contact/form.html>

A representative Committee on Interpretations has been established to prepare replies to requests for interpretation of the rules contained in the Code. Requests for interpretation should state the rule in question, as well as the conditions under which it is being applied. Interpretations are intended to clarify the intent of specific rules and are not intended to supply consulting information on the application of the Code. Requests for interpretation should be submitted using the NESC Interpretation Request Form on the NESC home page: <http://standards.ieee.org/about/nesc/interps.html>.

If the request is suitable for processing, it will be sent to the Interpretations Subcommittee. After consideration by the committee, which may involve many exchanges of correspondence, the inquirer will be notified of its decision. Decisions are published regularly and may be obtained or accessed online at no cost at <http://standards.ieee.org/about/nesc/interps.html>.

The NESC as written is a voluntary standard. However, some editions and some parts of the Code have been adopted, with and without changes, by some state and local jurisdictional authorities. To determine the legal status of the NESC in any particular state or locality within a state, the authority having jurisdiction should be contacted.

Change proposals and comments for the 2012 Edition of the NESC will be submitted to the NESC Secretary online via the Internet. For information on how this electronic revision process will take place and for updates and complete information on the NESC, please visit the National Electrical Safety Code Zone on the IEEE Standards Web site at <http://standards.ieee.org/about/nesc/>.

Standards Committee Membership

At the time this Code was approved, Accredited Standards Committee C2 had the following membership:

Michael J. Hyland, Chair
James R. Tomaseski, Vice Chair
William A. Ash, Secretary, 2003–2010
Michael D. Kipness, Secretary, 2010–2011

<i>Organization represented</i>	<i>Principle</i>	<i>Alternate</i>	<i>Employer</i>
Chair	Michael J. Hyland		American Public Power Association
Past Chair	O. Chuck Amrhyn		OPEC
AAR	Robert Verhelle		Amtrak
AEIC	Swapan Dey		NSTAR Electric & Gas Corp.
APPA	Nathan Mitchell		American Public Power Association
APTA	George S. Pristach		Parsons Brinckerhoff
		Billy Raley	Progress Energy
ATIS	Lawrence M. Slavin		Outside Plant Consulting Services, Inc.
BPA	Maggie Emery		Bonneville Power Administration
EEI	Ewell T. Robeson		Progress Energy
		Edward Harrel	Oncor Electric Delivery
EIA	Percy E. Pool		Verizon
		Marie Shaw	Verizon
IBEW	James R. Tomaseski		International Brotherhood of Electrical Workers
IEEE	Nelson G. Bingel		Osmose Utilities Services, Inc.
IEEE/IAS		Walter D. Jones	Intermountain Rural Electric Assoc.
IEC	James C. Tuggle		Malpaso Group Inc.
		Robert W. Baird	Independent Electrical Contractors
		John M. Brack	Independent Electrical Contractors
Int'l Munic. Sign Assn.	Warren S. Farrell		International Municipal Signal Association
NARUC	Paul Emerson		NY State Dept. of Public Service
NCTA	Rex Bullinger		National Cable & Telecommunications Association
		Christopher Austin	Time Warner Cable, NYC–Liberty Division
NECA	O. L. Dennis		Manzano-Western Inc.
NEMA	Vincent Balawski		National Electrical Manufacturers Association
		Scott Choinski	National Electrical Manufacturers Association
NRECA	Robert D. Saint		National Rural Electric Cooperative Association
		Michael C. Pehosh	National Rural Electric Cooperative Association
NSC	Kenneth Schriener		Western Area Power Administration
NSPE	Robert S. Fuller		Texas-New Mexico Power Co.
NRS	Georg A. Shultz		USDA, Rural Utilities Service
OTCL	Timothy Cooke		Times Fiber Communications, Inc.
TVA	Clayton L. Clem		Tennessee Valley Authority, Power System Operations
		Stephen Cantrell	Tennessee Valley Authority
WAPA	Jeffrey Wild		Western Area Power Administration, U.S. Dept of Energy

National Electrical Safety Code—Subcommittee 1 Sections 1, 2, and 3

Allen L. Clapp, Chair

Charles C. Bleakley, Secretary

<i>Principle</i>	<i>Alternate</i>	<i>Organization represented</i>	<i>Employer</i>
Donald E. Hooper		Int. SC	ES&C, Inc.
O. Chuck Amrhn		Main	OPEC
Allen L. Clapp		SC1	Clapp Research Associates, P. C.
John B. Dagenhart		SC2	Clapp Research Associates, P. C.
	Ewell T. Robeson	SC2	Progress Energy
D. J. Christofersen		SC3	CeCe
	Gary R. Engmann	SC3	Burns and McDonnell Engineering
David G. Komassa		SC4	We Energies
	Eric Engdahl	SC4	American Electric Power
Nelson G. Bingel		SC5	Osmose Utilities Services, Inc.
Charles C. Bleakley		SC7	Georgia Power Company
	John C. Spence	SC7	Baltimore Gas & Electric Co.
James R. Tomaseski		SC8	International Brotherhood of Electrical Workers
	Samuel Stonerock	SC8	Southern California Edison Co.

AAR—Association of American Railroads
 AEIC—Association of Edison Illuminating Companies
 AISI—American Iron and Steel Institute
 APWA—American Public Power Association
 APTA—American Public Transit Association
 ATIS—Alliance for Telephone Industry Solutions
 AWPA—American Wood Preserves Association
 BPA—Bonneville Power Admin., U.S. Dept. of Energy
 EEI—Edison Electric Institute
 EIA—Electronic Industries Association
 IBEW—International Brotherhood of Electrical Workers
 IEC—Independent Electrical Contractors
 IEEE—Institute of Electrical and Electronics Engineers, Inc.

IMSA—International Municipal Signal Association
 NARUC—National Association of Regulatory Utility Commissioners
 NCTA—National Cable Television Association
 NECA—National Electrical Contractors Association
 NEMA—National Electrical Manufacturers Association
 NSC—National Safety Council
 NSPE—National Society of Professional Engineers
 RUS—Rural Utilities Services, U.S. Dept. of Agriculture
 SCTE—Society of Telecommunication Engineers
 SEEX—Southeastern Electric Exchange
 TVA—Tennessee Valley Authority
 WAPA—Western Area Power Administration, U.S. Dept. of Energy

**National Electrical Safety Code—Subcommittee 2—Grounding Methods
Section 9**

John B. Dagenhart, Chair
Ewell T. Robeson, Secretary

<i>Principle</i>	<i>Alternate</i>	<i>Organization represented</i>	<i>Employer</i>
Trevor Bowmer		ATIS	Telcordia
Michael M. Dixon		EEI	Ameren
Robert Molde		EEI	Xcel Energy
Ewell T. Robeson		EEI	Progress Energy
	Lauren E. Gaunt	EEI	Northeast Utilities
	Timothy P. Hayden	EEI	National Grid
	Gregory Obenchain	EEI	Edison Electric Institute
	Justin Rush	EEI	Westar Energy
	Marcus Schlegel	EEI	American Electric Power
	Ron Wellman	EEI	American Electric Power
Percy E. Pool		EIA	Verizon
	John Korman	EIA	Verizon
James R. Tomaseski		IBEW	International Brotherhood of Electrical Workers
Donald W. Zipse		IEEE/IAS	Zipse Electrical Engineering Inc.
John B. Dagenhart		IEEE/PES/T&D	Clapp Research Associates, P. C.
Ned Maxwell		NARUC	Public Utilities Commission of OH
Ronald Boyer		NCTA	Time Warner Cable
Roger J. Montambo		NEMA	Ga. an Industries
Robert D. Saint		NRECA	National Rural Electric Cooperative Association
	Michael C. Pehosh	NRECA	National Rural Electric Cooperative Association
Ted Pejman		US	USDA, Rural Utilities Service
	Robert Lash	US	USDA, Rural Utilities Service
Timothy Cooke		CTE	Times Fiber Communications, Inc.
Keith Reese		SEEX	Georgia Power Company
	John Bruce	SEEX	Dominion Virginia Power

**National Electrical Safety Code—Subcommittee 3—Electric Supply Stations
Sections 10–19**

D. J. Christofersen, *Chair*
Gary R. Engmann, *Secretary*

<i>Principle</i>	<i>Alternate</i>	<i>Organization represented</i>	<i>Employer</i>
Alton L. Comans		AEIC	Alabama Power Company
	James Houston	AEIC	Alabama Power Company
George Zaczek		APPA	Eugene Water & Electric Board
Kevin Robinson		EEI	American Electric Power
	Timothy Jyrkas	EEI	Xcel Energy
	Kenneth Posey	EEI	American Electric Power
James R. Tomaseski		IBEW	International Brotherhood of Electrical Workers
Gary R. Engmann		IEEE	Burns and McDonnell Engineering
W. Bruce Dietzman		IEEE	Oncor Electric Delivery Company
D. J. Christofersen		IEEE/PES/SUB	CeCe
	Kenneth D. White	IEEE/PES/SUB	Georgia Transmission Corporation
Keith Harrison		NRECA	KAMO Power Cooperative
	Robert D. Saint	NRECA	National Rural Electric Cooperative Association
Mehrdad Eskandary		RUS	USDA, Rural Utilities Service
	Lou Riggs	RUS	USDA, Rural Utilities Service
Mark A. Konz		SEEX	Gulf Power Company
	Christopher A. Carson	SEEX	Alabama Power Company

**National Electrical Safety Code—Subcommittee 4—Overhead Lines—Clearances
Sections 20, 21, 22, 23**

David G. Komassa, *Chair*
Eric K. Engdahl, *Secretary*

<i>Principle</i>	<i>Alternate</i>	<i>Organization represented</i>	<i>Employer</i>
Charles C. Bleakley		AEIC	Georgia Power Company
	Keith Reese	AEIC	Georgia Power Company
Jan Howard		APPA	Owensboro Municipal Utilities
Trevor Bowmer		ATIS	Telcordia
Lawrence M. Slavin		ATIS	Outside Plant Consulting Services, Inc.
	Dennis Henry	ATIS	Telcordia
Maggie Emery		BPA	Bonneville Power Administration
Rudolph J. Bednarz		Consultant	JayCo Engineering, Inc.
Allen L. Clapp		Consultant	Clapp Research Associates, P. C.
Donald E. Hooper		Consultant	ES&C, Inc.
Kevin Drzewiecki		EEI	National Grid
Eric K. Engdahl		EEI	American Electric Power
	Barrett Thomas	EEI	American Electric Power
	Frank Tucker	EEI	American Electric Power
Mickey B. Gunter		EEI	Engineering Consultant

Subcommittee 4 (continued)

<i>Principle</i>	<i>Alternate</i>	<i>Organization represented</i>	<i>Employer</i>
David G. Komassa		EEI	We Energies
Jeffrey Steiner		EEI	National Grid
	Tracy Dencker	EEI	Ameren
	Alan Kuipers	EEI	Consumer Energy
	Chris Ann Shellberg	EEI	Consumer Energy
	Gregory Obenchain	EEI	Edison Electric Institute
	Jeffery Hall	EEI	Florida Power and Light
Alan T. Young		EIA	Verizon Network Services
	Mark Berlinger	EIA	Verizon
Joseph Renowden		Emeritus	
James R. Tomaseski		IBEW	International Brotherhood of Electrical Workers
Marc Candels		IEC	Candels Consulting
Paul Bachman		IEEE/IAS	Ulteig Engineers
Robert G. Oswald		IEE/PES/T&D	Power Engineers, Inc.
Darren Gill		NARUC	Pennsylvania Public Utility Commission
Christopher Austin		NCTA	Time Warner Cable, NYC–Liberty Division
	Rex Bullinger	NCTA	National Cable & Telecommunications Association
	Steve Mace	NCTA	National Cable & Telecommunications Association
Ernest H. Neubauer		NRECA	Southern Rivers Energy
	Michael C. Pehosh	NRECA	National Rural Electric Cooperative Association
Charles Crawford		NSPE	Oncor Electric Delivery
David J. Marne		NSPE	Marne and Associates, Inc.
O. Chuck Amrhyn		OPEC	OPEC
Gerard Moore		RUS	USDA, Rural Utilities Service
	Donald Junta	RUS	USDA, Rural Utilities Service
Joseph J. White		SEEX	Utility Line Construction Services
	Branch Davis	SEEX	Entergy Corporation
	Donnie Trivitt	SEEX	OG&E Electric Services

**National Electrical Safety Code—Subcommittee 5—Overhead Lines—
Strength and Loading
Sections 24, 25, and 27**

Nelson G. Bingel, *Chair*
Bruce Freimark, *Secretary*

<i>Principle</i>	<i>Alternate</i>	<i>Organization represented</i>	<i>Employer</i>
John Busel		ACMA	ACMA
	Brian Lacoursiere	ACMA	RS Technologies
	Dustin Troutman	ACMA	Creative Pultrusions Inc.
Helen Chen		AISI	American Iron and Steel Institute
	Richard Aichinger	AISI	Valmont-Newmark
Christopher Jones		APPA	Springfield City Utilities
Joseph Rempe		APPA	Tacoma Power
Lawrence M. Slavin		ATIS	Outside Plant Consulting Services, Inc.
Nelson G. Bingel		AWPA	Osmose Utilities Services, Inc.
Leon Kempner		BPA	Bonneville Power Administration
Allen L. Clapp		Consultant	Clapp Research Associates, P. C.
Ronald Cotant		EEI	American Electric Power
Bruce Freimark		EEI	American Electric Power
	John-Chung Ng	EEI	American Electric Power
Jeffery Erdle		EEI	Duke Energy
Edward Harrel		EEI	Western Area Power Administration
Robert O. Kluge		EEI	American Transmission Company
Richard J. Stanford		EEI	National Grid
	G. Paul Anundson	EEI	National Grid
C. Jerry Wong		EEI	Florida Power & Light
	David West	EEI	Duke Power Company
	Bryan L. Williams	EEI	Oncor Electric Delivery Company
	Prasad Yenumula	EEI	Progress Energy, NC
Marc Berlinger		EIA	Verizon
	Alan T. Young	EIA	Verizon Network Services
Robert C. Peters		IEEE	
Andrew Schwalm		IEEE	Victor Insulators, Inc.
Donald Soderberg, Jr.		IEEE	Consumers Energy
Mark Jurgemeyer		IEEE/IAS	Stanley Consultants, Inc.
	Russell Guerry	NCEMC	Edgecombe-Martin County EMC
Jacob Joplin		NCEMC	Carteret-Craven Electric Cooperative
Rex Bullinger		NCTA	National Cable & Telecommunications Association
	Christopher Austin	NCTA	Time Warner Cable, NYC–Liberty Division
	Steve Mace	NCTA	National Cable & Telecommunications Association
Jim Byrne		NRECA	Poudre Valley Rural Electric Association
	Michael C. Pehosh	NRECA	National Rural Electric Cooperative Association
Robert S. Fuller		NSPE	Texas-New Mexico Power Co.
	Grant Glaus	NSPE	Columbia Rural Electric Association
Otto J. Lynch		Power Line Systems	Power Line Systems, Inc.
Thomas Haire		REMC	Rutherford EMC

Subcommittee 5 (continued)

<i>Principle</i>	<i>Alternate</i>	<i>Organization represented</i>	<i>Employer</i>
Robert Lash		RUS	USDA, Rural Utilities Service
Timothy Cooke		SCTE	Times Fiber Communications, Inc.
Ron Corzine		SEEX	Georgia Power
Wade Shultz		SEEX	Alabama Power Company
	Frank Agnew	SEEX	Alabama Power Company
	David West	SEEX	Duke Power Company
Clayton L. Clem		TVA	TVA Power System Operations
Douglas Hanson		WAPA	Western Area Power Administration, U.S. Dept of Energy
	Terry Burley	WAPA	Western Area Power Administration, U.S. Dept of Energy

**National Electrical Safety Code—Subcommittee 7—Underground Lines
Sections 30–39**

Charles C. Bleakley, Chair
John C. Spence, Secretary

<i>Principle</i>	<i>Alternate</i>	<i>Organization represented</i>	<i>Employer</i>
Michael Dyer		APPA	Salt River Project
George S. Pristach		APTA	Parsons Brinckerhoff
Lawrence M. Slavin		ATIS	Outside Plant Consulting Services, Inc.
Trevor Bowmer		ATIS	Telcordia
	Dennis Henry	ATIS	Telcordia
James D. Mars		Consultant	Genesis Engineering, Inc.
Lauren E. Gaunt		EEI	Northeast Utilities
Donald Guinn		EEI	Progress Energy
Dennis B. Miller		EEI	Com Ed
John C. Spence		EEI	Baltimore Gas & Electric Co.
	Gregory Obenchain	EEI	Edison Electric Institute
	Jonathan Gonynor	EEI	National Grid
	Katie Croteau	EEI	National Grid
John Korman		EIA	Verizon
	Percy E. Pool	EIA	Verizon
James R. Tomaseski		IBEW	International Brotherhood of Electrical Workers
James Cowan		IEC	Wakker Engineering
Ewell T. Robeson		IEEE	Progress Energy
Richard S. Vencus		IEEE	United Illuminating Company
Christopher Austin		NCTA	Time Warner Cable, NYC–Liberty Division
	Rex Bullinger	NCTA	National Cable & Telecommunications Association
	Steve Mace	NCTA	National Cable & Telecommunications Association
Monte Szendre		NECA	Wilson Construction Company Inc.
Michael C. Pehosh		NRECA	National Rural Electric Cooperative Association
	Robert D. Saint	NRECA	National Rural Electric Cooperative Association
O. Chuck Amrhyn		OPEC	OPEC
Trung Hiu		RUS	Rural Development—Electric Program

Subcommittee 7 (continued)

<i>Principle</i>	<i>Alternate</i>	<i>Organization represented</i>	<i>Employer</i>
	Donald Junta	RUS	USDA, Rural Utilities Service
Timothy Cooke		SCTE	Times Fiber Communications, Inc.
Charles C. Bleakley		SEEX	Georgia Power Company
Mickey B. Gunter		SEEX	Engineering Consultant
	Michael Kosinski	SEEX	Appalachian Power Company

**National Electrical Safety Code—Subcommittee 8—Work Rules
Sections 40–43**

James R. Tomaseski, Chair

Samuel Stonerock, Secretary

<i>Principle</i>	<i>Alternate</i>	<i>Organization represented</i>	<i>Employer</i>
Greg Herbinger		AEIC	Alabama Power Company
	William C. Weintritt	AEIC	Gulf Power Company
Brent McKinney		APPA	City Utilities of Springfield
	Kevin Dody	APPA	City Utilities of Springfield
Wayne Blackley		ATC	Associated Training Corporation
Trevor Bowmer		ATIS	Telcordia
	Dennis Henry	ATIS	Telcordia
Michael Granata		EEI	Appalachian Power Company
Tommy Russell		EEI	Southwestern Electric Power
Samuel Stonerock		EEI	Southern California Edison Co.
	Patrick Geoffrey	EEI	PG&E
	Alan Kuipers	EEI	Consumer Energy
	J. Hilton Lester	EEI	Dominion
	Larry Nash	EEI	Dominion Virginia Power
	Thuy Nguyen	EEI	American Electric Power
George Kerstetter		EIA	Verizon
	John Korman	EIA	Verizon
James R. Tomaseski		IBEW	International Brotherhood of Electrical Workers
Charles Woodings		IEC	Anderson & Wood Constructions Co. Inc.
	James C. Tuggle	IEC	Malpaso Group Inc.
	Robert W. Baird	IEC	Independent Electrical Contractors
Lawrence Schweitzer		IEEE	The L. E. Myers Company
Thomas Verdecchio		IEEE	PSE&G
Stephen Poholski		NECA	Newkirk Electric
Kenneth Brubaker		NRECA	National Rural Electric Cooperative Association
	Mark Zavislan	NRECA	Ohio Rural Electric Cooperatives, Inc.
Steven Theis		NSC	PSEG
F. M. Brooks		NSPE	Brooks & Jackson, Inc.
Albert Smoak		NSPE	Southwestern Electric Power Company
Brian Erga		NWPPA	ESCI Inc.
David M. Wallis		OSHA	OSHA Office of Engineering Safety
Charles Shaw		SEEX	Alabama Power Company

Subcommittee 8 (continued)

<i>Principle</i>	<i>Alternate</i>	<i>Organization represented</i>	<i>Employer</i>
	Keith Wallace	SEEX	Alabama Power Company
Bruce Gurley		SEEX	Duke Energy
J. Frederick Doering		Self	J. F. Doering Associates
Charles W. Grose		Self	Consultant
Edward Hunt		WAPA	Western Area Power Association, U.S. Dept of Energy
	Jeffrey Wild	WAPA	Western Area Power Association, U.S. Dept of Energy

National Electrical Safety Code—Executive Subcommittee

Michael J. Hyland, Chair

James R. Tomaseski, Secretary

<i>Name</i>	<i>Organization</i>	<i>Employer</i>
Michael J. Hyland	APPA	American Public Power Association
Larry Slavin	ATIS	Outside Plant Consulting Services, Inc.
Leon Kempner	BPA	Bonneville Power Administration
Ewell T. Robeson	EEl	Progress Energy
James R. Tomaseski	IBEW	International Brotherhood of Electrical Workers
O. Chuck Amrhyn	OPEC	OPEC

Lisa Perry
IEEE Standards Project Editor

National Electrical Safety Code—Interpretations Subcommittee

Donald E. Hooper, *Chair*

<i>Name</i>	<i>Employer</i>	<i>Part</i>	<i>Section</i>
O. Chuck Amrhyn	OPEC	A	
Rudolph J. Bednarz	JayCo Engineering, Inc.	A	
Charles C. Bleakley	Georgia Power Company	A	
D. J. Christofersen	CeCe	1	
Allen L. Clapp	Clapp Research Associates, P. C.	A	
Alton L. Comans	Alabama Power Company	1	9
John B. Dagenhart	Clapp Research Associates, P. C.	2	9
L. Davis	Manzano-Western Incorporated	3	
Eric K. Engdahl	American Electric Power	A	
Gary R. Engmann	Burns and McDonnell Engineering	1	
Bruce Freimark	American Electric Power	2	
Charles W. Grose	Consultant	4	
Mickey B. Gunter	Engineering Consultant	A	
Donald E. Hooper	ES&C, Inc.	A	
Herman N. Johnson, Jr.	Pike Energy Solutions	A	
Robert G. Oswald	Power Engineers, Inc.	2	
Percy E. Pool	Verizon	3	9
Ewell T. Robeson	Progress Energy	3	9
Wayne B. Roelle	Consultant	2	
Lanny L. Smith	Consultant	A	
James R. Tomaseski	International Brotherhood of Electrical Workers	A	

Key:

A = All areas; 1 = Part 1; 2 = Part 2; 3 = Part 3; 4 = Part 4; 9 = Section 9

Grounding:

When a member has Section 9 and a part number, the member covers grounding and grounding for that part.

Contents

Letter symbols for units	xxxix
Sec. 1. Introduction to the National Electrical Safety Code	1
010. Purpose.....	1
011. Scope.....	1
A. Covered	1
B. Not covered	2
C. Types of requirements	3
012. General rules.....	4
013. Application.....	4
A. New installations and extensions	4
B. Existing installations	4
C. Inspection and work rules	5
014. Waiver.....	5
A. Emergency installations	5
B. Temporary overhead installations	5
015. Intent	5
016. Effective date	6
017. Units of measure	6
018. Method of calculation	6
Sec. 2. Definitions of special terms	7
Sec. 3. References.....	20
Sec. 9. Grounding methods for electric supply and communications facilities.....	22
090. Purpose.....	22
091. Scope.....	22
092. Point of connection of grounding conductor	22
A. Direct-current systems that are required to be grounded	22
1. 750 V and below	22
2. Over 750 V	22
B. Alternating current systems that are required to be grounded	22
1. 750 V and below	22
2. Over 750 V	22
3. Separate grounding conductor	23
C. Messenger wires and guys	23
1. Messenger wires	23
2. Guys	23
3. Common grounding of messengers and guys on the same supporting structure	23
D. Current in grounding conductor	24
E. Fences	24
093. Grounding conductor and means of connection	25
A. Composition of grounding conductors	25
B. Connection of grounding conductors	25
C. Ampacity and strength	25
1. System grounding conductors for single-grounded systems	25
2. System grounding conductors for multi-grounded alternating current systems	25
3. Grounding conductors for instrument transformers	25
4. Grounding conductors for primary surge arresters	26
5. Grounding conductors for equipment, messenger wires, and guys	26

Contents

<i>Section</i>	<i>Page</i>
6. Fences	26
7. Bonding of equipment frames and enclosures	26
8. Ampacity limit	26
9. Strength	26
D. Guarding and protection	26
E. Underground	27
F. Common grounding conductor for circuits, metal raceways, and equipment	27
094. Grounding electrodes	27
A. Existing electrodes	28
1. Metallic water piping system	28
2. Local systems	28
3. Steel reinforcing bars in concrete foundations and footings	28
B. Made electrodes	28
1. General	28
2. Driven rods	28
3. Buried wire, strips, or plates	29
4. Pole-butt plates and wire wraps	29
5. Concentric neutral cable	30
6. Concrete-encased electrodes	30
7. Directly embedded metal poles	30
095. Method of connection to electrode	30
A. Ground connections	30
B. Point of connection to piping systems	31
C. Contact surfaces	31
096. Ground resistance requirements.....	31
A. General	31
B. Supply stations	31
C. Multi-grounded systems	32
D. Single-grounded (unigrounded or delta) systems	32
097. Separation of grounding conductors	32
098. Number 098 not used in this edition.....	33
099. Additional requirements for grounding and bonding of communication apparatus.....	33
A. Electrode	33
B. Electrode connection	34
C. Bonding of electrodes	34

Part 1. Rules for the Installation and Maintenance of Electric Supply Stations and Equipment

Sec. 10. Purpose and scope of rules.....	35
100. Purpose.....	35
101. Scope.....	35
102. Application of rules	35
103. Referenced sections	35
Sec. 11. Protective arrangements in electric supply stations	36
110. General requirements	36
A. Enclosure of equipment	36
1. Types of enclosures	36
2. Safety clearance zone	36
B. Rooms and spaces	37
1. Construction	37
2. Use	37
3. Ventilation	37
4. Moisture and weather	37

Contents

<i>Section</i>	<i>Page</i>
C. Electric equipment	37
111. Illumination.....	39
A. Under normal conditions	39
B. Emergency lighting	39
C. Fixtures	40
D. Attachment plugs and receptacles for general use	40
E. Receptacles in damp or wet locations	40
112. Floors, floor openings, passageways, and stairs	41
A. Floors	41
B. Passageways	41
C. Railings	41
D. Stair guards	41
E. Top rails	41
113. Exits	41
A. Clear exits	41
B. Double exits	41
C. Exit doors	41
114. Fire-extinguishing equipment	42
Sec. 12. Installation and maintenance of equipment	43
120. General requirements	43
121. Inspections	43
A. In-service equipment	43
B. Idle equipment	43
C. Emergency equipment	43
D. New equipment	43
122. Guarding shaft ends, pulleys, belts, and suddenly moving parts	43
A. Mechanical transmission machinery	43
B. Suddenly moving parts	43
123. Protective grounding.....	43
A. Protective grounding or physical isolation of non-current-carrying metal parts	43
B. Grounding method	44
C. Provision for grounding equipment during maintenance	44
D. Grounding methods for direct-current systems over 750 V	44
124. Guarding live parts.....	44
A. Where required	44
B. Strength of guards	44
C. Types of guards	44
1. Location or physical isolation	44
2. Shields or enclosures	45
3. Supplemental barriers or guards within electric supply stations	45
4. Mats	45
5. Live parts below supporting surfaces for persons	45
6. Insulating covering on conductors or parts	45
D. Taut-string distances	45
125. Working space about electric equipment.....	55
A. Working space (600 V or less)	55
1. Clear spaces	55
2. Access and entrance to working space	55
3. Working space	56
4. Headroom working space	56
5. Front working space	56
B. Working space over 600 V	56
126. Equipment for work on energized parts.....	56

Contents

<i>Section</i>	<i>Page</i>
127. Classified locations	56
A. Coal-handling areas	57
B. Flammable and combustible liquids	57
C. Flammable liquid storage area	58
D. Loading and unloading facilities for flammable and combustible liquids	58
E. Gasoline-dispensing stations	58
F. Boilers	58
G. Gaseous hydrogen systems for supply equipment	58
H. Liquid hydrogen systems	58
I. Sulfur	59
J. Oxygen	59
K. Liquefied petroleum gas (LPG)	59
L. Natural gas (methane)	59
128. Identification	59
129. Mobile hydrogen equipment	59
Sec. 13. Rotating equipment	60
130. Speed control and stopping devices	60
A. Automatic overspeed trip device for prime movers	60
B. Manual stopping devices	60
C. Speed limit for motors	60
D. Number 130D not used in this edition	60
E. Adjustable-speed motors	60
F. Protection of control circuits	60
131. Motor control	60
132. Number 132 not used in this edition	61
133. Short-circuit protection	61
Sec. 14. Storage batteries	62
140. General	62
141. Location	62
142. Ventilation	62
143. Racks	62
144. Floors in battery areas	62
145. Illumination for battery areas	62
146. Service facilities	62
Sec. 15. Transformers and regulators	64
150. Current-transformer secondary circuits protection when exceeding 600 V	64
151. Grounding secondary circuits of instrument transformers	64
152. Location and arrangement of power transformers and regulators	64
A. Outdoor installations	64
B. Indoor installations	64
153. Short-circuit protection of power transformers	65
Sec. 16. Conductors	66
160. Application	66
161. Electrical protection	66
A. Overcurrent protection required	66
B. Grounded conductors	66
C. Insulated power cables	66
162. Mechanical protection and support	66
163. Isolation	66

Contents

<i>Section</i>	<i>Page</i>
164. Conductor terminations.....	66
A. Insulation	66
B. Metal-sheathed or shielded cable	66
Sec. 17. Circuit breakers, reclosers, switches, and fuses	67
170. Arrangement	67
171. Application.....	67
172. Circuit breakers, reclosers, and switches containing oil	67
173. Switches and disconnecting devices	67
A. Capacity	67
B. Provisions for disconnecting	67
174. Disconnection of fuses.....	67
Sec. 18. Switchgear and metal-enclosed bus	69
180. Switchgear assemblies	69
A. General requirements for all switchgear	69
B. Metal-enclosed power switchgear	69
C. Dead-front power switchboards	70
D. Motor control centers	70
E. Control switchboards	70
181. Metal-enclosed bus	70
A. General requirements for all types of bus	70
B. Isolated-phase bus	71
Sec. 19. Surge arresters.....	72
190. General requirements.....	72
191. Indoor locations	72
192. Grounding conductors.....	72
193. Installation	72
 Part 2. Safety Rules for the Installation and Maintenance of Overhead Electric Supply and Communication Lines	
Sec. 20. Purpose, scope, and application of rules	73
200. Purpose.....	73
201. Scope.....	73
202. Application of rules	73
Sec. 21 General requirements	74
210. Referenced sections	74
211. Number 211 not used in this edition.....	74
212. Induced voltages	74
213. Accessibility.....	74
214. Inspection and tests of lines and equipment	74
A. When in service	74
1. Initial compliance with rules	74
2. Inspection	74
3. Tests	74
4. Inspection records	74
5. Corrections	74
B. When out of service	75
1. Lines infrequently used	75
2. Lines temporarily out of service	75
3. Lines permanently abandoned	75

Contents

<i>Section</i>	<i>Page</i>
215. Grounding of circuits, supporting structures, and equipment.....	75
A. Methods	75
B. Circuits	75
1. Common neutral	75
2. Other neutrals	75
3. Other conductors	75
4. Surge arresters	75
5. Use of earth as part of circuit	75
C. Non-current-carrying parts	75
1. General	75
2. Anchor guys and span guys	76
3. Span wires carrying luminaires or traffic signals	76
4. Use of insulators in anchor guys	76
5. Use of insulators in span guys and span wires supporting luminaries and traffic signals	76
6. Use of insulators in span wires supporting energized trolley or electric railroad contact conductors	76
7. Insulators used to limit galvanic corrosion	77
8. Multiple messengers on the same structure	77
216. Arrangement of switches	77
A. Accessibility	77
B. Indicating open or closed position	77
C. Locking	77
D. Uniform position	77
E. Remotely controlled, automatic transmission, or distribution overhead line switching devices	77
217. General.....	77
A. Supporting structures	77
1. Protection of structures	77
2. Readily climbable supporting structures	78
3. Identification	78
4. Attachments, decorations, and obstructions	79
B. Unusual conductor supports	79
C. Protection and marking of guys	79
218. Vegetation management	79
A. General	79
B. At line crossings, railroad crossings, limited-access highway crossings, or navigable waterways requiring crossing permits	79
Sec. 22. Relations between various classes of lines and equipment.....	80
220. Relative levels.....	80
A. Standardization of levels	80
B. Relative levels: supply and communication conductors	80
1. Preferred levels	80
2. Special construction for supply circuits, the voltage of which is 600 V or less and carrying power not in excess of 5 kW	80
C. Relative levels: Supply lines of different voltage classifications (0 to 750 V, over 750 V to 8.7 kV, over 8.7 kV to 22 kV, over 22 kV to 50 kV, and over 50 kV)	81
1. At crossings or conflicts	81
2. On structures used only by supply conductors	81
D. Identification of overhead conductors	81
E. Identification of equipment on supporting structures	81
221. Avoidance of conflict.....	81

Contents

<i>Section</i>	<i>Page</i>
222. Joint use of structures	82
223. Communications protective requirements	82
A. Where required	82
B. Means of protection	82
224. Communication circuits located within the supply space and supply circuits located within the communication space	82
A. Communication circuits located in the supply space	82
B. Supply circuits used exclusively in the operation of communication circuits	83
225. Electric railway construction	83
A. Trolley-contact conductor fastenings	83
B. High-voltage contact conductors	84
C. Third rails	84
D. Prevention of loss of contact at railroad crossings at grade	84
E. Guards under bridges	84
Sec. 23. Clearances	85
230. General	85
A. Application	85
1. Permanent and temporary installations	85
2. Emergency installations	85
3. Measurement of clearance and spacing	85
4. Rounding of calculation results	86
B. Ice and wind loading for clearances	87
C. Supply cables	88
D. Covered conductors	88
E. Neutral conductors	88
F. Fiber-optic cable	88
1. Fiber-optic—supply cable	88
2. Fiber-optic—communication cable	89
G. Alternating- and direct-current circuits	89
H. Constant-current circuits	89
I. Maintenance of clearances and spacings	89
231. Clearances of supporting structures from other objects	91
A. From fire hydrants	91
B. From streets, roads, and highways	91
C. From railroad tracks	91
232. Vertical clearances of wires, conductors, cables, and equipment above ground, roadway, rail, or water surfaces	91
A. Application	91
B. Clearance of wires, conductors, cables, equipment, and support arms mounted on supporting structures	92
1. Clearance to wires, conductors, and cables	92
2. Clearance to unguarded rigid live parts of equipment	92
3. Clearance to support arms, switch handles, and equipment cases	92
4. Street and area lighting	92
C. Additional clearances for wires, conductors, cables, and unguarded rigid live parts of equipment	92
1. Voltages exceeding 22 kV	92
D. Alternate clearances for voltages exceeding 98 kV ac to ground or 139 kV dc to ground	93
1. Sag conditions of line conductors	93
2. Reference heights	93
3. Electrical component of clearance	93
4. Limit	94

Contents

<i>Section</i>	<i>Page</i>
233. Clearances between wires, conductors, and cables carried on different supporting structures	105
A. General	105
1. Conductor movement envelope	105
2. Clearance envelope	106
B. Horizontal clearance	106
1. Clearance requirements	106
2. For voltages exceeding 50 kV, the additional clearance specified in Rule 233B1 shall be increased 3% for each 300 m (1000 ft) in excess of 1000 m (3300 ft) above mean sea level	106
3. Alternate clearances between conductors of different circuits where one or both circuits exceed 98 kV ac to ground or 139 kV dc to ground	106
C. Vertical clearance	107
1. Clearance requirements	107
2. Voltages exceeding 22 kV	107
3. Alternate clearances for voltage exceeding 98 kV ac to ground or 139 kV dc to ground	107
234. Clearance of wires, conductors, cables, and equipment from buildings, bridges, rail cars, swimming pools, and other installations	116
A. Application	116
1. Vertical and horizontal clearances (no wind displacement)	116
2. Horizontal clearances (with wind displacement)	117
3. Transition between horizontal and vertical clearances	117
B. Clearances of wires, conductors, and cables from other supporting structures	117
1. Horizontal clearances	117
2. Vertical clearances	118
C. Clearances of wires, conductors, cables, and rigid live parts from buildings, signs, billboards, chimneys, radio and television antennas, tanks, flagpoles and flags, banners, and other installations except bridges	118
1. Vertical and horizontal clearances	118
2. Guarding of supply conductors and rigid live parts	119
3. Supply conductors attached to buildings or other installations	119
4. Communication conductors attached to buildings or other installations	120
D. Clearance of wires, conductors, cables, and unguarded rigid live parts from bridges	120
1. Vertical and horizontal clearances	120
2. Guarding trolley-contact conductors located under bridges	121
E. Clearance of wires, conductors, cables, or unguarded rigid live parts installed over or near swimming areas with no wind displacement	121
1. Swimming pools	121
2. Beaches and waterways restricted to swimming	121
3. Waterways subject to water skiing	122
F. Clearances of wires, conductors, cables, and rigid live parts from grain bins	122
1. Grain bins loaded by permanently installed augers, conveyers, or elevator systems ..	122
2. Grain bins loaded by portable augers, conveyers, or elevators (with no wind displacement)	122
G. Additional clearances for voltages exceeding 22 kV for wires, conductors, cables, and unguarded rigid live parts of equipment	122
H. Alternate clearances for voltages exceeding 98 kV ac to ground or 139 kV dc to ground	123
1. Sag conditions of line conductors	123
2. Reference distances	123
3. Electrical component of clearance	123
4. Limit	123
I. Clearance of wires, conductors, and cables to rail cars	123

Contents

<i>Section</i>	<i>Page</i>
J. Clearance of equipment mounted on supporting structures	124
1. Clearance to unguarded rigid live parts of equipment	124
2. Clearance to equipment cases	124
235. Clearance for wires, conductors, or cables carried on the same supporting structure	145
A. Application of rule	145
1. Multiconductor wires or cables	145
2. Conductors supported by messengers or span wires	145
3. Line conductors of different circuits	145
B. Horizontal clearance between line conductors	146
1. Fixed supports	146
2. Suspension insulators	147
3. Alternate clearances for different circuits where one or both circuits exceed 98 kV ac to ground or 139 kV dc to ground	147
C. Vertical clearance between conductors at the support	148
1. Basic clearance for conductors of same or different circuits	148
2. Additional clearances	148
3. Alternate clearances for different circuits where one or both exceed 98 kV ac, or 139 kV dc to ground	150
4. Communication worker safety zone	151
D. Diagonal clearance between line wires, conductors, and cables located at different levels on the same supporting structure	151
E. Clearances in any direction at or near a support from line conductors to supports, and to vertical or lateral conductors, service drops, and span or guy wires, attached to the same support	151
1. Fixed supports	151
2. Suspension insulators	151
3. Alternate clearances for voltages exceeding 98 kV ac to ground or 139 kV dc to ground	151
F. Clearances between circuits of different voltage classifications located in the supply space on the same support arm	152
G. Conductor spacing: vertical racks or separate brackets	153
H. Clearance and spacing between communication conductors, cables, and equipment	153
I. Clearances in any direction from supply line conductors to communication antennas in the supply space attached to the same supporting structure	153
1. General	153
2. Communication antenna	153
3. Equipment case that supports or is adjacent to a communication antenna	153
4. Vertical or lateral communication conductors and cables attached to a communication antenna	153
236. Climbing space	171
A. Location and dimensions	171
B. Portions of supporting structures in climbing space	172
C. Support arm location relative to climbing space	172
D. Location of equipment relative to climbing space	172
E. Climbing space between conductors	172
F. Climbing space on buckarm construction	172
G. Climbing space past longitudinal runs not on support arms	173
H. Climbing space past vertical conductors	173
I. Climbing space near ridge-pin conductors	173
237. Working space	176
A. Location of working spaces	176
B. Dimensions of working spaces	176
1. Along the support arm	176
2. At right angles to the support arm	176

Contents

<i>Section</i>	<i>Page</i>
3. Vertically	176
C. Location of vertical and lateral conductors relative to working spaces	176
D. Location of buckarms relative to working spaces	176
1. Standard height of working space	176
2. Reduced height of working space	176
E. Guarding of energized equipment	176
F. Working clearances from energized equipment	177
238. Vertical clearance between certain communications and supply facilities located on the same structure	177
A. Equipment	177
B. Clearances in general	177
C. Clearances for span wires or brackets	177
D. Clearance of drip loops of luminaire or traffic signal brackets	177
E. Communication worker safety zone	178
239. Clearance of vertical and lateral facilities from other facilities and surfaces on the same supporting structure	179
A. General	179
B. Location of vertical or lateral conductors relative to climbing spaces, working spaces, and pole steps	180
C. Conductors not in conduit	180
D. Guarding and protection near ground	180
E. Requirements for vertical and lateral supply conductors on supply line structures or within supply space on jointly used structures	180
1. General clearances	180
2. Special cases	180
F. Requirements for vertical and lateral communication conductors on communication line structures or within the communication space on jointly used structures	181
1. Clearances from communication conductors	181
2. Clearances from supply conductors	181
G. Requirements for vertical supply conductors and cables passing through communication space on jointly used line structures	181
1. Guarding—General	181
2. Cables and conductors in conduit or covering	182
3. Protection near trolley, ungrounded traffic signal, or ungrounded luminaire attachments	182
4. Aerial services	182
5. Clearance from through bolts and other metal objects	182
H. Requirements for vertical communication conductors passing through supply space on jointly used structures	182
1. Metal-sheathed communication cables	182
2. Communication conductors	183
3. Communication grounding conductors	183
4. Clearance from through bolts and other metal objects	183
I. Operating rods	183
J. Additional rules for standoff brackets	183
Sec. 24. Grades of construction	186
240. General	186
241. Application of grades of construction to different situations	186
A. Supply cables	186
B. Order of grades	186
C. At crossings	186
1. Grade of upper line	186

Contents

<i>Section</i>	<i>Page</i>
2. Grade of lower line	186
3. Multiple crossings	186
D. Conflicts (see Section 2, structure conflict)	186
242. Grades of construction for conductors	187
A. Constant-current circuit conductors	187
B. Railway feeder and trolley-contact circuit conductors	187
C. Communication circuit conductors and cables	187
D. Fire-alarm circuit conductors	187
E. Neutral conductors of supply circuits	187
F. Surge-protection wires	187
243. Grades of construction for line supports	189
A. Structures	189
B. Crossarms and support arms	189
C. Pins, armless construction brackets, insulators, and conductor fastenings	189
Sec. 25. Loadings for Grades B and C	191
250. General loading requirements and maps	191
A. General	191
B. Combined ice and wind district loading	191
C. Extreme wind loading	191
1. Velocity pressure exposure coefficient, k_z	192
2. Gust response factor, G_{RF}	192
D. Extreme ice with concurrent wind loading	193
251. Conductor loading	208
A. General	208
B. Load components	208
1. Vertical load component	208
2. Horizontal load component	209
3. Total load	209
252. Loads on line supports	209
A. Assumed vertical loads	209
B. Assumed transverse loads	210
1. Transverse loads from conductors and messengers	210
2. Wind loads on structures	210
3. At angles	210
4. Span lengths	210
C. Assumed longitudinal loading	210
1. Change in grade of construction	210
2. Jointly used poles at crossings over railroads, communication lines, or limited access highways	211
3. Deadends	211
4. Unequal spans and unequal vertical loads	211
5. Stringing loads	211
6. Longitudinal capability	211
7. Communication conductors on unguyed supports at railroad and limited access highway crossings	211
D. Simultaneous application of loads	211
253. Load factors for structures, crossarms, support hardware, guys, foundations, and anchors....	211
Sec. 26. Strength requirements	213
260. General (see also Section 20)	213
A. Preliminary assumptions	213
B. Application of strength factors	213

Contents

<i>Section</i>	<i>Page</i>
261. Grades B and C construction	214
A. Supporting structures	214
1. Metal, prestressed-, and reinforced-concrete structures	214
2. Wood structures	214
3. Fiber-reinforced polymer structures	215
4. Transverse strength requirements for structures where side guying is required, but can be installed only at a distance	215
5. Longitudinal strength requirements for sections of higher grade in lines of a lower grade construction	216
B. Strength of foundations, settings, and guy anchors	216
C. Strength of guys and guy insulators	216
1. Metal and prestressed-concrete structures	216
2. Wood and reinforced-concrete structures	216
3. Fiber-reinforced polymer structures	216
D. Crossarms and braces	217
1. Concrete and metal crossarms and braces	217
2. Wood crossarms and braces	217
3. Fiber-reinforced polymer crossarms and braces	217
4. Crossarms and braces of other materials	217
5. Additional requirements	217
E. Insulators	218
F. Strength of pin-type or similar construction and conductor fastenings	218
1. Longitudinal strength	218
2. Double pins and conductor fastenings	218
3. Single supports used in lieu of double wood pins	218
G. Armless construction	219
1. General	219
2. Insulating material	219
3. Other components	219
H. Open supply conductors and overhead shield wires	219
1. Tensions	219
2. Splices, taps, dead-end fittings, and associated attachment hardware	219
3. Trolley-contact conductors	219
I. Supply cable messengers	220
J. Open-wire communication conductors	220
K. Communication cables and messengers	220
1. Communication cables	220
2. Messenger	220
L. Paired metallic communication conductors	220
1. Paired conductors supported on messenger	220
2. Paired conductors not supported on messenger	220
M. Support and attachment hardware	221
N. Climbing and working steps and their attachments to the structure	221
262. Number 262 not used in this edition	223
263. Grade N construction	223
A. Poles	223
B. Guys	223
C. Crossarm strength	223
D. Supply line conductors	223
1. Size	223
E. Service drops	223
1. Size of open-wire service drops	223
2. Tension of open-wire service drops	224
3. Cabled service drops	224

Contents

<i>Section</i>	<i>Page</i>
F. Trolley-contact conductors	224
G. Communication conductors	224
H. Street and area lighting equipment	224
I. Insulators	224
264. Guying and bracing.....	225
A. Where used	225
B. Strength	225
C. Point of attachment	225
D. Guy fastenings	226
E. Electrolysis	226
F. Anchor rods	226
Sec. 27. Line insulation.....	227
270. Application of rule	227
271. Material and marking.....	227
272. Ratio of flashover to puncture voltage.....	227
273. Insulation level.....	227
274. Factory tests	228
275. Special insulator applications	228
A. Insulators for constant-current circuits	228
B. Insulators for single-phase circuits directly connected to three-phase circuits	228
276. Number 276 not used in this edition.....	228
277. Mechanical strength of insulators	228
278. Aerial cable systems	230
A. Electrical requirements	230
B. Mechanical requirements	230
279. Guy and span insulators.....	230
A. Insulators	230
1. Properties of guy insulators	230
2. Galvanic corrosion and BIL insulation	230
B. Properties of span-wire insulators	231
1. Material	231
2. Insulation level	231
3. Mechanical strength	231
Sec. 28. Section number 28 not used in this edition.....	231
Sec. 29. Section number 29 not used in this edition.....	231

Part 3. Safety Rules for the Installation and Maintenance of Underground Electric Supply and Communication Lines

Sec. 30. Purpose, scope, and application of rules	233
300. Purpose.....	233
301. Scope.....	233
302. Application of rules	233
Sec. 31. General requirements applying to underground lines	234
310. Referenced sections	234
311. Installation and maintenance	234
312. Accessibility.....	234
313. Inspection and tests of lines and equipment	234
A. When in service	234
1. Initial compliance with safety rules	234
2. Inspection	234
3. Tests	234
4. Inspection records	234

Contents

<i>Section</i>	<i>Page</i>
5. Corrections	234
B. When out of service	235
1. Lines infrequently used	235
2. Lines temporarily out of service	235
3. Lines permanently abandoned	235
314. Grounding of circuits and equipment	235
A. Methods	235
B. Conductive parts to be grounded	235
C. Circuits	235
1. Neutrals	235
2. Other conductors	235
3. Surge arresters	235
4. Use of earth as part of circuit	235
315. Communications protective requirements	235
A. Where required	235
B. Means of protection	236
316. Induced voltage.....	236
Sec. 32. Underground conduit systems.....	237
320. Location	237
A. Routing	237
1. General	237
2. Natural hazards	237
3. Highways and streets	237
4. Bridges and tunnels	237
5. Crossing railroad tracks	237
6. Submarine crossing	237
B. Separation from other underground installations	238
1. General	238
2. Separations between supply and communication conduit systems	238
3. Sewers, sanitary and storm	238
4. Water lines	238
5. Gas and other lines that transport flammable material	238
6. Steam lines	238
321. Excavation and backfill	238
A. Trench	238
B. Quality of backfill	238
322. Ducts and joints	239
A. General	239
B. Installation	239
1. Restraint	239
2. Joints	239
3. Externally coated pipe	239
4. Building walls	239
5. Bridges	239
323. Manholes, handholes, and vaults	239
A. Strength	239
B. Dimensions	240
C. Manhole access	240
D. Covers	241
E. Vault and utility tunnel access	241
F. Ladder requirements	241
G. Drainage	241
H. Ventilation	241

Contents

<i>Section</i>	<i>Page</i>
I. Mechanical protection	242
J. Identification	242
Sec. 33. Supply cable	243
330. General	243
331. Sheaths and jackets	243
332. Shielding	243
A. General	243
B. Material	243
333. Cable accessories and joints	243
Sec. 34. Cable in underground structures	245
340. General	245
341. Installation	245
A. General	245
B. Cable in manholes and vaults	245
1. Supports	245
2. Clearance	245
3. Identification	246
342. Grounding and bonding	246
343. Fireproofing	246
344. Communication cables containing special supply circuits	247
Sec. 35. Direct-buried cable and cable in duct not part of a conduit system	248
350. General	248
351. Location and routing	249
A. General	249
B. Natural hazards	249
C. Other conditions	249
1. Swimming pools (in-ground)	249
2. Buildings and other structures	250
3. Railroad tracks	250
4. Highways and streets	250
5. Submarine crossings	250
352. Installation	250
A. Trenching	250
B. Plowing	250
C. Boring	250
D. Depth of burial	251
353. Deliberate separations—Equal to or greater than 300 mm (12 in) from underground structures or other cables	251
A. General	251
B. Crossings	252
C. Parallel facilities	252
D. Thermal protection	252
354. Random separation—Separation less than 300 mm (12 in) from underground structures or other cables	252
A. General	252
B. Supply cables or conductors	252
C. Communication cables or conductors	252
D. Supply and communication cables or conductors	253
1. General	253
2. Grounded bare or semiconducting jacketed neutral supply cables	253
3. Insulating jacketed grounded neutral supply cables	254

Contents

<i>Section</i>	<i>Page</i>
4. Insulating jacketed grounded neutral supply cables in nonmetallic duct	254
E. Supply and communication cables or conductors and non-metallic water and sewer lines	254
355. Additional rules for duct not part of a conduit system	254
Sec. 36. Risers	255
360. General	255
361. Installation	255
362. Pole risers—Additional requirements	255
363. Pad-mounted installations	255
Sec. 37. Supply cable terminations	256
370. General	256
371. Support at terminations	256
372. Identification	256
373. Clearances in enclosures or vaults	256
374. Grounding	256
Sec. 38. Equipment	257
380. General	257
381. Design	257
382. Location in underground structures	258
383. Installation	258
384. Grounding and bonding	258
385. Identification	258
Sec. 39. Installation in tunnels	259
390. General	259
391. Environment	259
Part 4. Work Rules for the Operation of Electric Supply and Communications Lines and Equipment	
Sec. 40. Purpose and scope	261
400. Purpose	261
401. Scope	261
402. Referenced sections	261
Sec. 41. Supply and communications systems—Rules for employers	262
410. General requirements	262
A. General	262
B. Emergency and first aid procedures	263
C. Responsibility	263
411. Protective methods and devices	267
A. Methods	267
B. Devices and equipment	267
C. Inspection and testing of protective devices and equipment	268
D. Signs and tags for employee safety	268
E. Identification and location	268
F. Fall protection	268
Sec. 42. General rules for employees	269
420. General	269
A. Rules and emergency methods	269

Contents

<i>Section</i>	<i>Page</i>
B. Qualifications of employees	269
C. Safeguarding oneself and others	269
D. Energized or unknown conditions	269
E. Ungrounded metal parts	270
F. Arcing conditions	270
G. Liquid-cell batteries	270
H. Tools and protective equipment	270
I. Clothing	270
J. Ladders and supports	270
K. Fall protection	270
L. Fire extinguishers	271
M. Machines or moving parts	271
N. Fuses	271
O. Cable reels	272
P. Street and area lighting	272
Q. Communication antennas	272
421. General operating routines	272
A. Duties of a first-level supervisor or person in charge	272
B. Area protection	272
1. Areas accessible to vehicular and pedestrian traffic	272
2. Areas accessible to employees only	272
3. Locations with crossed or fallen wires	273
C. Escort	273
422. Overhead line operating procedures	273
A. Setting, moving, or removing poles in or near energized electric supply lines	273
B. Checking structures before climbing	273
C. Installing and removing wires or cables	273
423. Underground line operating procedures	274
A. Guarding manhole and street openings	274
B. Testing for gas in manholes and unventilated vaults	274
C. Flames	274
D. Excavation	274
E. Identification	274
F. Operation of power-driven equipment	275
Sec. 43. Additional rules for communications employees	276
430. General	276
431. Approach to energized conductors or parts	276
432. Joint-use structures	278
433. Attendant on surface at joint-use manhole	279
434. Sheath continuity	279
Sec. 44. Additional rules for supply employees	280
440. General	280
441. Energized conductors or parts	280
A. Minimum approach distance to energized lines or parts	280
1. General	280
2. Precautions for approach—Voltages from 51 V to 300 V	280
3. Precautions for approach—Voltages from 301 V to 72.5 kV	280
4. Precautions for approach—Voltages above 72.5 kV	281
5. Temporary (transient) overvoltage control device (TTOCD)	282
6. Altitude correction	282
B. Additional approach requirements	282
C. Live-line tool clear insulation length	283

Contents

<i>Section</i>	<i>Page</i>
1. Clear live-line tool length	283
2. Live-line conductor support tool length	283
442. Switching control procedures	287
A. Designated person	287
B. Specific work	287
C. Operations at stations	287
D. Re-energizing after work	287
E. Tagging electric supply circuits associated with work activities	287
F. Restoration of service after automatic trip	288
G. Repeating oral messages	288
443. Work on energized lines and equipment	288
A. General requirements	288
B. Requirement for assisting employee	289
C. Opening and closing switches	289
D. Working position	289
E. Protecting employees by switches and disconnectors	289
F. Making connections	289
G. Switchgear	289
H. Current transformer secondaries	289
I. Capacitors	289
J. Gas-insulated equipment	290
K. Attendant on surface	290
L. Unintentional grounds on delta circuits	290
444. De-energizing equipment or lines to protect employees	290
A. Application of rule	290
B. Employee's request	290
C. Operating switches, disconnectors, and tagging	290
D. Employee's protective grounds	290
E. Proceeding with work	291
F. Reporting clear—Transferring responsibility	291
G. Removal of tags	291
H. Sequence of re-energizing	291
445. Protective grounds	291
A. Installing grounds	292
1. Current-carrying capacity of grounds	292
2. Initial connections	292
3. Test for voltage	292
4. Completing grounds	292
B. Removing grounds	292
446. Live work	292
447. Protection against arcing and other damage while installing and maintaining insulators and conductors.....	293
 Appendix A—Uniform system of clearances (adopted in the 1990 Edition).....	 295
 Appendix B—Uniform clearance calculations for conductors under ice and wind conditions (adopted in the 2007 Edition)	 301
 Appendix C—Example applications for Rule 250C Tables 250-2 and 250-3	 304
 Appendix D—Determining maximum anticipated per-unit overvoltage factor (T) at the worksite.....	 319

Contents

<i>Section</i>	<i>Page</i>
Appendix E—Bibliography	320
Index	325
Procedure for revising the National Electrical Safety Code	348
Time schedule for the next revision of the National Electrical Safety Code.....	350
Working Group assignments and activities for the 2017 Edition	351

Contents

<i>Figure</i>	<i>Rule</i>	<i>Page</i>
Figure D-1	Sag and apparent sag.....	15
Figure 110-1	Safety clearance to electric supply station fences.....	38
Figure 110-2	Safety clearance to electric supply station impenetrable fence.....	38
Figure 124-1	Clearance from live parts.....	46
Figure 124-2	Railings or fences used as guards.....	46
Figure 124-3	Taut-string measurement of vertical clearance to energized parts of equipment or behind barriers.....	47
Figure 230-1	Clearance zone map of the United States.....	89
Figure 233-1	Use of clearance envelope and conductor movement envelopes to determine applicable clearance.....	108
Figure 233-2	Conductor movement envelope (m).....	109
Figure 233-2	Conductor movement envelope (ft).....	110
Figure 233-3	Clearance envelope.....	111
Figure 234-1(a)	Clearance diagram for building.....	125
Figure 234-1(b)	Clearance diagram for other structures.....	126
Figure 234-1(c)	Transitional clearance when H is greater than V.....	126
Figure 234-2	Clearances of service drop terminating on support mast.....	127
Figure 234-3	Swimming pool clearances.....	127
Figure 234-4(a)	Clearance envelope for grain bins filled by permanently installed augers, conveyors, or elevators.....	128
Figure 234-4(b)	Clearance envelope for grain bins filled by portable augers, conveyors, or elevators.....	129
Figure 234-5	Rail car clearances.....	129
Figure 235-1	Clearance diagram for energized conductor.....	154
Figure 236-1	Rule 236G, EXCEPTION 3.....	174
Figure 237-1	Obstruction of working space by buckarm.....	177
Figure 250-1	General loading map of United States with respect to loading of overhead lines.....	194
Figure 250-2(a)	Basic wind speeds.....	195
Figure 250-2(b)	Basic wind speeds.....	196
Figure 250-2(c)	Western Gulf of Mexico hurricane coastline.....	197
Figure 250-2(d)	Eastern Gulf of Mexico and southeastern U.S. hurricane coastline.....	197
Figure 250-2(e)	Mid and northern Atlantic hurricane coastline.....	198
Figure 250-3(a)	Uniform ice thickness with concurrent wind.....	199
Figure 250-3(b)	Uniform ice thickness with concurrent wind.....	200
Figure 250-3(c)	Uniform ice thickness with concurrent wind.....	201
Figure 250-3(d)	Uniform ice thickness with concurrent wind.....	201
Figure 250-3(e)	Uniform ice thickness with concurrent wind.....	202
Figure 250-3(f)	Uniform ice thickness with concurrent wind.....	203
Figure 279-1	Insulator used for BIL insulation.....	231
Figure 323-1	Roadway vehicle load.....	242
Figure 323-2	Wheel load area.....	242
Figure 350-1	Symbols for identification of buried cables.....	249
 <i>Appendix figure</i>		
Figure A-1	Clearance at maximum sag.....	300

Contents

<i>Table</i>		<i>Rule</i>	<i>Page</i>
Table 110-1	Values for use with Figure 110-1	11B2	39
Table 111-1	Illumination levels.....	111A	40
Table 124-1	Clearances from live parts.....	124A1	48
Table 125-1	Working space.....	125A3	56
Table 230-1	Ice thickness for purposes of calculating clearances.....	230B	90
Table 230-2	Ice, wind pressures, temperatures, and additive constants for purposes of calculating final inelastic deformation	230B	90
Table 232-1	Vertical clearance of wires, conductors, and cables above ground, roadway, rail, or water surfaces.....	232B1	94
Table 232-2	Vertical clearance of equipment cases, support arms, platforms, braces and unguarded rigid live parts above ground, roadway, or water surfaces	232B2	101
Table 232-3	Reference heights	232D2	104
Table 232-4	Electrical component of clearance in Rule 232D3a	232D3a	105
Table 233-1	Vertical clearance between wires, conductors, and cables carried on different supporting structure.....	233C1	111
Table 233-2	Clearance between supply wires, conductors, and cables in Rules 233A and 233C3b(1)	233C3b(1)	115
Table 233-3	Reference heights	233C3a	116
Table 234-1	Clearance of wires, conductors, cables, and unguarded rigid live parts adjacent but not attached to buildings and other installations except bridges	234C1a	130
Table 234-2	Clearance of wires, conductors, cables, and unguarded rigid live parts from bridges	234D1a	138
Table 234-3	Clearance of wires, conductors, cables, or unguarded rigid live parts over or near swimming pools.....	234E1	142
Table 234-4	Electrical component of clearance of buildings, bridges, and other installations	234H3a	144
Table 234-5	Reference distances	234H2	145
Table 235-1	Horizontal clearance between wires, conductors, or cables at supports	235B1a	155
Table 235-2	Horizontal clearances between line conductors smaller than AWG No. 2 at supports, based on sags	235B1b(1)	156
Table 235-3	Horizontal clearances between line conductors AWG No. 2 or larger at supports, based on sags	235B1b(2)	158
Table 235-4	Electrical clearances in Rule 235B3a(1)	235B3a(1)	160
Table 235-5	Vertical clearance between conductors at supports	235C1	161
Table 235-6	Clearance in any direction from line conductors at or near a support to supports, and to vertical or lateral conductors, service drops, span or guy wires, and to communication antennas attached to the same support	235E1	165
Table 235-7	Clearance in any direction from line conductors to supports.....	235E3b	170
Table 235-8	Vertical spacing between conductors supported on vertical racks or separate brackets.....	235	171
Table 236-1	Horizontal clearance between conductors bounding the climbing space.....	236E	175
Table 238-1	Vertical clearance between supply conductors and communications equipment, between communication conductors and supply equipment, and between supply and communications equipment	238B	178
Table 238-2	Vertical clearance of span wires and brackets from communication lines	238C	179

Contents

<i>Table</i>	<i>Rule</i>	<i>Page</i>
Table 239-1	Clearance of open vertical and lateral conductors	239E1 184
Table 239-2	Clearance between open vertical conductors and pole surface	239E2a(1) 185
Table 242-1	Grades of construction for conductors and cables alone, at crossing, or on the same structures with other conductors and cables	250C 188
Table 250-1	Ice, wind pressures, and temperatures	250C 204
Table 250-2	Velocity pressure exposure coefficient k_z	250C 205
Table 250-3	Structure and wire gust response factors, G_{RF}	250C 206
Table 250-3	Structure and wire gust response factors, G_{RF}	250C 207
Table 250-4	Wind speed conversions to pressure	250D 208
Table 251-1	Temperatures and constants	251B3 209
Table 253-1	Load factors for structures, crossarms, support hardware, guys, foundations, and anchors to be used with the strength factors of Table 261-1	253 212
Table 261-1	Strength factors for structures, crossarms, braces, support hardware, guys, foundations, and anchors	261D 222
Table 261-2	Dimensions of crossarm cross section of select Southern Pine and Douglas Fir	261D2 223
Table 263-1	Sizes for Grade N supply line conductors	263D1 224
Table 263-2	Sizes of service drops of 750 V or less	263E1a(1) 225
Table 273-1	Insulation level requirements	273 228
Table 277-1	Allowed percentages of strength ratings	277 229
Table 341-1	Clearance between supply and communications facilities in joint-use manholes and vaults	341B2b(5) 246
Table 352-1	Supply cable, conductor, or duct burial depth	352D2 251
Table 410-1	Clothing and clothing systems (cal/cm^2) for voltages 50 V to 1000 V (ac)	410A3 263
Table 410-2	Clothing and clothing systems—voltage, fault current, and maximum clearing time for voltages 1.1 kV to 46 kV ac	410A3 265
Table 410-3	Live-line tool work clothing and clothing systems—voltage, fault current, and maximum clearing time for voltages 46.1 kV to 800 kV ac	410A3 266
Table 431-1	Communication work minimum approach distances	431 277
Table 441-1	AC live work minimum approach distance	441A4 284
Table 441-2	DC live work minimum approach distance	441A4 285
Table 441-3	Altitude correction factor	441A4 286
Table 441-4	Maximum use voltage for rubber insulating equipment	441A1 286
 Appendix tables		
Table A-1		296
Table A-2a—Reference components of Rule 232		297
Table A-2b—Reference components of Rule 234		299

Letter symbols for units

This Code uses standard symbols for units. They have the following meanings:

A	ampere
C	degree Celsius
ft	foot
ft ²	square foot
ft ³	cubic foot
F	degree Fahrenheit
g	gram
Hz	hertz
h	hour
in	inch
in ²	square inch
k	kilo (10 ³)
kg	kilogram
kPa	kilopascal
km ²	square kilometer
kV	kilovolt (1000 volts)
kVA	kilovoltampere
kW	kilowatt
m	meter
m ²	square meter
m ³	cubic meter
m	milli (10 ⁻³)
mA	milliampere
mi	mile (international)
mm	millimeter
min	minute (time)
N	newton
Pa	pascal
lb	pound
s	second (time)
V	volt
W	watt

Section 1. Introduction to the National Electrical Safety Code®

The National Electrical Safety Code (NESC®) is American National Standard C2. It is a consensus standard that has been prepared by the National Electrical Safety Code Committee under procedures approved by the American National Standards Institute (ANSI). The membership of the NESC Committee is composed of national and international organizations and is certified by ANSI as having an appropriate balance of the interests of members of the public, utility workers, regulatory agencies, and the various types of private and public utilities.

The NESC is used in whole or in part by statute, regulation, or consent as the standard (or basis of the standard) of safe practice for public and private utilities in the United States, as well various jurisdictions and industries in other countries.

010. Purpose

- A. The purpose of the NESC is the practical safeguarding of persons, utility facilities, and affected property during the installation, operation, and maintenance of electric supply and communication facilities, under specified conditions.

NOTE: NESC rules are founded upon the fundamental principles used for safety of utility facilities, and the NESC is globally accepted as good engineering practice.

- B. NESC rules contain the basic provisions, under specified conditions, that are considered necessary for the safeguarding of:
 - 1. The public,
 - 2. Utility workers (employees and contractors),
 - 3. Utility facilities,
 - 4. Electric supply and communication equipment connected to utility facilities, and
 - 5. Other facilities or premises adjacent to or containing utility facilities.
- C. NESC rules are intended to provide a standard of safe practices that can be adopted by public utilities, private utilities, state or local utility commissions or public service commissions, or other boards or bodies having control over safe practices employed in the design, installation, operation, and maintenance of electric supply, communication, street and area lighting, signal, or railroad utility facilities.
- D. This Code is not intended as a design specification or as an instruction manual.

011. Scope

- A. Covered

See Figure 011-1.

The NESC covers:

- 1. Supply and communication facilities (including metering) and associated work practices employed by a public or private electric supply, communications, railway, trolley, street and area lighting, traffic signal (or other signal), irrigation district or other community owned utility, or a similar utility in the exercise of its function as a utility.
- 2. The generation, transmission, and distribution of electricity, lumens, communication signals, and communication data through public and private utility systems that are installed and maintained under the exclusive control of utilities or their authorized representatives.