

# IEEE Standard for Qualifying Class 1E Protective Relays and Auxiliaries for Nuclear Power Generating Stations

IEEE Power and Energy Society

Sponsored by the  
Power System Relaying Committee

---

IEEE  
3 Park Avenue  
New York, NY 10016-5997  
U.S.A.

**IEEE Std C37.105™-2010**  
(Revision of  
IEEE Std C37.105-1987)

29 October 2010

Currently in preview, click buy full version

# IEEE Standard for Qualifying Class 1E Protective Relays and Auxiliaries for Nuclear Power Generating Stations

Sponsor

**Power System Relaying Committee**  
of the  
**IEEE Power and Energy Society**

Approved 30 September 2010  
**IEEE-SA Standards Board**

**Abstract:** Basic principles, requirements, and methods for qualifying Class 1E protective relays and auxiliaries in nuclear power generating stations including digital and analog devices, but excluding devices located inside the primary containment, are covered.

**Keywords:** aging, auxiliaries, Class 1E, margin, nuclear, power plants, qualifying, radiation, relays, seismic, tests, thermal

The Institute of Electrical and Electronics Engineers, Inc.  
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2010 by the Institute of Electrical and Electronics Engineers, Inc.  
All rights reserved. Published 29 October 2010. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by the Institute of Electrical and Electronics Engineers, Incorporated.

**PDF:** ISBN 978-0-7381-6503-5      **STD97040**  
**Print:** ISBN 978-0-7381-6504-2      **STDPD97040**

*IEEE prohibits discrimination, harassment and bullying. For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>. No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.*

**IEEE Standards** documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. The IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While the IEEE administers the process and establishes rules to promote fairness in the consensus development process, the IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

Use of an IEEE Standard is wholly voluntary. The IEEE disclaims liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon this, or any other IEEE Standard document.

The IEEE does not warrant or represent the accuracy or content of the material contained herein, and expressly disclaims any express or implied warranty, including any implied warranty of merchantability or fitness for a specific purpose, or that the use of the material contained herein is free from patent infringement. IEEE Standards documents are supplied "AS IS."

The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation, or every ten years for stabilization. When a document is more than five years old and has not been reaffirmed, or more than ten years old and has not been stabilized, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

In publishing and making this document available, the IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Nor is the IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing this, and any other IEEE Standards document, should rely upon his or her independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

**Interpretations:** Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretation is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration. A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered the official position of IEEE or any of its committees and shall not be considered to be, nor be relied upon as, a formal interpretation of the IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position, explanation, or interpretation of the IEEE.

Comments for revision of IEEE standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Recommendations to change the status of a stabilized standard should include a rationale as to why revision or withdrawal is required. Comments and recommendations on standards, and requests for interpretation, should be addressed to:

Secretary, IEEE-SA Standards Board  
445 Hoes Lane  
Piscataway, NJ 08854  
USA

Authorization to photocopy portions of any individual standard for internal or personal use is granted by The Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

## Introduction

This introduction is not part of IEEE Std C37.105-2010, IEEE Standard for Qualifying Class 1E Protective Relays and Auxiliaries for Nuclear Power Generating Stations.

IEEE Std 323<sup>TMa</sup> provides general guidance for demonstrating and documenting the adequacy of electrical equipment used in all Class 1E and interface systems. This standard has been prepared to deal specifically with protective relays and auxiliary equipment, using IEEE Std 323 as the parent document for guidance. Relays and auxiliary equipment shall meet the applicable requirements of IEEE Std C37.90<sup>TM</sup>, IEEE Std C37.90.1<sup>TM</sup>, IEEE Std C37.90.2<sup>TM</sup>, and IEEE Std C37.90.3<sup>TM</sup>.

IEEE Std 7-4.3.2<sup>TM</sup> shall be used to address the use of Digital computer software and firmware used in all safety systems for nuclear generating stations. Safety systems equipment in nuclear power generating stations must meet or exceed its performance requirements throughout its installed life. This is accomplished by a program of design qualification and quality assurance of design, production, installation, maintenance and surveillance. This standard is for the design qualification portion of the program only.

The nuclear power generating station safety analysis, in part, considers the station and its safety system design in terms of a set of postulated service conditions. Inherent to each such analysis are two requirements that must be evaluated to assure overall technical validity. First, designs must be such that equipment is capable of actually performing designated safety functions in postulated service environments. Second, in service aging must not degrade safety systems equipment from its original design condition to the point where it cannot perform designated safety functions when required.

The special environmental stresses associated with some postulated service conditions promote the possibility that production testing, normal service testing, and surveillance may not be able to determine whether the equipment is vulnerable to failure, either as a result of inadequate design or aging. Under these circumstances, simultaneous failure of redundant safety equipment might occur just at the time safety functions are required. It is the fundamental role of qualification to provide reasonable assurance that design and age related common failure modes do not exist and that the equipment design is adequate to permit the equipment to perform its safety function during postulated service conditions.

Adherence to this standard alone may not suffice for assuring public health and safety since it is the integrated performance of the structures, fluid systems, instrumentation systems, and electric systems of the generating station that establishes safe operating conditions. The user has the responsibility to establish that this standard is pertinent to the particular requirements of the generating station of concern and that the integrated performance of the station is adequate.

IEEE Std C37.105 was issued in 1987 and reaffirmed in December 1999. This revision incorporates current nuclear industry practices for qualification of protective relays and auxiliaries.

## Notice to Users

### Law and regulations

Users of these documents should consult all applicable laws and regulations. Compliance with the provisions of this standard does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

<sup>a</sup> Information on references can be found in Clause 2.

## Copyrights

This document is copyrighted by the IEEE. It is made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making this document available for use and adoption by public authorities and private users, the IEEE does not waive any rights in copyright to this document.

## Updating of IEEE documents

Users of IEEE standards should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect. In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE Standards Association web site at <http://ieeexplore.ieee.org/xpl/standards.jsp>, or contact the IEEE at the address listed previously.

For more information about the IEEE Standards Association or the IEEE standard development process, visit the IEEE-SA web site at <http://standards.ieee.org>.

## Errata

Errata, if any, for this and all other standards can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/updates/errata/index.html>. Users are encouraged to check this URL for errata periodically.

## Interpretations

Current interpretations can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/interp/index.html>.

## Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patent Claims or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

## Participants

At the time this standard was submitted to the IEEE-SA Standards Board for approval, the I9 Working Group had the following membership:

**Roy Ball**, *Chair*  
**Sahib Usman**, *Vice Chair*

Mannu Bajpai  
Gustavo Brunello  
Jeff Burnworth

James D. Huddleston  
Steve Kunsman

Marie Nemier  
Mario M. Ranieri  
R. Vittal Rebbapragada

The following members of the individual balloting committee voted on this standard. Balloters may have voted for approval, disapproval, or abstention.

William Ackerman  
Munnu Bajpai  
Michael Baldwin  
Roy Ball  
Farouk Baxter  
Robert Beresh  
Wesley Bowers  
Daniel Brosnan  
Gustavo Brunello  
Jeff Burnworth  
John W. Chadwick, Jr.  
Garry Chapman  
Mason Clark  
R. Daubert  
Surin Dureja  
Matthew Davis  
Paul Drum

Doug Edwards  
Gary Engmann  
Rabiz Foda  
Jay Forster  
Frank Gerleve  
Britton Grim  
Roger Hedding  
Jerry Hohn  
James D. Huddleston  
Jose Jarque  
Joseph L. Koepfinger  
Steve Kunsman  
Jason Lin  
Albert Livshitz  
Gregory Luri  
Jesus Martinez  
Subino Mazumdar  
Jeffrey NeEla

Mark McGranaghan  
John Merado  
Gary M...  
Marie Nemier  
James Parelo  
Mario M. Ranieri  
R. Vittal Rebbapragada  
Mohindar S. Sachdev  
Tarlochan Sidhu  
H. Jin Sim  
James Stoner  
Shanmugan Thamilarasan  
Eric Udren  
Sahib Usman  
James Wilson  
Murty Yalla  
Karl Zimmerman

When the IEEE-SA Standards Board approved this amendment on 30 September 2010, it had the following membership:

**Robert M. Grow**, *Chair*  
**Richard H. Hulett**, *Vice Chair*  
**Steve M. Mills**, *Past Chair*  
**Judith Gorman**, *Secretary*

Karen Bartleson  
Victor Berman  
Ted Burse  
Clint Chaplin  
Andy Drozd  
Alexander Gelman  
Jim Hughes  
Young Kyun Kim

Joseph L. Koepfinger\*  
John Kulick  
David J. Law  
Hung Ling  
Oleg Logvinov  
Ted Olsen

Ronald C. Petersen  
Thomas Prevost  
Jon Walter Rosdahl  
Sam Sciacca  
Mike Seavey  
Curtis Siller  
Don Wright

\*Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Satish Aggarwal, *NRC Representative*  
Richard DeBlasio, *DOE Representative*  
Michael Janezic, *NIST Representative*

Catherine Berger  
*IEEE Standards Project Editor*

Matthew Coglia  
*IEEE Standards Program Manager, Technical Program Development*

## Contents

1. Overview .....	1
1.1 Scope .....	1
1.2 Purpose .....	2
2. Normative references .....	2
3. Definitions .....	3
4. Qualification requirements .....	3
5. Principles of qualification .....	3
5.1 Application to protective relays and auxiliaries .....	4
5.1.1 Identification of equipment and its application .....	6
5.1.2 Qualification program .....	8
5.2 Alternative methods .....	9
6. Qualification procedure .....	9
6.1 Testing alternative and test sequence .....	9
6.1.1 Inspection and baseline data measurement .....	9
6.1.2 Performance evaluation .....	10
6.1.3 Aging .....	10
6.1.3.1 Radiation aging tests .....	12
6.1.3.2 Operational aging test .....	12
6.1.3.3 Thermal aging tests .....	12
6.1.4 Seismic testing .....	13
6.1.5 Final operational test .....	13
6.2 Analysis alternative .....	13
6.2.1 Performance evaluation analysis .....	14
6.2.2 Aging analysis .....	14
6.2.2.1 Radiation aging analysis .....	14
6.2.2.2 Operational aging analysis .....	14
6.2.2.3 Thermal aging analysis .....	14
6.2.3 Seismic analysis .....	15
6.3 Electromechanical relays .....	15
6.4 Static relays .....	15
6.5 Microprocessor-based relays .....	15
6.6 Switches .....	15
6.6.1 Not applicable to switches .....	16
6.6.2 Applicable to switches .....	16
6.7 Auxiliary devices .....	16
6.8 Other events .....	16
6.9 Determination of qualification .....	16
6.9.1 Failure during qualification .....	16
7. Environmental conditions .....	17
8. Margins .....	17
9. Modifications .....	17
9.1 Modifications during qualification .....	17
9.2 Modifications after qualification .....	18
10. Documentation .....	18

10.1 General .....	18
10.2 Equipment qualification data .....	18
10.2.1 Service conditions .....	18
10.2.2 Specific feature(s) .....	18
10.2.3 Qualification plan .....	18
10.2.4 Test report .....	18
10.3 Supporting documentation .....	19
10.3.1 Operating experience data .....	19
10.3.2 Analysis .....	19
10.3.3 Extrapolation .....	19
Annex A (informative) Bibliography .....	20

# IEEE Standard for Qualifying Class 1E Protective Relays and Auxiliaries for Nuclear Power Generating Stations

*IMPORTANT NOTICE: This standard is not intended to ensure safety, security, health, or environmental protection. Implementers of the standard are responsible for determining appropriate safety, security, environmental, and health practices or regulatory requirements.*

*This IEEE document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.*

## 1. Overview

This standard describes the basic principles, requirements, and methods for qualifying Class 1E protective relays and auxiliaries for applications in nuclear power generating stations. When properly employed it can be used to demonstrate the design adequacy of such equipment under normal, abnormal, design basis event (DBE), and post-design basis event (post-DBE) conditions in accordance with IEEE Std 323<sup>TM</sup>.<sup>1</sup> Static relays that utilize analog and digital electronic components require additional considerations and applicable requirements of IEEE Std C37.90<sup>TM</sup>, IEEE Std C37.90.1<sup>TM</sup>, IEEE Std C37.90.2<sup>TM</sup>, and IEEE Std C37.90.3<sup>TM</sup>. Microprocessor-based relays may require additional consideration of software and firmware qualification to comply with the requirements of IEEE Std 7-4.3.2<sup>TM</sup>, IEEE Std 1012<sup>TM</sup>, and IEEE Std 1028<sup>TM</sup>.

The qualification procedure presented is generic in nature. Other methods may be used at the discretion of the qualifier, provided the basic precepts of IEEE Std 323 are satisfied.

### 1.1 Scope

This standard covers qualification of Class 1E protective relays and auxiliaries to be used outside the primary containment in the nuclear power generating stations. Protective relays and auxiliaries located inside the primary containment in a nuclear power generating station present special conditions beyond the scope of this document.

---

<sup>1</sup> Information on references can be found in Clause 2.