

**IEEE Std C37.118.1™-2011**

(Revision of  
IEEE Std C37.118™-2005)

# **IEEE Standard for Synchrophasor Measurements for Power Systems**

Sponsor

**Power System Relaying Committee  
of the  
IEEE Power & Energy Society**

Approved 7 December 2011

**IEEE-SA Standards Board**

Currently in preview, click buy full version

**Abstract:** Synchronized phasor (synchrophasor) measurements for power systems are presented. This standard defines synchrophasors, frequency, and rate of change of frequency (ROCOF) measurement under all operating conditions. It specifies methods for evaluating these measurements and requirements for compliance with the standard under both steady-state and dynamic conditions. Time tag and synchronization requirements are included. Performance requirements are confirmed with a reference model, provided in detail. This document defines a *phasor measurement unit* (PMU), which can be a stand-alone physical unit or a functional unit within another physical unit. This standard does not specify hardware, software, or a method for computing phasors, frequency, or ROCOF.

**Keywords:** data concentrator, DC, FE, frequency error, IEEE C37.118.1, IRIG-B, PDC, phasor, phasor measurement, phasor measurement unit, PMU, RFE, ROCOF, ROCOF error, synchronized phasor, synchrophasor, total vector error, TVE

---

The Institute of Electrical and Electronics Engineers, Inc.  
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2011 by the Institute of Electrical and Electronics Engineers, Inc.  
All rights reserved. Published 28 December 2011. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by the Institute of Electrical and Electronics Engineers, Incorporated.

PDF: ISBN 978-0-7381-6811-1 STD97167  
Print: ISBN 978-0-7381-6812-8 STDPD97167

IEEE prohibits discrimination, harassment and bullying. For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>.  
No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

**IEEE Standards** documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. The IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While the IEEE administers the process and establishes rules to promote fairness in the consensus development process, the IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

Use of an IEEE Standard is wholly voluntary. The IEEE disclaims liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon this, or any other IEEE Standard document.

The IEEE does not warrant or represent the accuracy or content of the material contained herein, and expressly disclaims any express or implied warranty, including any implied warranty of merchantability or fitness for a specific purpose, or that the use of the material contained herein is free from patent infringement. IEEE Standards documents are supplied "AS IS."

The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation, or every ten years for stabilization. When a document is more than five years old and has not been reaffirmed, or more than ten years old and has not been stabilized, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

In publishing and making this document available, the IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Nor is the IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing this, and any other IEEE Standards document, should rely upon his or her independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

**Interpretations:** Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretation is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration. A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered the official position of IEEE or any of its committees and shall not be considered to be, nor be relied upon as, a formal interpretation of the IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position, explanation, or interpretation of the IEEE.

Comments for revision of IEEE standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Recommendations to change the status of a stabilized standard should include a rationale as to why revision or withdrawal is required. Comments and recommendations on standards, and requests for interpretation, should be addressed to:

Secretary, IEEE-SA Standards Board  
445 Hoes Lane  
Piscataway, NJ 08854  
USA

Authorization to photocopy portions of any individual standard for internal or personal use is granted by The Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

## Introduction

This introduction is not part of IEEE Std C37.118.1-2011, IEEE Standard for Synchrophasor Measurements for Power Systems.

The original synchrophasor standard was IEEE Std 1344™-1995 [B5].<sup>a</sup> It was replaced by IEEE Std C37.118-2005 [B8]. This has now been split into two standards: IEEE Std 37.118.1-2011 (this standard), covering measurement provisions, and IEEE Std 37.118.2™-2011 [B9], covering data communication. Both standards contain the previous material with updates and additional provisions.

In this standard, additional clarification is provided for the phasor and synchronized phasor definitions. The concepts of total vector error (TVE) and compliance tests are retained and expanded, tests over temperature variation have been added, and dynamic performance tests have been introduced. In addition, limits and characteristics of frequency measurement and rate of change of frequency (ROCOF) measurements have been developed. Annex C includes a system model intended to verify the ability to implement the required performance measures. The model is meant as a reference benchmark only; it is assumed that many real implementations will surpass this model in performance.

Phasors are used in many protection and data acquisition functions. By referencing them to a common time base they become comparable over a wide area of measurement. A synchrophasor is a phasor value obtained from voltage or current waveforms and precisely referenced to a common time base. Simultaneous measurement sets derived from synchronized phasors provide a vastly improved method for tracking power system dynamic phenomena for improved power system monitoring, protection, operation, and control.

The intent of any instrument connected to the power grid is to monitor power system parameters. The intent of this standard is to describe and quantify the performance of the *phasor measurement unit* (PMU) instrument deployed to monitor the power grid. The PMU extracts the parameters magnitude, phase angle, frequency, and ROCOF from the signals appearing at its input terminals. These signals may be corrupted by harmonic content, noise, and changes in state caused by system loads, and control and protective actions. Some examples are harmonics introduced by large non-linear loads, step changes in phase introduced by switched reactive elements, and transient noise from arc furnaces. These artifacts complicate the process of measuring the generation and load characteristics at or near the system fundamental frequency.

The filtering associated with the computation of the synchrophasors rejects the undesirable signal components appearing at the PMU input within the limits provided by the filter attenuation. The frequency is computed as the first derivative of the synchrophasor phase angle, and ROCOF is computed as the second derivative of the same phase angle. These two quantities are less reliable measurements, particularly ROCOF, because they are more sensitive to undesirable components in the signal like harmonics, off-nominal components, or noise.

This standard presents a set of PMU performance requirements to ensure that compliant instruments will perform similarly when presented with this suite of test signals. The user shall be aware that in the presence of the previously mentioned undesirable components in the input signal, higher measurement errors could result. These errors may be substantial, particularly where higher order derivatives (such as ROCOF) are needed. Signal processing alternatives may be employed to reduce or eliminate these errors. They are difficult to implement in a real-time environment and could adversely affect the measurement latency or the synchrophasor measurement response time. Alternatives are neither described nor evaluated in this document.

<sup>a</sup>The numbers in brackets correspond to those of the bibliography in Annex A.

## Notice to users

### Laws and regulations

Users of these documents should consult all applicable laws and regulations. Compliance with the provisions of this standard does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

### Copyrights

This document is copyrighted by the IEEE. It is made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. In making this document available for use and adoption by public authorities and private users, the IEEE does not waive any rights in copyright to this document.

### Updating of IEEE documents

Users of IEEE standards should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect. In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE Standards Association web site at <http://ieeexplore.ieee.org/xpl/standards.jsp>, or contact the IEEE at the address listed previously.

For more information about the IEEE Standards Association or the IEEE standards development process, visit the IEEE-SA web site at <http://standards.ieee.org>.

### Errata

Errata, if any, for this and all other standards can be accessed at the following URL: <http://standards.ieee.org/findstds/errata/index.html>. Users are encouraged to check this URL for errata periodically.

### Interpretations

Current interpretations can be accessed at the following URL: <http://standards.ieee.org/findstds/interps/index.html>.

## Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

## Participants

At the time this standard was submitted to the IEEE-SA Standards Board for approval, the Synchrophasor Measurements for Power Systems Working Group had the following membership:

**Kenneth Martin**, *Chair*  
**Bogdan Kasztenny**, *Vice Chair*

Mark Adamiak  
Scott Anderson  
Galina Antonova  
Miroslav Begovic  
Gabriel Benmouyal  
Gustavo Brunello  
Bill Dickerson

Juan Gers  
Allen Goldstein  
Hank Hechun  
Yi Hu  
Mladen Kezunovic  
Harold Kirkham  
Jay Murphy

Krish Narendra  
Arun Phadke  
Tevfik Sezi  
Veselin Skendzic  
Jerry Stenbakken  
Eric Udren  
John Wang

The following members of the individual balloting committee voted on this standard. Balloters may have voted for approval, disapproval, or abstention.

William J. Ackerman  
Mark Adamiak  
Eric Allen  
M. Victoria Alonso  
Galina Antonova  
James Ariza  
Jack Arnold  
Ali Al Awazi  
David Bassett  
Philip Beaumont  
Kenneth Behrendt  
Oscar Bolado  
Gustavo Brunello  
Arvind K. Chaudhary  
Luis Coronado  
Randall Crellin  
Gary Donner  
Michael Dood  
Randall Dotson  
Gary Engmann  
Herbert Falk  
Fredric Friend  
Vasudev S. Gharpure  
Jeffrey Gilbert  
Mietek Glinkowski  
Jalal Gohari  
Allen Goldstein  
Roman Graf  
Stephen Grier  
Graham Groves

Roger Hedding  
Jerry Hohn  
C. Huntley  
Gerald Johnson  
Innocent Kamwa  
Bogdan Kasztenny  
Yuri Khersonsky  
James Kinney  
Joseph L. Koepfinger  
Jim Kulchisky  
Chung-Yiu Lam  
Raluca Lascu  
Kenneth Martin  
Pierre Maréchal  
John McDonald  
Michael McDonald  
Harish Mehta  
Gary Michel  
Adi Mulawarman  
Jerry Murphy  
R. Murphy  
Bruce Muschlitz  
Michael S. Newman  
Mohamed Omran  
Dean Ouellette  
Lorraine Padden  
Donald Parker  
Mark Peterson  
Robert Pettigrew  
Bruce Pickett

Sarmad Rahmatian  
Michael Roberts  
Charles Rogers  
Miriam Sanders  
Steven Sano  
Bartien Sayogo  
Thomas Schossig  
Robert Seitz  
Jose Antonio De La O Serna  
Gil Shultz  
Mark Simon  
Veselin Skendzic  
James Smith  
Jerry Smith  
Gary Stoedter  
Charles Sufana  
Richard Taylor  
William Taylor  
Demetrios Tziouvaras  
Joe Uchiyama  
Eric Udren  
John Vergis  
Ilia Voloh  
Roel Vries  
John Wang  
Kenneth White  
Thomas Wiedman  
Ray Young  
Jian Yu  
Sergio Zimath

When the IEEE-SA Standards Board approved this standard on 7 December 2011, it had the following membership:

**Richard H. Hulett**, *Chair*  
**John Kulick**, *Vice Chair*  
**Robert M. Grow**, *Past Chair*  
**Judith Gorman**, *Secretary*

Masayuki Ariyoshi  
William Bartley  
Ted Burse  
Clint Chaplin  
Wael Diab  
Jean-Philippe Faure  
Alexander Gelman  
Paul Houzé

Jim Hughes  
Joseph L. Koepfinger\*  
David J. Law  
Thomas Lee  
Hung Ling  
Oleg Logvinov  
Ted Olsen

Gary Robinson  
Jon Walter Rosdahl  
Sam Sciacca  
Mike Seavey  
Curtis Siller  
Phil Winston  
Howard L. Wolfman  
Don Wright

\*Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Satish K. Aggarwal, *NRC Representative*  
Richard DeBlasio, *DOE Representative*  
Michael Janezic, *NIST Representative*

Don Messina  
*IEEE Standards Program Manager, Document Development*

Soo H. Kim  
*IEEE Standards Project Manager*

## Contents

1. Overview .....	1
1.1 Scope .....	1
1.2 Purpose .....	1
1.3 General overview.....	2
1.4 Need for this standard.....	2
2. Normative references.....	3
3. Definitions, acronyms, and abbreviations .....	3
3.1 Definitions .....	3
3.2 Special terms.....	4
3.3 Acronyms and abbreviations .....	4
4. Synchrophasor measurement.....	5
4.1 Phasor definition.....	5
4.2 Synchrophasor definition.....	5
4.3 Measurement time synchronization .....	7
5. Synchrophasor measurement requirements and compliance verification .....	8
5.1 Synchrophasor estimation.....	8
5.2 Frequency and rate of change of frequency estimation .....	8
5.3 Measurement evaluation.....	9
5.4 Measurement reporting.....	10
5.5 Measurement compliance .....	12
Annex A (informative) Bibliography .....	24
Annex B (informative) Time tagging and dynamic response.....	25
Annex C (informative) Reference signal processing models .....	29
Annex D (informative) Time and synchronization communication .....	38
Annex E (informative) TVF evaluation and PMU testing.....	44
Annex F (informative) Generator voltage and power angle measurement.....	48

# IEEE Standard for Synchrophasor Measurements for Power Systems

**IMPORTANT NOTICE:** This standard is not intended to ensure safety, security, health, or environmental protection. Implementers of the standard are responsible for determining appropriate safety, security, environmental, and health practices or regulatory requirements.

This IEEE document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.

## 1. Overview

### 1.1 Scope

This standard is for synchronized phasor measurement systems in power systems. It defines a synchronized phasor (synchrophasor), frequency, and rate of change of frequency (ROCOF) measurements. It describes time tag and synchronization requirements for measurement of all three of these quantities. It specifies methods for evaluating these measurements and requirements for compliance with the standard under both static and dynamic conditions. It defines a *phasor measurement unit* (PMU), which can be a stand-alone physical unit or a functional unit within another physical unit. This standard does not specify hardware, software, or a method for computing phasors, frequency, or ROCOF.

### 1.2 Purpose

This standard defines synchronized phasor and frequency measurements in substations along with methods and requirements for measurement verification. Measurements compliant with the standard and taken at various locations in the power system can be readily and accurately combined for power system analysis and operations. Time tag and other essential associations are also described to facilitate communication and reliable data application. Communication and recording of phasor measurements are covered in other standards, such as the companion standard IEEE Std C37.118.2™-2011 [B9].<sup>1</sup>

---

<sup>1</sup> The numbers in brackets correspond to those of the bibliography in Annex A.

### 1.3 General overview

This standard covers synchronized phasor measurements used in electric power systems. It defines the measurement, provides methods of quantifying the measurements, defines performance tests, and specifies acceptable limits. The following clauses are provided:

- Clause 1 provides the scope and needs for the standard.
- Clause 2 references other standards that are related or may be useful in the study and application of this standard.
- Clause 3 defines terms and abbreviations found in this standard.
- Clause 4 defines the measurement.
- Clause 5 defines measurement requirements, a method of quantifying the measurement, a test method, and accuracy limits.

Six informative annexes are also provided to clarify the standard and give supporting information, as follows:

- Annex A is a bibliography.
- Annex B explores the effects of time tagging and transient response relevant to this measurement technique.
- Annex C provides the algorithms that were used to confirm the performance requirements.
- Annex D discusses time synchronization.
- Annex E explains the total vector error (TVE) concept of measurement quality and gives plots of error results.
- Annex F describes two methods that can be used for measuring the internal voltages and power angles of generators.

### 1.4 Need for this standard

The 2005 version of the standard, commonly followed by equipment manufacturers and system integrators, specifies the performance of phasor measurements only under steady-state conditions. Synchrophasor applications, particularly during severe system disturbances, will utilize dynamic synchronized measurements. This revision of the standard extends the synchrophasor definition and specifies measurement requirements and test conditions to include practical dynamic power system conditions.

The original synchrophasor standard, IEEE Std 1344<sup>TM</sup>-1995 [B5], and its successor, IEEE Std C37.118<sup>TM</sup>-2005 [B8], provide for reporting of system frequency and rate of change of system frequency. These quantities are not defined, however, and no measurement requirements are mandated.

This revision provides definition and measurement requirements for power system frequency and ROCOF under practical power system conditions. A number of issues in the standard have been identified that require clarification or modification. This revision also separates the measurement and communication subclauses of IEEE Std C37.118-2005 [B8] into individual standards. This simplifies widespread adoption and aids deployment by allowing freer use of other standards for synchrophasor communication.

## 2. Normative references

The following referenced documents are indispensable for the application of this document (i.e., they must be understood and used, so each referenced document is cited in text and its relationship to this document is explained). For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments or corrigenda) applies.

IEEE Std 754™-1985, IEEE Standard for Binary Floating-Point Arithmetic.<sup>2, 3</sup>

## 3. Definitions, acronyms, and abbreviations

For the purposes of this document, the following terms and definitions apply. The *IEEE Standards Dictionary: Glossary of Terms & Definitions* [B2] should be consulted for terms not defined in this clause.<sup>4</sup>

### 3.1 Definitions

**anti-aliasing:** The process of filtering a signal before sampling to remove components of that signal whose frequency is equal to or greater than the Nyquist frequency (one-half the sample rate). If not removed, these signal components would appear as a lower frequency component (an alias).

**Coordinated Universal Time (UTC):** (Initials are ordered based on French language.) The time of day at the Earth's prime meridian (0° longitude). It is distributed by various media, including the Global Positioning System (GPS) system.

**data concentrator (DC):** A device that combines data from several measurement devices.

**frequency error (FE):** The measure of error between the theoretical frequency and the measured frequency for the given instant of time.

**Global Positioning System (GPS):** A U.S. Department of Defense (DoD) navigation system that uses a constellation of 24 satellites broadcasting a precision signal for location and time synchronization. Basic time synchronization accuracy is  $\pm 0.2$  microseconds ( $\mu\text{s}$ ).

**IEEE floating point:** A 32-bit representation of a real number.

NOTE—This definition is in accordance with IEEE Std 754-1985.<sup>5</sup>

**leap second:** A positive or negative one-second adjustment to the Coordinated Universal Time (UTC) that keeps it close to mean solar time.

**Nyquist frequency:** A frequency that is one-half the sampling frequency of a discrete signal processing system.

**Nyquist rate:** A sampling rate that is twice the bandwidth of a band-limited signal. It is the minimum sample rate that will result in an alias-free representation of a signal. It must therefore be greater than twice the highest frequency component in the signal.

---

<sup>2</sup> IEEE publications are available from the Institute of Electrical and Electronics Engineers, 445 Hoes Lane, Piscataway, NJ 08854, USA (<http://standards.ieee.org>).

<sup>3</sup> The IEEE standards or products referred to in Clause 2 are trademarks owned by the Institute of Electrical and Electronics Engineers, Incorporated.

<sup>4</sup> The *IEEE Standards Dictionary: Glossary of Terms & Definitions* is available at <http://shop.ieee.org/>.

<sup>5</sup> Information on references can be found in Clause 2.