

IEEE Standard for DC (3200 V and below) Power Circuit Breakers Used in Enclosures

IEEE Power and Energy Society

Sponsored by the
Switchgear Committee

IEEE
3 Park Avenue
New York, NY 10016-5997
© SA

IEEE Std C37.14™-2015
(Revision of
IEEE Std C37.14-2002)

Currently in preview, click buy full version

IEEE Standard for DC (3200 V and below) Power Circuit Breakers Used in Enclosures

Sponsor

Switchgear Committee
of the
IEEE Power and Energy Society

Approved 26 March 2015

IEEE-SA Standards Board

Abstract: Enclosed dc power circuit breakers of the stationary or drawout 32 type of one- or two-pole construction with one or more rated maximum voltages of 300 V, 325 V, 33 600 V, 800 V, 1000 V, 1200 V, 1600 V, or 3200 V for applications on dc systems having nominal 34 voltages of 250 V, 275 V, 500 V, 750 V, 850 V, 1000 V, 1500 V, or 3000 V, with general-purpose, 35 high-speed, semi-high-speed and rectifier circuit breakers; manually or power-operated; and with 36 or without electromechanical or electronic trip devices are covered in this standard. Service conditions, ratings, 37 functional components, temperature limitations and classification of insulating materials, dielectric 38 withstand voltage requirements, test procedures, and application are dealt with in this standard.

Keywords: current-limiting, direct-acting trip, general purpose, high-speed, IEEE C37.14™, impulse trip device, mining duty, reverse-current trip device, semi-high-speed or rectifier circuit breaker

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2015 by The Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 3 June 2015. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by The Institute of Electrical and Electronics Engineers, Incorporated.

PDF: ISBN 978-0-7381-9711-1 STD20223
Print: ISBN 978-0-7381-9712-8 STDPD20223

IEEE prohibits discrimination, harassment, and bullying.

For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Important Notices and Disclaimers Concerning IEEE Standards Documents

IEEE documents are made available for use subject to important notices and legal disclaimers. These notices and disclaimers, or a reference to this page, appear in all standards and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Standards Documents.”

Notice and Disclaimer of Liability Concerning the Use of IEEE Standards Documents

IEEE Standards documents (standards, recommended practices, and guides), both full-use and trial-use, are developed within IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (“IEEE-SA”) Standards Board. IEEE (“the Institute”) develops its standards through a consensus development process, approved by the American National Standards Institute (“ANSI”), which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and participate without compensation from IEEE. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

IEEE does not warrant or represent the accuracy or content of the material contained in its standards, and expressly disclaims all warranties (express, implied and statutory) not included in this or any other document relating to the standard, including, but not limited to, the warranties of: merchantability; fitness for a particular purpose; non-infringement; and quality, accuracy, effectiveness, currency, or completeness of material. In addition, IEEE disclaims any and all conditions relating to: results; and workmanlike effort. IEEE standards documents are supplied “AS IS” and “WITH ALL FAULTS.”

Use of an IEEE standard is wholly voluntary. The existence of an IEEE standard does not imply that there are no other ways to produce, test, measure, purchase, make, or provide other goods and services related to the scope of the IEEE standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard.

In publishing and making its standards available, IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity nor is IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing any IEEE Standards document, should rely upon his or her own independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

IN NO EVENT SHALL IEEE BE LIABLE FOR ANY DIRECT, INDIRECT, INCIDENTAL, SPECIAL, EXEMPLARY, OR CONSEQUENTIAL DAMAGES (INCLUDING, BUT NOT LIMITED TO: PROCUREMENT OF SUBSTITUTE GOODS OR SERVICES; LOSS OF USE, DATA, OR PROFITS; OR BUSINESS INTERRUPTION) HOWEVER CAUSED AND ON ANY THEORY OF LIABILITY, WHETHER IN CONTRACT, STRICT LIABILITY, OR TORT (INCLUDING NEGLIGENCE OR OTHERWISE) ARISING IN ANY WAY OUT OF THE PUBLICATION, USE OF, OR RELIANCE UPON ANY STANDARD, EVEN IF ADVISED OF THE POSSIBILITY OF SUCH DAMAGE AND REGARDLESS OF WHETHER SUCH DAMAGE WAS FORESEEABLE.

Translations

The IEEE consensus development process involves the review of documents in English only. In the event that an IEEE standard is translated, only the English version published by IEEE should be considered the approved IEEE standard.

Official statements

A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered or inferred to be the official position of IEEE or any of its committees and shall not be considered to be, or be relied upon as, a formal position of IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position of IEEE.

Comments on standards

Comments for revision of IEEE Standards documents are welcome from any interested party, regardless of membership affiliation with IEEE. However, IEEE does not provide consulting information or advice pertaining to IEEE Standards documents. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Since IEEE standards represent a consensus of concerned interests, it is important that any responses to comments and questions also receive the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to comment or questions except in those cases where the matter has previously been addressed. For the same reason, IEEE does not respond to interpretation requests. Any person who would like to participate in revisions to an IEEE standard is welcome to join the relevant IEEE working group.

Comments on standards should be submitted to the following address:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
Piscataway, NJ 08854 USA

Laws and regulations

Users of IEEE Standards documents should consult all applicable laws and regulations. Compliance with the provisions of any IEEE Standards document does not imply compliance to any applicable regulatory requirements. Implementers of the standards are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

IEEE draft and approved standards are copyrighted by IEEE under U.S. and international copyright laws. They are made available by IEEE and are adopted for a wide variety of both public and private uses. These include both use by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making these documents available for use and adoption by public authorities and private users, IEEE does not waive any rights in copyright to the documents.

Photocopies

Subject to payment of the appropriate fee, IEEE will grant users a limited, non-exclusive license to photocopy portions of any individual standard for company or organizational internal use or individual, non-commercial use only. To arrange for payment of licensing fees, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Updating of IEEE Standards documents

Users of IEEE Standards documents should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect.

Every IEEE standard is subjected to review at least every ten years. When a document is more than ten years old and has not undergone a revision process, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE standard.

In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE-SA Website at <http://ieeexplore.ieee.org/xpl/standards.jsp> or contact IEEE at the address listed previously. For more information about the IEEE-SA or IEEE's standards development process, visit the IEEE-SA Website at <http://standards.ieee.org>.

Errata

Errata, if any, for all IEEE standards can be accessed on the IEEE-SA Website at the following URL: <http://standards.ieee.org/findstds/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken by the IEEE with respect to the existence or validity of any patent rights in connection therewith. If a patent holder or patent applicant has filed a statement of assurance via an Accepted Letter of Assurance, then the statement is listed on the IEEE-SA Website at <http://standards.ieee.org/about/sasb/patcom/patents.html>. Letters of Assurance may indicate whether the Submitter is willing or unwilling to grant licenses under patent rights without compensation or under reasonable rates, with reasonable terms and conditions that are demonstrably free of any unfair discrimination to applicants desiring to obtain such licenses.

Essential Patent Claims may exist for which a Letter of Assurance has not been received. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims, or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

Participants

At the time this IEEE standard was completed, the DC Circuit Breaker working group had the following membership:

Keith Flowers, *Chair*

David Dunne
Douglas J. Edwards
Brian Gerzeny
Lou Grahor
Jeffrey Hidaka
Dan Hrcncir
Anurag Jivanani

Harry Josten
Chad Kennedy
Michael Lafond
Jeffery Mizener
Darryl Moser
Paul Notarian

George Nourse
T. W. Olsen
Owen Parks
Richard Rohr
Mike Seabrook
John Shullaw
Michael D. Sigmon

The following members of the individual balloting committee voted on this standard. Balloters may have voted for approval, disapproval, or abstention.

Paul Barnhart
Robert Beavers
William Bloethe
Ted Burse
Eldridge Byron
Paul Cardinal
Gary Donner
Edgar Dullni
Douglas J. Edwards
Michael Flack
Keith Flowers
Paul Forquer
Frank Gerleve
Brian Gerzeny
Lou Grahor
Randall Groves
Ajit Gwal
Jeff Hanson

Thomas Hawkins
Dan Hrcncir
Anurag Jivanani
Andrew Jones
Harry Josten
Chad Kennedy
Yuri Khersonsky
Boris Kogan
Jim Kulchisky
Saumen Kundu
Chung-Yiu Lam
Albert Livshitz
William Mc Bride
Jeffery Mizener
Charles Moser
Michael Newman
George Nourse

T. W. Olsen
John Shullaw
Bartien Sayogo
Shawn Patterson
Julian Profir
Michael Roberts
Richard Rohr
Bartien Sayogo
Nikunj Shah
John Shullaw
Michael D. Sigmon
Jerry Smith
Ralph Stell
Marcelo Valdes
John Vergis
John Webb
Jian Yu
Matthew Zeedyk

When the IEEE-SA Standards Board approved this standard on 26 March 2015, it had the following membership:

John D. Kulick, *Chair*
Jon Walter Rosdahl, *Vice Chair*
Richard H. Hulett, *Past Chair*
Konstantinos Karachalios, *Secretary*

Masayuki Ariyoshi
Ted Burse
Stephen Dukes
Jean-Philippe Faure
J. Travis Griffith
Gary Hoffman
Michael Janezic
Joseph L. Keopfing

David J. Law
Hung Ling
Andrew Myles
T. W. Olsen
Glenn Parsons
Ronald C. Petersen
Annette D. Reilly

Stephen J. Shellhammer
Adrian P. Stephens
Yatin Trivedi
Philip Winston
Don Wright
Yu Yuan
Daidi Zhong

Michelle Turner
IEEE-SA Content Production and Management

Erin Spiewak
IEEE-SA Technical Program Operations

Introduction

This introduction is not part of IEEE Std C37.14™-2015, IEEE Standard for DC (3200 V and below) Power Circuit Breakers Used in Enclosures.

IEEE Std C37.14-1979 superseded IEEE Std C37.14-1969, and included recognition of the widespread use of solid-state rectifiers in industry, particularly for the traction power systems that evolved in the 1970s. It was based on known applications as well as considerations for future system development, with basic ratings and tests evolving from the classic mathematical solutions available at the time.

The revision working group for IEEE Std C37.14-1992 concluded that certain major changes were necessary. One of the changes made was the replacement of the 1200 V maximum design rating, with a new 1000 V rating. Dielectric withstand test voltages were correspondingly increased.

The revision working group maintained the peak-current multiplier of 1.65 times the sustained current, even though it can be shown that a multiplier of 1.42 can be utilized for 12-pulse rectifier designs. However, since the 6-pulse rectifier designs can produce the 1.65 peak, and because of known future applications with additional and/or replacement circuit breakers, it was preferred to maintain the 1.65 value.

Rated peak current was maintained as a rating because depending on the transformer/rectifier-design impedance coupled with the primary short-circuit current capacity and a low dc inductance, it may be possible to obtain a higher peak current and/or sustained current, depending on conditions. This design combination should be investigated to prevent inadvertent application of circuit breakers above their ratings.

Some considerations that were addressed in the IEEE Std C37.14-1992 revision are as follows:

- a) The need for lower rated circuit breakers for light-duty transit systems, which are generally 800 V catenary surface systems, was recognized. The power requirements are approximately one-half those of a heavy-duty transit system with the rectifier circuit breakers requiring maximum continuous current ratings of 4000 A and feeder circuit breakers with proportionately lower ratings. Tables 12 and 12A were replaced with a new Table 12 in ANSI C37.16a, which was revised to reflect a reduced base rating of 1000 A in order to provide a lower level of design rated circuit breakers, which allows the use of designs differing from those utilized for heavy-duty systems.
- b) The question of rectifier and feeder circuit breakers being rated identically was previously addressed in the IEEE Std C37.14-1979 appendix, but this was now recognized and addressed in the body of the standard. Specific installation applications normally differentiate rating requirements between rectifier and feeder circuit breakers in the reverse/forward-current tripping modes, as well as in the short-time/momentary rating modes. Therefore, it is important to recognize this difference in rating structure to provide for realistic design ratings and testing.
- c) The designs of high-speed and semi-high-speed circuit breakers with two different rating/test tables were conceptually reviewed, and recognition of actual field application conditions forced a concept change. A given track system should produce given short-circuit currents and circuit stored-energy at various locations regardless of circuit breaker type applied. Thus, there is a need for only two tables: one for low frequency, and one for high-frequency impedance bonds. Actually, the high-speed type circuit breaker is truly current-limiting by limiting let-through current to less than the available (prospective) peak in all cases. The semi-high-speed type is “semi-current-limiting,” limiting let-through current to less than the sustained current in all cases except in allowing the maximum peak current available to flow on low-inductance (close-in) faults.

IEEE Std C37.14-1999 reestablished the 1200 V maximum design rating, and removed the 1000 V maximum design rating, while keeping the increased dielectric withstand voltages. This change recognized the existence of installed 1200 V maximum design rated systems and also maintained a more uniform

division between steps of preferred maximum design ratings. IEEE Std C37.14-1999 also clarified endurance design test requirements in order to eliminate confusion on the number of electrical operations required. There is a specific requirement to perform one group of no less than 120 consecutive close-open operations during electrical endurance testing.

IEEE Std C37.14-2002 again reestablished the 1000 V maximum design rating, while also retaining the 1200 V rating, in order to recognize the recent development and use of 1000 V maximum-design rated circuit breakers. Corresponding changes were made by NEMA to Table 11 and Table 11A of ANSI C37.16-2000, which established the preferred ratings for low-voltage power circuit breakers. Dielectric withstand test voltages were also relaxed for the 800 V and 1000 V maximum design ratings so as to differentiate from the 1200 V rating.

Another consideration of IEEE Std C37.14-2002 was that any dc circuit breaker shall be capable of handling all short-circuit conditions based on the speed of operation, current interrupted, and circuit energy interrupted as verified by the short-circuit test “a,” test “b,” test “c,” and test “d” of Table 11, Table 11A, and Table 12 in ANSI C37.16-2000. It was noted for comparison that ac low-voltage power circuit breakers are required by ANSI C37.50-1989 to be tested in four (4) sequences for certification/conformance. Similar analysis of required testing resulted in the assignment of two (2) sequences in IEEE Std C37.14-1992 standard.

IEEE Std C37.14-2002 acknowledged that depending on transformer/rectifier design impedance coupled with primary short-circuit current capacity and a low dc inductance, it may be possible to obtain a higher peak current and/or sustained current under certain conditions. This design combination needs to be properly investigated and applied to prevent overrating of all circuit breakers that cannot be rated higher than the rated peak and sustained currents listed in the preferred rating tables in ANSI C37.16-2000.

The working group for the present revision undertook another significant evolution of this standard. Some of the most significant considerations were as follows:

- a) General-purpose dc ratings were capped at 325 V in previous editions. In recent years, many additional dc applications have risen for voltages between 325 V and 1500 V. This revision addresses these voltages, and associated requirements, which has resulted in a number of requirements throughout the document.
- b) The preferred ratings, as applicable to dc power circuit breakers, have been incorporated from IEEE Std C37.16™, as IEEE Std C37.16 will be withdrawn when IEEE Std C37.13™ and IEEE Std C37.14 have been revised to incorporate the information previously included within IEEE Std C37.16. This resulted in significant restructuring of the document:
 - 1) A new clause has been introduced with preferred frame sizes.
 - 2) Preferred ratings have been introduced to “Ratings,” eliminating the references to IEEE Std C37.16. This also led to the inclusion of requirements regarding control voltages.
 - 3) The application specific preferred ratings and test conditions have been added as additional annexes, with one annex for general-purpose, and an additional annex for high-speed, semi-high-speed, and rectifier circuit breakers for use in traction power applications.
 - 4) The preferred rating table describing the preferred overcurrent performance of high-speed, semi-high-speed, and rectifier circuit breakers for use in systems with high frequency bonds had initially been removed. High or low frequency bonds is not a rating, but an application condition, and therefore it was open-ended as to which table was to be used for conformance testing. The working group considered the low frequency bonding to be the worst case application, but due to the prevalence of circuit breakers qualified in accordance to the test circuits for high frequency bonding, both the low frequency bonding tables and the high frequency bonding tables were retained, with the additional marking requirement for inclusion of the test circuit’s load circuit time constant on the nameplate.

- c) Clarifications have been made with regard to required functional components. The most significant changes are:
 - 1) Dependent-manual operation has been removed as a preferred construction type based on working group concerns about testing (dependence of speed of operation) and because dependent-manual operation is inconsistent with general recommended safety practices.
 - 2) At the request of users, it is now required that for drawout circuit breakers, primary disconnect assemblies shall be located on the drawout (removable) element for inspection and maintenance purposes. This philosophy is consistent with the ac power circuit breakers described in IEEE Std C37.13.
 - 3) Requirements for bonding of metallic components that are intended to be grounded for operator safety conditions have been added. Consideration has been given for applications where the intended application may or may not actually be directly connected to ground.
- d) Requirements have been added for flame resistance, thermal characteristics, and tracking resistance of insulating materials both in contact and not in contact with primary voltage.
- e) With the increased application of solid state trip systems in dc applications, additional testing considerations were added for solid state trip systems. A new test sequence has been added for determining resistance to electromagnetic interference, and surge withstand capability.
- f) Qualification of accessory devices has been added in this version, including auxiliary switches and undervoltage trip devices.
- g) With consideration that many dc power circuit breakers are third party certified, and of customer requirements for product performance test data, a new clause has been added for production monitoring and product retest requirements.

This standard represents the standard practice in the United States for dc power circuit breakers. Molded-case circuit breakers are covered by other standards, but in some instances may be able to meet the requirements of this standard.

Presently, there are no IEC standards that fully apply to dc power circuit breakers. Several IEC standards apply in part to dc power circuit breakers:

- a) IEC 60947-2 [B3]^a applies to industrial circuit breakers with rated voltages which do not exceed 1000 vac or 1500 vdc.
- b) Circuit breakers for traction applications are addressed by two IEC standards: IEC 60077-3 [B2] (dc circuit breakers installed on motive power units), and IEC 61992-2 [B4] (dc circuit breakers installed in fixed locations).

^a The numbers in brackets correspond to those of the bibliography in Annex A.

Contents

1. Overview	1
1.1 Scope	1
1.2 Purpose	2
2. Normative references.....	2
3. Definitions	3
4. Service conditions	4
5. Frame size.....	4
5.1 General	4
5.2 General-purpose dc power circuit breakers	4
5.3 High-speed dc power circuit breakers	4
5.4 Rectifier dc power circuit breakers.....	4
5.5 Semi-high-speed dc power circuit breakers	5
6. Ratings.....	5
6.1 Rating information.....	5
6.2 Rated maximum voltage.....	5
6.3 Rated continuous current.....	5
6.4 Rated peak current.....	6
6.5 Rated short-time current.....	6
6.6 Rated short-circuit current.....	7
6.7 Rated control voltage.....	8
7. Functional components.....	9
7.1 General	9
7.2 Nameplate(s).....	10
7.3 Contact position indicator.....	10
7.4 Mechanical manual open and close buttons.....	10
7.5 Stored-energy indicator	11
7.6 Locking.....	11
7.7 Primary disconnecting devices	11
7.8 Circuit breaker bonding connection.....	11
8. Temperature limitations and classification of insulating materials	12
8.1 Temperature limits.....	12
8.2 Limits of observable temperature rise	12
8.3 Classification of insulating materials.....	13
9. Dielectric withstand voltage requirements	15
9.1 Test values	15
9.2 Test procedures.....	15
10. Design test requirements	16
10.1 General	16
10.2 Test conditions.....	16
10.3 Schedule of design tests.....	16
10.4 Trip device calibration check test.....	18
10.5 Dielectric withstand voltage test.....	19

10.6 Continuous current test.....	19
10.7 Short-time current test.....	22
10.8 Endurance tests.....	23
10.9 Peak current test.....	25
10.10 Short-circuit current tests.....	25
10.11 Load (low) current switching tests.....	28
10.12 Electromagnetic compatibility tests.....	28
11. Accessory device design tests.....	29
11.1 General.....	29
11.2 Alarm and auxiliary switches.....	29
11.3 Undervoltage trip devices.....	31
11.4 Other electrical accessories.....	32
11.5 Mechanical accessory devices.....	32
12. Treatment of failures within a design test sequence.....	32
12.1 General.....	32
13. Production tests.....	32
13.1 General.....	32
13.2 Calibration.....	33
13.3 Control, secondary wiring, and devices check test.....	34
13.4 Dielectric withstand voltage test.....	34
13.5 No-load operation tests.....	34
Annex A (informative) Bibliography.....	36
Annex B (normative) Preferred ratings and test circuit parameters for general-purpose dc power circuit breakers.....	37
Annex C (normative) Preferred ratings and test circuit parameters for high-speed, semi-high-speed, and rectifier dc power circuit breakers.....	43
Annex D (informative) Application guide.....	49
D.1 Overview.....	49
D.2 Voltage.....	49
D.3 Continuous current.....	49
D.4 Short-circuit current.....	50
D.5 Application of direct current instrument shunts.....	52
D.6 Limiting transient arc voltage.....	53
D.7 Application of circuit breakers for selective tripping.....	53
D.8 Application limitations relating to mechanism types.....	54
D.9 Service conditions affecting circuit breaker applications.....	55
D.10 Application of general-purpose dc power circuit breakers to motor starting and running duty.....	58
D.11 Repetitive duty operations and normal maintenance.....	58
D.12 Application of circuit breakers without enclosures.....	59
Annex E (informative) Traction power technical application guide.....	60
Annex F (informative) Production monitoring and product retest requirements.....	63
F.1 Overview.....	63
F.2 Production monitoring.....	63
F.3 Product retest requirements.....	63

IEEE Standard for DC (3200 V and below) Power Circuit Breakers Used in Enclosures

IMPORTANT NOTICE: IEEE Standards documents are not intended to ensure safety, security, health, or environmental protection, or ensure against interference with or from other devices or networks. Implementers of IEEE Standards documents are responsible for determining and complying with all appropriate safety, security, environmental, health, and interference protection practices and all applicable laws and regulations.

This IEEE document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.

1. Overview

1.1 Scope

This standard covers the following types, preferred ratings, and testing requirements of enclosed dc power circuit breakers:

- a) Stationary or drawout type of one- or two-pole functional construction
- b) Having rated maximum voltages of up to 3200 V
- c) Manually operated or power operated
- d) With or without overcurrent trip devices

NOTE—In this standard, the use of the term “circuit breaker” is considered to mean “enclosed dc power circuit breaker.”¹

¹ Notes in text, tables, and figures of a standard are given for information only, and do not contain requirements needed to implement the standard.