

# IEEE Guide for Seismic Qualification of Class 1E Metal-Enclosed Power Switchgear Assemblies

IEEE Power and Energy Society

Sponsored by the  
Switchgear Committee

---

IEEE  
3 Park Avenue  
New York, NY 10016-5997  
USA

**IEEE Std C37.81™-2017**  
(Revision of IEEE Std C37.81-1989)

# **IEEE Guide for Seismic Qualification of Class 1E Metal-Enclosed Power Switchgear Assemblies**

Sponsor

**Switchgear Committee**  
of the  
**IEEE Power and Energy Society**

Approved 23 March 2017

**IEEE-SA Standards Board**

Currently in preview, click buy full version

**Abstract:** Requirements and guidance for the seismic qualification of metal-enclosed power switchgear assemblies including switching, interrupting, control, instrumentation, metering, and protective and regulating devices mounted therein are provided in this guide. As used in this guide, the word switchgear shall mean metal-enclosed power switchgear assemblies with the requirements as defined in IEEE Std C37.20.1™, Standard for Metal-Enclosed Low-Voltage Power Circuit Breaker Switchgear, IEEE Std C37.20.2™, Standard for Metal-Clad Switchgear, and IEEE Std C37.20.3™, Standard for Metal-Enclosed Interrupter Switchgear. By definition, metal-enclosed power switchgear assemblies include metal-clad switchgear, metal-enclosed interrupter switchgear, and low-voltage power circuit breaker switchgear. Metal-enclosed bus or control switchboards are not covered in this guide.

**Keywords:** class 1E metal-enclosed power switchgear assemblies, generic response spectrum (GRS), IEEE C37.81™, performance requirements, seismic criteria

---

The Institute of Electrical and Electronics Engineers, Inc.  
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2017 by The Institute of Electrical and Electronics Engineers, Inc.  
All rights reserved. Published 19 June 2017. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by The Institute of Electrical and Electronics Engineers, Incorporated.

PDF: ISBN 978-1-5044-4059-2 STD22610  
Print: ISBN 978-1-5044-4060-8 STDPD22610

*IEEE prohibits discrimination, harassment, and bullying.*

For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

## Important Notices and Disclaimers Concerning IEEE Standards Documents

IEEE documents are made available for use subject to important notices and legal disclaimers. These notices and disclaimers, or a reference to this page, appear in all standards and may be found under the heading “Important Notices and Disclaimers Concerning IEEE Standards Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.

### Notice and Disclaimer of Liability Concerning the Use of IEEE Standards Documents

IEEE Standards documents (standards, recommended practices, and guides), both full-use and trial-use, are developed within IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (“IEEE-SA”) Standards Board. IEEE (“the Institute”) develops its standards through a consensus development process, approved by the American National Standards Institute (“ANSI”), which brings together volunteers representing varied viewpoints and interests to achieve the final product. IEEE Standards are documents developed through scientific, academic, and industry-based technical working groups. Volunteers in IEEE working groups are not necessarily members of the Institute and participate without compensation from IEEE. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

IEEE Standards do not guarantee or ensure safety, security, health, or environmental protection, or ensure against interference with or from other devices or networks. Implementers and users of IEEE Standards documents are responsible for determining and complying with all appropriate safety, security, environmental, health, and interference protection practices and all applicable laws and regulations.

IEEE does not warrant or represent the accuracy or content of the material contained in its standards, and expressly disclaims all warranties (express, implied and statutory) not included in this or any other document relating to the standard, including, but not limited to, the warranties of: merchantability; fitness for a particular purpose; non-infringement; and quality, accuracy, effectiveness, currency, or completeness of material. In addition, IEEE disclaims any and all conditions relating to: results; and workmanlike effort. IEEE standards documents are supplied “AS IS” and “WITH ALL FAULTS.”

Use of an IEEE standard is wholly voluntary. The existence of an IEEE standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change from time to time about through developments in the state of the art and comments received from users of the standard.

In publishing and making its standards available, IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity nor is IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing any IEEE Standards document, should rely upon his or her own independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

IN NO EVENT SHALL IEEE BE LIABLE FOR ANY DIRECT, INDIRECT, INCIDENTAL, SPECIAL, EXEMPLARY, OR CONSEQUENTIAL DAMAGES (INCLUDING, BUT NOT LIMITED TO: PROCUREMENT OF SUBSTITUTE GOODS OR SERVICES; LOSS OF USE, DATA, OR PROFITS; OR BUSINESS INTERRUPTION) HOWEVER CAUSED AND ON ANY THEORY OF LIABILITY, WHETHER IN CONTRACT, STRICT LIABILITY, OR TORT (INCLUDING NEGLIGENCE OR OTHERWISE) ARISING IN ANY WAY OUT OF THE PUBLICATION, USE OF, OR RELIANCE UPON ANY STANDARD, EVEN IF ADVISED OF THE POSSIBILITY OF SUCH DAMAGE AND REGARDLESS OF WHETHER SUCH DAMAGE WAS FORESEEABLE.

## Translations

The IEEE consensus development process involves the review of documents in English only. In the event that an IEEE standard is translated, only the English version published by IEEE should be considered the approved IEEE standard.

## Official statements

A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered or inferred to be the official position of IEEE or any of its committees and shall not be considered to be, or be relied upon as, a formal position of IEEE. At lectures, symposia, seminars, conferences, and educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position of IEEE.

## Comments on standards

Comments for revision of IEEE Standards documents are welcome from any interested party, regardless of membership affiliation with IEEE. However, IEEE does not provide consulting information or advice pertaining to IEEE Standards documents. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Since IEEE standards represent a consensus of concerned interests, it is important that any responses to comments and questions also receive the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to comments or questions except in those cases where the matter has previously been addressed. For the same reason, IEEE does not respond to interpretation requests. Any person who would like to participate in revisions to an IEEE standard is welcome to join the relevant IEEE working group.

Comments on standards should be submitted to the following address:

Secretary, IEEE-SA Standards Board  
445 Hoes Lane  
Piscataway, NJ 08854 USA

## Laws and regulations

Users of IEEE Standards documents should consult all applicable laws and regulations. Compliance with the provisions of any IEEE Standards document does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

## Copyrights

IEEE draft and approved standards are copyrighted by IEEE under US and international copyright laws. They are made available by IEEE and are adopted for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making these documents available for use and adoption by public authorities and private users, IEEE does not waive any rights in copyright to the documents.

## Photocopies

Subject to payment of the appropriate fee, IEEE will grant users a limited, non-exclusive license to photocopy portions of any individual standard for company or organizational internal use or individual, non-commercial use only. To arrange for payment of licensing fees, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

## Updating of IEEE Standards documents

Users of IEEE Standards documents should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect.

Every IEEE standard is subjected to review at least every 10 years. When a document is more than 10 years old and has not undergone a revision process, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE standard.

In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE Explore at <http://ieeexplore.ieee.org/> or contact IEEE at the address listed previously. For more information about the IEEE-SA or IEEE's standards development process, visit the IEEE-SA Website at <http://standards.ieee.org>.

## Errata

Errata, if any, for all IEEE standards can be accessed on the IEEE-SA Website at the following URL: <http://standards.ieee.org/findstds/errata/index.html>. Users are encouraged to check this URL for errata periodically.

## Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken by the IEEE with respect to the existence or validity of any patent rights in connection therewith. If a patent holder or patent applicant has filed a statement of assurance via an Accepted Letter of Assurance, then the statement is listed on the IEEE-SA Website at <http://standards.ieee.org/about/sasb/patcom/patents.html>. Letters of Assurance may indicate whether the Submitter is willing or unwilling to grant licenses under patent rights without compensation or under reasonable rates, with reasonable terms and conditions that are demonstrably free of any unfair discrimination to applicants desiring to obtain such licenses.

Essential Patent Claims may exist for which a Letter of Assurance has not been received. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patent Claims, or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

## Participants

At the time this IEEE guide was completed, the SASC - IEEE Guide for Seismic Qualification of Class 1E Metal-Enclosed Power Switchgear Assemblies Working Group had the following membership:

**Dave Riffe, *Chair***

Larry Connor

Michael Flack  
Amy Rowell

Terrance Woodyard

The following members of the individual balloting committee voted on this guide. Balloters may have voted for approval, disapproval, or abstention.

Satish K. Aggarwal  
Jean-Marc Biasse  
William Bloethe  
Gustavo Brunello  
Paul Cardinal  
Suresh Channarasappa  
Gary Donner  
Edgar Dullni  
Jerry Earl  
Doug Edwards  
Michael Flack  
Sergio Flores  
Lou Grahor

Randall Groves  
Thomas Hawkins  
Hamidreza Heidarisafa  
Jeffrey Hoelzl  
Richard Jackson  
Boris Kogan  
Jim Kulchisky  
Chung-Yiu Lam  
Albert Livshitz  
Jeffrey Mizener  
Charles Morse  
Darryl Moser

Ryan Musgrove  
Michael Newmar  
T.W. Olsen  
Lorraine Padgett  
Bansi Patel  
K. James Phillips  
Bartley Snyogo  
Jerry Smith  
John Taylor  
John Vergis  
John Webb  
Terrance Woodyard  
Yaowu Zhan

When the IEEE-SA Standards Board approved this guide on 23 March 2017, it had the following membership:

**Jean-Philippe Faure, *Chair***

**Gary Hoffman, *Vice Chair***

**John D. Kulick, *Past Chair***

**Konstantinos Karachalios, *Secretary***

Chuck Adams  
Masayuki Ariyoshi  
Ted Burse  
Stephen Dukes  
Doug Edwards  
J. Travis Griffith  
Michael Janezic

Thomas Koshy  
Joseph L. Koepfinger\*  
Kevin Lu  
Daleep Mohla  
Damir Novosel  
Ronald C. Peterson  
Annette D. Reilly

Robby Robson  
Dorothy Stanley  
Adrian Stephens  
Mehmet Ulema  
Phil Wenblom  
Howard Wolfman  
Yu Yuan

\*Member Emeritus

## Introduction

This introduction is not part of IEEE Std IEEE Std C37.81–2017, IEEE Guide for Seismic Qualification of Class 1E Metal-Enclosed Power Switchgear Assemblies.

This guide complements IEEE Std 344™, Standard for Seismic Qualification of Equipment for Nuclear Power Generating Stations by providing specific requirements and guidance for seismic qualification of metal-enclosed power switchgear assemblies.<sup>1</sup>

Changes include IEEE Std C37.81 include the following:

- a) Added definitions and guidance for Seismic Category I and Seismic Category II equipment. Seismic Category I equipment is equivalent to equipment defined as Class 1E in the previous revision.
- b) Added guidance on sites with high frequency content, including a fourth Generic Response Spectra (GRS).
- c) Added definitions for functional failure, structural damage and triaxial test
- d) Revised the definitions for:
  - 1) Biaxial test
  - 2) Malfunction

Metal-enclosed power switchgear assemblies fall into the category of complex devices as described in IEEE Std 344; therefore, basic seismic qualification is dependent upon test data. Analysis may be used in data reduction, reconciling response spectra, and evaluating change. A method of combined test and analysis may also be used in justifying seismic qualification of similar equipment to the tested samples.

It should be noted that while the primary purpose of this guide is for the application of metal-enclosed power switchgear assemblies in nuclear power generating stations, it is not restricted to this application. This guide may also be used as a guide in other applications in which the seismic response of metal-enclosed power switchgear assemblies is a consideration.

<sup>1</sup>Information on references can be found in [Clause 2](#).

## Contents

1. Overview.....	9
1.1 Scope.....	9
2. Normative references .....	10
3. Definitions.....	10
4. Seismic criteria.....	11
4.1 General .....	11
4.2 Proof testing .....	12
4.3 Generic testing.....	12
4.4 Information furnished by the user.....	14
5. Performance requirements .....	15
5.1 General .....	15
5.2 Functional performance criteria .....	15
5.3 Operational performance criteria.....	16
5.4 Structural performance criteria.....	16
5.5 Demonstration of adequacy .....	17
6. Qualification methods .....	17
6.1 Analysis .....	17
6.2 Testing .....	17
6.3 Combined test and analysis .....	17
6.4 Experience.....	17
7. Testing and results .....	17
7.1 Introduction .....	17
7.2 Selection and test setup.....	18
7.3 Resonance search procedure.....	18
7.4 Seismic test input.....	19
7.5 Number and duration of tests .....	19
7.6 Tests and measurements before seismic tests.....	19
7.7 Tests and measurements during seismic tests .....	19
7.8 Tests and measurements after seismic tests.....	21
7.9 Refurbishment, maintenance, and repairs during testing .....	21
8. Combined analysis and testing .....	22
8.1 Introduction.....	22
8.2 Analysis .....	22
8.3 Test procedure .....	23
8.4 Qualifying the complete assembly.....	23
9. Extrapolation for similar equipment.....	24
10. Documentation .....	24
10.1 General .....	24
10.2 Test qualification report .....	24
10.3 Combined analysis and test qualification report .....	25
10.4 Documentation for qualification by extrapolation .....	26

# IEEE Guide for Seismic Qualification of Class 1E Metal-Enclosed Power Switchgear Assemblies

## 1. Overview

### 1.1 Scope

This guide provides requirements and guidance for the seismic qualification of metal-enclosed power switchgear assemblies including switching, interrupting, control, instrumentation, metering, and protective and regulating devices mounted therein.

This guide may be used by equipment manufacturers to establish procedures that will yield data to substantiate performance or by equipment users to evaluate and verify performance of representative devices and assemblies as part of an overall qualification effort.

As used in this guide, the word switchgear shall mean metal-enclosed power switchgear assemblies with the requirements as defined in IEEE Std C37.20.1<sup>1</sup>, IEEE Std C37.20.2<sup>2</sup>, IEEE and Std C37.20.3<sup>2,3,4</sup>. By definition, metal-enclosed power switchgear assemblies include metal-clad switchgear, metal-enclosed interrupter switchgear, and low-voltage power circuit breaker switchgear. This guide does not cover metal-enclosed bus or control switchboards.

Metal-enclosed power switchgear assemblies fall into the category of complex devices as described in IEEE Std 344<sup>5</sup>. Therefore, seismic qualification is dependent on test data. Switchgear assemblies have many different types and arrangements of devices and components. It is neither practical nor necessary to test each unique configuration of devices and components, nor is it necessary to test a given configuration for every possible seismic environment. However, it is essential that each switchgear assembly used in Seismic Category I and Seismic Category II applications be seismically qualified for its environment, and Seismic Category I qualification must be based on data obtained by test. Analysis may be used in data reduction, reconciling response spectra, evaluation of changes and Seismic Category II qualification.

A method of combined test and analysis may also be used in justifying seismic qualification of equipment similar to the tested sample. A combination of testing and analysis may also be used to justify the seismic qualification of equipment with removable elements and drawout-mounted devices in various positions (connect, test, disconnect, and removed).

<sup>1</sup>IEEE publications are available from the Institute of Electrical and Electronics Engineers (<http://standards.ieee.org>).

<sup>2</sup>The IEEE standards or products referred to in this clause are trademarks of the Institute of Electrical and Electronics Engineers, Inc.

<sup>4</sup>Information on references can be found in [Clause 2](#).