

# IEEE Guide for Acceptance and Maintenance of Natural Ester Insulating Liquid in Transformers

IEEE Power and Energy Society

Sponsored by the  
Transformers Committee

---

IEEE  
3 Park Avenue  
New York, NY 10016-5997  
USA

**IEEE Std C57.147™-2018**  
(Revision of IEEE Std C57.147-2008)

# **IEEE Guide for Acceptance and Maintenance of Natural Ester Insulating Liquid in Transformers**

Sponsor

**Transformers Committee**  
of the  
**IEEE Power and Energy Society**

Approved 15 February 2018

**IEEE-SA Standards Board**

Currently in preview, click buy full version

**Abstract:** Assistance to equipment manufacturers and service companies to evaluate the suitability of unused natural ester insulating liquids being received from suppliers is provided in this guide. Information for transformer operators in evaluating and maintaining natural ester insulating liquids in serviceable condition is also provided.

**Keywords:** dielectric coolant, high fire point liquid, IEEE C57.147™, insulating liquid, less-flammable liquid, natural ester liquid, transformer, vegetable oil

---

The Institute of Electrical and Electronics Engineers, Inc.  
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2018 by The Institute of Electrical and Electronics Engineers, Inc.  
All rights reserved. Published 19 July 2018. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by The Institute of Electrical and Electronics Engineers, Incorporated.

PDF: ISBN 978-1-5044-4919-9 STD23135  
Print: ISBN 978-1-5044-4920-5 STDPD23135

*IEEE prohibits discrimination, harassment, and bullying.*

For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

## Important Notices and Disclaimers Concerning IEEE Standards Documents

IEEE documents are made available for use subject to important notices and legal disclaimers. These notices and disclaimers, or a reference to this page, appear in all standards and may be found under the heading “Important Notices and Disclaimers Concerning IEEE Standards Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.

### Notice and Disclaimer of Liability Concerning the Use of IEEE Standards Documents

IEEE Standards documents (standards, recommended practices, and guides), both full-use and trial-use, are developed within IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (“IEEE-SA”) Standards Board. IEEE (“the Institute”) develops its standards through a consensus development process, approved by the American National Standards Institute (“ANSI”), which brings together volunteers representing varied viewpoints and interests to achieve the final product. IEEE Standards are documents developed through scientific, academic, and industry-based technical working groups. Volunteers in IEEE working groups are not necessarily members of the Institute and participate without compensation from IEEE. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

IEEE Standards do not guarantee or ensure safety, security, health, or environmental protection, or ensure against interference with or from other devices or networks. Implementers and users of IEEE Standards documents are responsible for determining and complying with all appropriate safety, security, environmental, health, and interference protection practices and all applicable laws and regulations.

IEEE does not warrant or represent the accuracy or content of the material contained in its standards, and expressly disclaims all warranties (express, implied and statutory) not included in this or any other document relating to the standard, including, but not limited to, the warranties of: merchantability; fitness for a particular purpose; non-infringement; and quality, accuracy, effectiveness, currency, or completeness of material. In addition, IEEE disclaims any and all conditions relating to: results; and workmanlike effort. IEEE standards documents are supplied “AS IS” and “WITH ALL FAULTS.”

Use of an IEEE standard is wholly voluntary. The existence of an IEEE standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change from time to time about through developments in the state of the art and comments received from users of the standard.

In publishing and making its standards available, IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity nor is IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing any IEEE Standards document, should rely upon his or her own independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

IN NO EVENT SHALL IEEE BE LIABLE FOR ANY DIRECT, INDIRECT, INCIDENTAL, SPECIAL, EXEMPLARY, OR CONSEQUENTIAL DAMAGES (INCLUDING, BUT NOT LIMITED TO: PROCUREMENT OF SUBSTITUTE GOODS OR SERVICES; LOSS OF USE, DATA, OR PROFITS; OR BUSINESS INTERRUPTION) HOWEVER CAUSED AND ON ANY THEORY OF LIABILITY, WHETHER IN CONTRACT, STRICT LIABILITY, OR TORT (INCLUDING NEGLIGENCE OR OTHERWISE) ARISING IN ANY WAY OUT OF THE PUBLICATION, USE OF, OR RELIANCE UPON ANY STANDARD, EVEN IF ADVISED OF THE POSSIBILITY OF SUCH DAMAGE AND REGARDLESS OF WHETHER SUCH DAMAGE WAS FORESEEABLE.

## Translations

The IEEE consensus development process involves the review of documents in English only. In the event that an IEEE standard is translated, only the English version published by IEEE should be considered the approved IEEE standard.

## Official statements

A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered or inferred to be the official position of IEEE or any of its committees and shall not be considered to be, or be relied upon as, a formal position of IEEE. At lectures, symposia, seminars, and educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position of IEEE.

## Comments on standards

Comments for revision of IEEE Standards documents are welcome from any interested party, regardless of membership affiliation with IEEE. However, IEEE does not provide consulting information or advice pertaining to IEEE Standards documents. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Since IEEE standards represent a consensus of concerned interests, it is important that any responses to comments and questions also receive the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to comments or questions except in those cases where the matter has previously been addressed. For the same reason, IEEE does not respond to interpretation requests. Any person who would like to participate in revisions to an IEEE standard is welcome to join the relevant IEEE working group.

Comments on standards should be submitted to the following address:

Secretary, IEEE-SA Standards Board  
445 Hoes Lane  
Piscataway, NJ 08854 U.S.A.

## Laws and regulations

Users of IEEE Standards documents should consult all applicable laws and regulations. Compliance with the provisions of any IEEE Standards document does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

## Copyrights

IEEE draft and approved standards are copyrighted by IEEE under U.S. and international copyright laws. They are made available by IEEE and are adopted for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making these documents available for use and adoption by public authorities and private users, IEEE does not waive any rights in copyright to the documents.

## Photocopies

Subject to payment of the appropriate fee, IEEE will grant users a limited, non-exclusive license to photocopy portions of any individual standard for company or organizational internal use or individual, non-commercial use only. To arrange for payment of licensing fees, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

## Updating of IEEE Standards documents

Users of IEEE Standards documents should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. A current IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect.

Every IEEE standard is subjected to review at least every 10 years. When a document is more than 10 years old and has not undergone a revision process, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE standard.

In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE Explorer at <http://ieeexplore.ieee.org/> or contact IEEE at the address listed previously. For more information about the IEEE-SA or IEEE's standards development process, visit the IEEE-SA Website at <http://standards.ieee.org>.

## Errata

Errata, if any, for all IEEE standards can be accessed on the IEEE-SA Website at the following URL: <http://standards.ieee.org/findstds/errata/index.html>. Users are encouraged to check this URL for errata periodically.

## Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken by the IEEE with respect to the existence or validity of any patent rights in connection therewith. If a patent holder or patent applicant has filed a statement of assurance via an Accepted Letter of Assurance, then the statement is listed on the IEEE-SA Website at <http://standards.ieee.org/about/sasb/patcom/patents.html>. Letters of Assurance may indicate whether the Submitter is willing or unwilling to grant licenses under patent rights without compensation or under reasonable rates, with reasonable terms and conditions that are demonstrably free of any unfair discrimination to applicants desiring to obtain such licenses.

Essential Patent Claims may exist for which a Letter of Assurance has not been received. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patent Claims, or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

## Participants

At the time this IEEE guide was completed, the Natural Ester Fluids Working Group had the following membership:

**C. Patrick McShane, *Chair***  
**C. Clair Claiborne, *Vice Chair***  
**James Graham, *Secretary***

Roberto Asano  
Derek Baranowski  
Claude Beauchemin  
Julio Caldeira  
Juan Castellanos  
Luis Cheim  
Donald Cherry  
Jermaine Clonts  
Valery Davydov  
Stephanie Denzer

George Frimpong  
Rainer Frotscher  
Eduardo Garcia  
James Gardner  
David Hanson  
Jesse Inkpen  
Gael Kennedy  
Robert Kinner  
Libin Mao  
Susan McNelly

Vinay Mehrota  
Nicholas Perjanik  
Jimmy Rasco  
Scott Reed  
Gregory Stem  
Craig Stiegemeier  
Roger Wicks  
Deanna Woods

The following members of the individual balloting committee voted on this guide. Balloters may have voted for approval, disapproval, or abstention.

Donald Ayers  
Peter Balma  
Thomas Barnes  
Barry Beaster  
Enrique Betancourt  
Wallace Binder  
Thomas Bishop  
Thomas Blackburn  
William Bloethe  
W. Boettger  
Paul Boman  
Stephan Brauer  
Paul Cardinal  
Juan Castellanos  
Donald Cherry  
C. Clair Claiborne  
John Crouse  
Willaim Darovny  
Dieter Dohnal  
Gary Donner  
Don Duchesne  
Donald Dunn  
Jorge Fernandez Daher  
Joseph Foidi  
Bruce Forsyth  
Michael Francheck  
Frederic Friend  
George Frimpong  
Ramsis Girgis  
James Graham  
William Griesacker  
Randall Groves  
Ajit Gwal  
Attila Gyore

John Harley  
Roger Hayes  
Werner Hoelzl  
Gary Hoffman  
Jill Holmes  
Hali Jackson  
Richard Jackson  
John Johnson  
Laszlo Kollar  
Gael Kennedy  
Donald Kennedy  
Gar King  
James Kinney  
Zan Kiparizoski  
Axel Kraemer  
Krzysztof Kulasek  
Jim Kulchisky  
John Lackey  
Benjamin Lanz  
Thomas La Rose  
Aleksandr Levin  
Thomas Lundquist  
Richard Marek  
J. Dennis Marlow  
Omar Mazzoni  
William McDermid  
Mark McNally  
Susan McNelly  
C. Patrick McShane  
C. Michael Miller  
Daleep Mohla  
Charles Morgan  
Daniel Mulkey  
Jerry Murphy

Ryan Musgrove  
Ali Naderian Jahromi  
K. R. M. Nair  
Michael Newman  
Joe Nims  
Lorraine Padden  
Dwight Parkinson  
Luke Parthemore  
Bansi Patel  
George Payerle  
Brian Penny  
Howard Penrose  
Branimir Petosic  
Christopher Petrola  
Alvaro Portillo  
Kevin Rapp  
Jimmy Rasco  
Robert Razor  
Jean-Christophe Riboud  
John Roach  
Oleg Roizman  
Zoltan Roman  
Thomas Rozek  
Daniel Sauer  
Bartien Sayogo  
Stephen Shull  
Hyeong Sim  
Richard Simonelli  
Jeremy Smith  
David Stankes  
Juan Thierry  
James Thompson  
Roger Verdolin  
John Vergis

Jane Verner  
Sukhdev Walia  
David Wallach

Joe Watson  
Lee Welch  
Kenneth White

Roger Wicks  
Deanna Woods  
Jennifer Yu

When the IEEE-SA Standards Board approved this guide on 15 February 2018, it had the following membership:

**Jean-Philippe Faure**, *Chair*  
**Vacant Position**, *Vice Chair*  
**John D. Kulick**, *Past Chair*  
**Konstantinos Karachalios**, *Secretary*

Ted Burse  
Guido R. Hiertz  
Christel Hunter  
Joseph L. Koepfinger\*  
Thomas Koshy  
Hung Ling  
Dong Liu

Xiaohui Liu  
Kevin Lu  
Daleep Mohla  
Andrew Myles  
Paul Nikolich  
Ronald C. Petersen  
Annette D. Reilly

Robby Robson  
Dorothy Stanley  
Mehmet Ulema  
Phil Wennblom  
Philip Winston  
Howard Wolfman  
Jingyi Zhou

\*Member Emeritus

## Introduction

This introduction is not part of IEEE Std C57.147-2018, IEEE Guide for Acceptance and Maintenance of Natural Ester Insulating Liquid in Transformers.

This guide was prepared by the Insulating Fluids Subcommittee of the Transformers Committee of the IEEE Power and Energy Society. The purpose of this guide is to identify standards for acceptance and maintenance of natural ester insulating liquid in transformers. This guide is the first revision of the initial guide published in 2008. Overall, the guide was substantially updated to include the current state of the art for natural ester insulating liquids.

This revision includes updates to follow the current IEEE SA policies, style, and terms appropriate for a Guide. In this revision, where appropriate, the term “fluid” has been replaced with “liquid” to be more descriptive of the application and for consistency of terminology within C57 transformer standards. The normative references have been updated and expanded. Based on available data from testing samples from operating transformers, the normative and informative information on limits for continued service have been expanded. The bibliography has been expanded to provide additional background for the user. Two additional informative annexes were added: [Annex C](#) provides discussion on fire safety, environmental and sustainability factors of natural ester insulating liquids; [Annex D](#) discusses considerations when applying natural esters to load tap changers (LTCs).

## Acknowledgments

[Table B.1](#) and [Figure B.1](#) were modified with permission from Doble Engineering Company, Lewand, L. R., “Laboratory evaluation of several synthetic and agricultural-based dielectric liquids,” *Proceedings of the 86th Annual International Conference of Doble Clients*, Doble Engineering Company, Watertown, MA, USA, 2001 [B13].

[Figure B.1](#) was reprinted from IEEE Std C57.106™-2002 [B26].

[Figure B.2](#), [Figure B.3](#), and [Figure B.4](#) were reprinted from McShane, C. P., J. Luksich, and K. J. Rapp, “Retrofilling aging transformer with natural ester based dielectric coolant for safety and life extension,” *Proceedings of the IEEE IAS/PCA Cement Industry Technical Conference*, Dallas, TX, USA, May 2003 [B35].

[Table C.1](#) was reprinted with permission from CIGRE Technical Brochure 436, *Experiences in service with new insulating liquids*, © 2011 [B39].

## Contents

1. Overview .....	11
1.1 Scope .....	11
1.2 Purpose .....	11
1.3 System design .....	11
1.4 Background information on mixtures of natural ester liquids with other dielectric liquids .....	12
2. Normative references .....	12
3. Acronyms and abbreviations .....	14
4. Liquid tests and the significance of each test .....	15
4.1 General .....	15
4.2 Practices for sampling (ASTM D923) .....	16
4.3 Acid number (ASTM D664 and ASTM D974) .....	16
4.4 Dielectric breakdown voltage (ASTM D1816) .....	17
4.5 Dielectric breakdown voltage—impulse conditions (ASTM D3300) .....	17
4.6 AC loss characteristics—dissipation factor and relative permittivity (ASTM D922) .....	18
4.7 Interfacial tension (ASTM D971) .....	18
4.8 Color (ASTM D1500) .....	18
4.9 Kinematic viscosity (ASTM D445) .....	19
4.10 Flash point and fire point—Cleveland Open Cup Method (ASTM D92) .....	19
4.11 Relative density (ASTM D1298) .....	19
4.12 Pour point (ASTM D97, ASTM D5949 [B5], and ASTM D1950 [B5]) .....	19
4.13 Volume resistivity (ASTM D1169) .....	20
4.14 Gas analysis (ASTM D3284, D3612) .....	20
4.15 Oxidation stability .....	21
4.16 Water content—Karl Fischer Method (ASTM D1523) .....	22
4.17 Visual examination of used liquids (ASTM D1524) .....	22
4.18 Gassing of insulating liquids under electrical stress and ionization (ASTM D2300) .....	22
4.19 Corrosive sulfur test (ASTM D1275) .....	23
4.20 Polychlorinated biphenyls (PCBs) (ASTM D4059) .....	23
4.21 Furanic compounds (ASTM D5877) .....	23
5. Liquid compatibility with transformer materials .....	23
6. Handling and evaluation of natural ester liquids for use in filling transformers at the installation site .....	23
6.1 General .....	23
6.2 Shipping containers .....	23
6.3 Check tests on receipt .....	24
6.4 Handling of the liquid by the user and placing the liquid in storage .....	24
6.5 Handling and testing of natural ester liquids for installation into apparatus .....	26
7. Evaluation of natural ester liquids received in new equipment and after filling apparatus on-site .....	27
8. Maintenance of natural ester liquids .....	28
8.1 Field screening .....	28
8.2 Laboratory screening .....	29
8.3 Test limits for in-service natural ester liquids .....	29
8.4 Reconditioning .....	30
8.5 Reclaiming .....	31
8.6 Mixtures of different types of insulating liquids .....	32
9. General environmental procedures .....	32
9.1 General .....	32

9.2 Leaks .....	32
9.3 Minor spills .....	32
9.4 Spills on soil .....	33
9.5 Spills on water .....	33
Annex A (informative) Bibliography.....	34
Annex B (informative) Additional technical information.....	38
Annex C (informative) Additional information on fire, safety, environmental, and sustainable properties of natural esters.....	42
Annex D (informative) Discussion regarding natural ester immersed load tap changers (LTCs).....	44

# IEEE Guide for Acceptance and Maintenance of Natural Ester Insulating Liquid in Transformers

## 1. Overview

### 1.1 Scope

This guide recommends tests and evaluation procedures, as well as criteria and methods of maintenance, for natural ester-based (e.g., vegetable oil) insulating liquids. Methods of reconditioning, field applications, and diagnostics of natural ester-based insulating liquids are also described.

### 1.2 Purpose

This guide recommends standard tests and evaluation procedures of natural ester insulating liquids for application in distribution and power transformers and other liquid-filled electrical equipment. Natural ester insulating liquids are also being applied in retrofilling existing liquid-filled equipment. This guide provides recommendations for new and retrofill field applications including: field testing of equipment filled with natural ester insulating liquids, methods of reconditioning and reclaiming natural ester insulating liquids, and the analysis results at which reprocessing or replacement of the insulating liquid is necessary.

### 1.3 System design

The reliable performance of natural ester liquids in an insulation system depends upon certain basic liquid characteristics that can affect overall apparatus characteristics. Such liquid characteristics are integral to equipment design for which the manufacturer should have final responsibility. The reliable operation of the equipment in service, for which the transformer operator should have final responsibility, also depends on maintaining certain basic liquid characteristics. Adherence to the recommended liquid characteristics can assist in obtaining the desired equipment characteristics. Other tests or verification of the integrity of the insulation system may be necessary.

The essential properties of insulating liquids used in transformers should be maintained if the liquid is to perform its multiple roles as electrical insulation and heat transfer agent. It should have adequate dielectric strength to withstand the normal range of electric stresses imposed in service. It should have a certain combination of thermal conductivity, specific heat, and viscosity so that its ability to transfer heat is sufficient for the particular equipment. It should have a sufficiently high flash point and fire point to meet safety requirements. The natural ester liquid should not be allowed to become so deteriorated or contaminated that it adversely affects other materials in the apparatus.