

Recognized as an
American National Standard (ANSI)

IEEE Std C57.18.10-1998(R2003)
(Revision and redesignation of
ANSI/IEEE C57.18-1964)

IEEE Standard Practices and Requirements for Semiconductor Power Rectifier Transformers

Sponsor

**Transformers Committee
of the
IEEE Power Engineering Society**

Approved 4 February 1999

American National Standards Institute

Reaffirmed 9 December 2003
Approved 19 March 1998

IEEE-SA Standards Board

Abstract: Practices and requirements for semiconductor power rectifier transformers for dedicated loads rated single-phase 300 kW and above and three-phase 500 kW and above are included. Static precipitators, high-voltage converters for dc power transmission, and other nonlinear loads are excluded. Service conditions, both usual and unusual, are specified, or other standards are referenced as appropriate. Routine tests are specified. An informative annex provides several examples of load loss calculations for transformers when subjected to nonsinusoidal currents, based on calculations provided in the standard.

Keywords: eddy current losses, harmonic load losses, single-phase transformers, three-phase transformers, three-winding transformers, transformer load losses, two-winding transformers

The Institute of Electrical and Electronics Engineers, Inc.
345 East 47th Street, New York, NY 10017-2394, USA
Copyright © 1998 by the Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 1998. Printed in the United States of America

ISBN 0-7381-0191-5
Second Printing 26 January 2006. To obtain errata information, please go to
<http://standards.ieee.org/reading/ieee/updates/errata/index.html>.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

IEEE Standards documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. Members of the committees serve voluntarily and without compensation. They are not necessarily members of the Institute. The standards developed within IEEE represent a consensus of the broad expertise on the subject within the Institute as well as those activities outside of IEEE that have expressed an interest in participating in the development of the standard.

Use of an IEEE Standard is wholly voluntary. The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation. When a document is more than five years old and has not been reaffirmed, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretation is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of all concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration.

Comments on standards and requests for interpretations should be addressed to:

Secretary, IEEE-SA standards Board
445 Hoes Lane
P.O. Box 1331
Piscataway, NJ 08855-1331
IEEE

Note: Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE shall not be responsible for identifying patents for which a license may be required by an IEEE standard or for conducting inquiries into the legal validity or scope of those patents that are brought to its attention.

Authorization to photocopy portions of any individual standard for internal or personal use is granted by the Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; (508) 750-8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Introduction

(This introduction is not part of IEEE Std C57.18.10-1998, IEEE Standard Practices and Requirements for Semiconductor Power Rectifier Transformers.)

Early editions of ANSI C57.18 were written for transformers used with pool cathode mercury arc rectifiers. The last revision date for ANSI C57.18 was 1964. That standard did not reflect the practices that have developed with the use of semiconductor rectifying or converting devices, nor did it reflect the latest transformer technology. As a result, much of it is inconsistent with current practices and with other related standards, such as ANSI C34.2^{*}, that deal with semiconductor converters. This new standard is the result of the decision to write a new rectifier transformer standard instead of revising the old standard. Suggestions for improvement of these practices will be welcomed.

Basic impulse level (BIL) ratings for windings connected to converters are not specified by this standard. There are many practical reasons why windings connected to converters need not have a BIL test or rating. These windings are often high-current, low-voltage windings that will not produce ANSI standard waveforms when tested. Interleaved windings cannot be impulse tested easily. Usually the converter and the transformer are close coupled in a throat connection and not subject to lightning strikes. The converter usually cannot withstand normal transformer BIL ratings for the winding voltages to which they are connected. These conditions aren't always true, however. If a user wishes to have a BIL rating or test, this may be arranged through commercial negotiations and technical specifications that may override this standard. This should also be acknowledged by the transformer manufacturer during the bidding process.

Hottest-spot winding temperatures are referred to in this standard. These are not tested values. Hottest-spot temperatures cannot be measured from a practical standpoint on production units. Therefore, average winding temperatures plus a hottest-spot increment may be used. There is continuing work in other standards groups on this matter.

The methods of rating the transformer kVA and currents in previous editions of ANSI C57.18 were based on the rms equivalent of a rectangular current wave shape based on the dc rated load commutated with zero commutating angle. This is the rms kVA and current method. All of the tables in Clause 10 are based on this traditional method. A new approach is to base the transformer kVA and currents on the rms value of the fundamental current and kVA. This is the fundamental kVA and current method. The fundamental kVA method is in use in IEC standards. This approach needs to be reflected in ANSI C34.2 and ANSI C34.3 as well as in this standard. The traditional tables are retained in Clause 10 to maintain its method. Both kVA values will be shown on the nameplate to accommodate either method. Specifying engineers should clearly define whether they are specifying the traditional rms kVA or the fundamental kVA so as to avoid confusion. RMS kVA is beneficial to users who utilize their primary metering on the transformer to monitor load. The fundamental kVA is related directly to the real power used by the rectifier or convertor. The rms kVA can be determined when the fundamental kVA is given along with the harmonic spectrum for the load. The specifying engineer is always obligated to supply the harmonic spectrum in order to properly rate and design the transformer. The specifying engineer has overall system responsibility; definition of the harmonic spectrum is not the transformer manufacturer's responsibility. The difference between the two methods should result in only a small percentage error in kVA sizing, but in some cases it may be determined to be critical. Future coordination with ANSI C34.2 and ANSI C34.3 working groups should give a final direction with regard to kVA rating method.

Two cautionary notes are in order regarding testing.

First, errors may result when measuring losses on transformers with low power factors. Care must be exercised in making the loss measurements for rectifier transformers with high reactance and low losses. Test tol-

^{*}A new working group has been formed to revise ANSI C34.2.

erances should be held to 3% throughout the ranges of reactance and losses so as to accurately measure stray losses for the harmonic calculations. There is ongoing work on this subject within the Loss Measurement Working Group of the Performance Characteristics Subcommittee.

Second, other errors regarding resistance readings for losses or temperature rise tests are possible on low-voltage, high-current windings having very low resistance, often with bolted joints. Connection losses may alter normal resistance measurements. Work on this topic should be undertaken in the future.

The exact methodology for temperature rise testing using service losses enhanced with harmonics needs to be more fully developed. After this standard has been in use, it is expected that manufacturers and users will develop more detailed preferred methods. Experience will also provide insight as to whether there are any serious shortcomings in these methods. It is hoped that they will be found to be safely conservative. It is believed that some development time is necessary with the new approach before exact methods are prescribed.

Work should be done on future revisions to this standard to develop more detailed methods of interphase transformer loss testing. More precise methods for determining losses for commercial guarantee purposes, as well as thermal and magnetic capability, are needed. These were not attempted in this standard revision due to lack of time.

This standard was developed by a Working Group of the Subcommittee on Performance Characteristics of the IEEE Transformer Committee. The Working Group had the following membership:

Sheldon P. Kennedy, *Chair*

Rajendra Ahuja
John Armstrong
Kal Atout
Jacques Aubin
Roy A. Bancroft
Alfons Bimbris
Jerry L. Corkran
John Crouse
John A. Ebert
Joseph Foldi
Jerry Frank
John Grace
Roger Hayes

Philip J. Hopkinson
Mike H. Iman
Charles W. Johnson
Anthony J. Jannat
Ed Kalkstein
Eric Kauffman
Lawrence M. Kirchner
A. J. Line
A. J. Ludbrook
Rick Marek
Michael J. Mitelman
Glenn Morrissey

B. K. Patel
Dhiru S. Patel
Charlie Pounds
Guy Prgent
Jeewan Puri
Subhas Sarkar
Ibrahim Shteyh
Anthony J. Siebert
Hyeong Jin Sim
Kenneth R. Skinger
Vis Thenappan
Robert A. Veitch
Kenneth Ziemann

The following persons were on the balloting committee:

R. K. Ahuja	Peter J. Hoeffler	Mark D. Perkins
George Allen	T. L. Holdway	Linden W. Pierce
Jim Antweiler	Philip J. Hopkinson	George J. Reitter
J. Arteaga	Richard Huber	J. C. Riboud
Roy A. Bancroft	A. F. Hueston	Hazairin Samaulah
E. Betancourt	John S. Hurst	Leo J. Savio
Wallace B. Binder	Charles W. Johnson	William E. Saxon
Joe V. Bonucchi	Anthony J. Jonnatti	Wes W. Schwartz
Max A. Cambre	Lars-Erik Juhlin	Pat Scully
Don Chu	Sheldon P. Kennedy	Anthony J. Siebert
Peter W. Clarke	L. Koga	Mark Siehling
Jerry L. Corkran	Barin Kumar	Hyeong Jin Sim
Robert C. Degeneff	John G. Lackey	Kenneth R. Skinger
Dieter Dohnal	Larry A. Lowdermilk	J. Ed Smith
J. C. Duart	Joe D. MacDonald	James E. Smith
John A. Ebert	William A. Maguire	Ronald J. Stora
Gary R. Engmann	K. T. Massouda	James E. Stephens
D. J. Fallon	John W. Matthews	Peter G. Stewart
Joseph Foldi	L. Bruce McClung	Ron S. Stoner
Michael A. Franchek	Jack W. McGill	John C. Sullivan
Juergen Gerth	Nigel P. McQuin	Vis T. Tanapan
Saurabh Ghosh	C. Patrick McShane	James A. Thompson
Richard D. Graham	Daleep C. Mohla	Thomas P. Traub
Robert L. Grubb	Chuck R. Murray	Edger R. Trummer
Robert L. Grunert	William H. Mutschler, Jr.	John Vandermaar
Michael E. Haas	Gerald A. Paiva	Robert A. Veitch
Patrick Hanan	B. K. Patel	Loren B. Wagenaar
Ernst Hanique	Dhiru S. Patel	Barry H. Ward
N. Wayne Hansen	Paulette A. Payton	Richard F. Weddleton
R. R. Hayes	Carlos Peixoto	William G. Wimmer
	Dan D. Percival	

When the IEEE-SA Standards Board approved this standard on 19 March 1998, it had the following membership:

Richard J. Holleman, *Chair*

Donald N. Heirman, *Vice Chair*

Jeff Gorman, *Secretary*

Satish K. Aggarwal
Clyde R. Camp
James T. Carlo
Gary R. Engmann
Harold E. Epstein†
Jay Forster†
Thomas F. Garrity
Ruben D. Herzon

James H. Gurney
Jim D. Isaak
Lowell G. Johnson
Robert Kennelly
E. G. "Al" Kiener
Joseph L. Koepfinger†
Stephen R. Lambert
Jim Logothetis
Donald C. Loughry

L. Bruce McClung
Louis-François Pau
Ronald C. Petersen
Gerald H. Peterson
John B. Posey
Gary S. Robinson
Hans E. Weinrich
Donald W. Zipse

†Member Emeritus

Kristin M. Dittmann
IEEE Standards Project Editor

Currently in preview, click buy full version

Contents

1. Overview.....	1
1.1 Scope.....	1
1.2 Mandatory requirements.....	1
2. References.....	1
3. Definitions.....	2
4. Symbols.....	3
5. Service conditions.....	4
5.1 Usual service conditions.....	4
5.2 Unusual service conditions.....	4
6. Rating data.....	5
6.1 Taps on rectifier transformers.....	6
6.2 Cooling classes of transformers.....	6
6.3 Frequency.....	6
6.4 Phases.....	6
6.5 Rated kVA.....	6
6.6 Compensation on rectifier transformers.....	6
6.7 Rated current.....	7
6.8 Connections.....	7
6.9 Polarity, angular displacement, and lead markings.....	7
6.10 Impedance.....	8
6.11 Losses.....	8
6.12 Temperature rise and insulation system capability.....	8
6.13 Nameplates.....	8
7. Construction.....	11
7.1 Mounting and location.....	11
7.2 Tanks.....	11
7.3 Method of coolant preservation.....	11
7.4 Grounding.....	11
7.5 Connection for shipping.....	11
7.6 Accessories.....	11
8. Testing and calculations.....	12
8.1 Routine tests.....	12
8.2 Symbols used in tests.....	13
8.3 Resistance measurement.....	13
8.4 Dielectric tests.....	13
8.5 Excitation losses.....	13
8.6 Load losses.....	13
8.7 Losses in interphase transformers.....	19
8.8 Impedance tests.....	19

8.9 Ratio tests	20
8.10 Temperature rise test.....	20
8.11 Short-circuit tests	22
8.12 Polarity and phase relation.....	22
9. Tolerances	23
9.1 Tolerances for ratio	23
9.2 Tolerances for impedance	23
9.3 Tolerances for losses.....	23
Annex A (informative) Harmonic loss calculation examples.....	49
Annex B (informative) Bibliography.....	61

IEEE Standard Practices and Requirements for Semiconductor Power Rectifier Transformers

1. Overview

1.1 Scope

This standard includes semiconductor power rectifier transformers for dedicated loads rated

- Single-phase 300 kW and above
- Three-phase 500 kW and above

The scope of this standard excludes

- Static precipitators
- High-voltage converters for dc power transmission
- Other nonlinear loads

1.2 Mandatory requirements

When this standard is used on a mandatory basis, the words “shall” and “must” indicate mandatory requirements, and the words “should” and “may” refer to matters that are recommended and permitted, respectively, but not mandatory.

2. References

When the following standards and guides referred to in this standard are superseded by an approved revision, the latest revision shall apply.

ANSI C34.3-1973 (IEEE Std 444-1973), IEEE Standard Practices and Requirements for Thyristor Converters for Motor Drives.¹

¹This standard has been withdrawn; however, copies can be obtained from Global Engineering, 15 Inverness Way East, Englewood, CO 80112-5704, USA, tel. (303) 792-2181.