

IEEE Standard Specifications for Surge Protectors Used in Low- Voltage Data, Communications, and Signaling Circuits

Sponsor

Surge Protective Devices Committee
of the
IEEE Power & Energy Society

Approved 11 September 2009

IEEE-SA Standards Board

Abstract: Surge protectors for application on multiconductor and coaxial, balanced or unbalanced, data, communications, and signaling circuits with voltages less than or equal to 1000 V rms or 1200 V dc are covered. These surge protectors are multiple-component series or parallel combinations of one or more nonlinear elements and zero or more linear elements. The tables of typical performance values provide a means of comparison among various surge protectors. They also provide a common engineering language beneficial to the user and manufacturer of surge protectors used in low-voltage data, communications, and signaling circuits.

Keywords: low voltage, performance, surge protector

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2009 by the Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 18 December 2009. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by the Institute of Electrical and Electronics Engineers, Incorporated.

National Electrical Code and NEC are both registered trademarks of the National Fire Protection Association, Inc.

PDF: ISBN 978-0-7381-6090-0 STD95983
Print: ISBN 978-0-7381-6091-7 STDPD95983

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

IEEE Standards documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. The IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While the IEEE administers the process and establishes rules to promote fairness in the consensus development process, the IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

Use of an IEEE Standard is wholly voluntary. The IEEE disclaims liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon this, or any other IEEE Standard document.

The IEEE does not warrant or represent the accuracy or content of the material contained herein, and expressly disclaims any express or implied warranty, including any implied warranty of merchantability or fitness for a specific purpose, or that the use of the material contained herein is free from patent infringement. IEEE Standards documents are supplied "AS IS."

The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation, or every ten years for stabilization. When a document is more than five years old and has not been reaffirmed, or more than ten years old and has not been stabilized, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

In publishing and making this document available, the IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Nor is the IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing this, and any other IEEE Standards document, should rely upon his or her independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretation is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration. A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered the official position of IEEE or any of its committees and shall not be considered to be, nor be relied upon as, a formal interpretation of the IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position, explanation, or interpretation of the IEEE.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Recommendations to change the status of a stabilized standard should include a rationale as to why revision or withdrawal is required. Comments and recommendations on standards, and requests for interpretation, should be addressed to:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
Piscataway, NJ 08854
USA

Authorization to photocopy portions of any individual standard for internal or personal use is granted by The Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Introduction

This introduction is not part of IEEE Std C62.64-2009, IEEE Standard Specifications for Surge Protectors Used in Low-Voltage Data, Communications, and Signaling Circuits.

This revision of IEEE Std C62.64-1997 has been developed by the Low-Voltage Data, Communications, and Signaling Circuit Surge Protective Devices Working Group of the Low-Voltage Surge Protective Devices Subcommittee. It provides typical values of the parameters that are used to specify the performance of these surge protectors. The tests that are used to characterize the parameters are in IEEE Std C62.36TM-2000, so the two standards are companion documents.^a

This standard is directed toward service providers who wish to provide electrical protection against surge on low-voltage circuits. The typical values promote consistency by helping users in selecting appropriate parameter values and by aiding suppliers in focusing their resources on parameters of interest. Yet, this standard is flexible enough that applications needing values that differ from the typical levels can use whatever is required.

This standard covers a wide range of possible protectors. They may limit voltages, currents, or both. Not all specification values apply to each protector. The user of the standard selects from among the many possible specifications, the tests and parameter values needed by the application. For instance, a protector for an application that requires only voltage limiting would not specify values from the current-limiting specifications, and would select only the parameters from the voltage-limiting specifications that are required by the application. In that way, a voltage-limiting surge protector may include, for example, a specification value for return loss (see 5.2.3.3), but not for longitudinal balance (see 5.2.3.4). The typical values of this standard also provide standardized values of important parameters for use with international standardization efforts.

Notice to users

Laws and regulations

Users of these documents should consult all applicable laws and regulations. Compliance with the provisions of this standard does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

This document is copyrighted by the IEEE. It is made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making this document available for use and adoption by public authorities and private users, the IEEE does not waive any rights in copyright to this document.

^a Information on references can be found in Clause 2.

Updating of IEEE documents

Users of IEEE standards should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect. In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE Standards Association web site at <http://ieeexplore.ieee.org/xpl/standards.jsp>, or contact the IEEE at the address listed previously.

For more information about the IEEE Standards Association or the IEEE standards development process, visit the IEEE-SA web site at <http://standards.ieee.org>.

Errata

Errata, if any, for this and all other standards can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/updates/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Interpretations

Current interpretations can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/interp/index.html>.

Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

Participants

At the time this standard was submitted to the IEEE-SA Standards Board for approval, the Low-Voltage Data, Communications, and Signaling Circuit Surge Protective Devices Working Group had the following membership:

Albert Martin, *Chair*

Robert Ashton
William Bush
Nisar Chaudhry
Leonard Drewes
Rick Ellenberger

Ernie Gallo
Phillip Havens
Bogey Klobassa
Carl Lindquist

Michael Maytum
Wolfgang Oertel
Alan Rebeck
Bill Travis
Donald Turner

The following members of the individual balloting committee voted on this standard. Balloters may have voted for approval, disapproval, or abstention.

William Bartley
William Bloethe
Kenneth Brown
Suresh Channarasappa
Tommy Cooper
Carlo Donati
Gary Engmann
Randall Groves
Steven Hensley
Raymond Hill
Ronald W. Hotchkiss
Chad Kiger

Joseph L. Koepfinger
Saumen Kundu
Carl Lindquist
Albert Martin
Michael Maytum
Gary Michel
Michael S. Newman
David Nichols
Wolfgang Oertel
Thomas Phipps
Percy Pool

Michael Roberts
Charles Rogers
Thomas Rozek
Bartien Sayogo
Kenneth Sedziol
Gil Shultz
James E. Smith
Jerry Smith
Donald Turner
John Vergis
James Wilson
Larry Young

When the IEEE-SA Standards Board approved this standard on 11 September 2009, it had the following membership:

Robert M. Grow, *Chair*
Thomas Prevost, *Vice Chair*
Steve M. Mills, *Past Chair*
Judith Gorman, *Secretary*

John Barr
Karen Bartleson
Victor Berman
Ted Burse
Richard DeBlasio
Andy Drozd
Mark Epstein

Alexander Gelman
Jim Hughes
Richard H. Hulett
Young Kyun Kim
Joseph L. Koepfinger*
John Kulick

David J. Law
Ted Olsen
Glenn Parsons
Ronald C. Petersen
Narayanan Ramachandran
Jon Walter Rosdahl
Sam Sciacca

*Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Howard L. Wolfman, *TAB Representative*
Michael Janezic, *NIST Representative*
Satish Aggarwal, *NRC Representative*

Lisa Perry
IEEE Standards Program Manager, Document Development

Soo H. Kim
IEEE Standards Program Manager, Technical Program Development

Contents

1. Overview	1
1.1 Scope	1
1.2 SPD configurations.....	2
1.3 Use of this standard	2
2. Normative references.....	5
3. Definitions	6
4. Service and test conditions	6
4.1 Service conditions.....	6
4.2 Test temperature and humidity	6
4.3 General environmental considerations.....	7
4.4 SPD testing	9
4.5 Waveform tolerances	9
5. Requirements and test specifications.....	10
5.1 General requirements.....	10
5.2 Electrical requirements	11
Annex A (normative) Application Categories A10 through A4	24
Annex B (normative) Application Category B.....	52
Annex C (normative) Application Category C.....	53
Annex D (normative) Application Category D.....	54
Annex E (normative) Application Category E.....	55
Annex F (normative) Application Category F.....	56
Annex G (normative) Application Categories G10 through G20	57
Annex H (informative) Glossary	58
Annex I (informative) Bibliography.....	59

IEEE Standard Specifications for Surge Protectors Used in Low-Voltage Data, Communications, and Signaling Circuits

IMPORTANT NOTICE: This standard is not intended to ensure safety, security, health, or environmental protection in all circumstances. Implementers of this standard are responsible for determining appropriate safety, security, environmental, and other practices or regulatory requirements.

This IEEE document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading "Important Notices and Disclaimers Concerning IEEE Documents." They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.

1. Overview

This standard is divided into five clauses, normative annexes (some of which are under study), a glossary, and a bibliography. Clause 1 provides the scope of this standard. Clause 2 lists references to publications that are needed to apply this standard. Clause 3 provides general definitions that may be needed for a surge protector regardless of its voltage- or current-limiting function. Clause 4 provides service and test conditions. Clause 5 provides requirements and test specifications.

1.1 Scope

This standard applies to surge protectors for application on multi-conductor and coaxial, balanced or unbalanced, data, communications, and signaling circuits with voltages less than or equal to 1000 V rms, or 120 V dc. These surge protectors are intended to limit voltage surges, current surges, or both.

This standard is not intended to cover individual device components. Installation of all surge protectors (SPDs) must be in conformance with the requirements of applicable local and national electrical codes. Specifically excluded from this standard are protectors for low-voltage power circuit applications.

The surge protectors covered by this standard are to be tested by means of the connections or terminations that are used when the surge protector is installed in the field. For surge protectors that are intended to be used with a base or connector, that base or connector shall be part of the tests.

The tables of typical performance values of this standard provide a means of comparison among various surge protectors. They also provide a common engineering language beneficial to the user and manufacturer of surge protectors used in low-voltage data, communications, and signaling circuits.

1.2 SPD configurations

The surge protectors covered are multiple-component series or parallel combinations of linear or nonlinear elements, packaged for the purpose of limiting voltage, current, or both. Figure 1 is based on Figure 1 of IEEE Std C62.36™-2000 and illustrates functional block diagrams for the surge protectors covered by this standard.¹

1.3 Use of this standard

1.3.1 Application types

Tables of applications in this standard often refer to application types. In such tables, each application type is given an alphanumeric designation that refers to a typical value(s) for that specific application. All of the typical values on the same row as the designator apply to that application type.

A given surge protector has the same designation in all application type tables. For example, a surge protector has application type designation A for the insulation resistance specification, and also application type designation A for the other specifications such as in-rush limiting voltage and impulse reset.

Table 1² describes the application types included in this document. For each application type (e.g., A), a short description is provided on the main characteristics of the surge protector (e.g., where used). Furthermore, each application type has further subcategories that address different designs of surge protectors applied to the same application type. These subcategories are:

- a) *Main characteristics of the telecommunications circuit.* This subcategory is described in the second column of Table 1 and is designated by the first numeric number after the designation (see Table 1).
- b) *Type of surge protector.* This subcategory is described in the third column of Table 1 and is designated by the second numeric number after the designation (see Table 1). This characteristic addresses the different surge protectors that may contain voltage-limiting devices, or current-limiting devices, or both.

For example, an application type can address primary surge protectors intended for paired conductors in telecommunications circuits (i.e., Public Switching Telephone Network, PSTN); the application type designation is A in Table 1. This application type may be subdivided to surge protectors that are intended for different services such as voice and certain Digital Subscriber Lines (DSLs) technologies; the application types are subdivided to A1, A2, and A3 as described in Table 1. In addition, the surge protector may have different combinations of voltage and various types of current limiters such as non-resetting and self-resetting intended for the same subcategory (e.g., A1). For this reason, the application types are further subdivided to A11, A12, A14, and A13 as described in Table 1.

¹ Information on references can be found in Clause 2.

² The numbers in brackets correspond to those of the bibliography in Annex I.