

Institute of Environmental Sciences and Technology

IEST-RP-CC021.3

Contamination Control Division
Recommended Practice 021.3

Testing HEPA and ULPA Filter Media



1827 Walden Office Square, Suite 400 |
Schaumburg, IL 60173 USA
Phone: (847) 981-0100 • Fax: (847)
981-4130 E-mail: iest@iest.org • Web:
www.iest.org

This Recommended Practice is published by the Institute of Environmental Sciences and Technology (IEST) to advance the technical and engineering sciences. Use of this document is entirely voluntary, and determination of its applicability and suitability for any particular use is solely the responsibility of the user. Use of this Recommended Practice does not imply any warranty or endorsement by IEST.

This Recommended Practice was prepared by and is under the jurisdiction of Working Group 021 of the IEST Contamination Control Division.

Copyright © 2009 by the Institute of Environmental Sciences and Technology

Second printing, July 2017

ISBN 978-0-9841330-1-7

PROPOSAL FOR IMPROVEMENT: The Working Group of the Institute of Environmental Sciences and Technology are continually working on improvements to their Recommended Practices and Reference Documents. Suggestions from users of these documents are welcome. If you have a suggestion regarding this document, please use the online Proposal for Improvement form found on the IEST website at www.iest.org.

Institute of Environmental Sciences and Technology
182 Walden Office Square, Suite 400 |
Schaumburg, IL 60173 USA
Phone: (847) 981-0100 • Fax: (847) 981-4130
E-mail: iest@iest.org • Web: www.iest.org

Testing HEPA and ULPA Filter Media

IEST-RP-CC021.3

CONTENTS

SECTION

1	SCOPE AND LIMITATIONS	5
2	REFERENCES.....	5
3	TERMS AND DEFINITIONS	6
4	TEST METHODS	7
5	REPORTING AND MARKING.....	17

FIGURES

1	TYPICAL TEST SYSTEM.....	9
B1	IMPACT SCORE DEVICE	23
B2	RILL PENETRATION.....	23

TABLES

B1	95% CONFIDENCE LIMITS FOR THE MEAN VALUE OF A POISSON VARIABLE	20
B2	SINGLE DETERMINATION ANALYSIS	25
B3	DUAL DETERMINATION ANALYSIS	26

APPENDIXES

A	CALIBRATION PERIOD SUMMARY	18
B	GENERAL INFORMATION	19
C	BIBLIOGRAPHY	27

COPYING IS ILLEGAL
Currently in preview, click buy full version

Testing HEPA and ULPA Filter Media

IEST-RP-CC021.3

1 SCOPE AND LIMITATIONS

1.1 Scope

This Recommended Practice (RP) discusses test methods for physical and filtration properties of high-efficiency particulate air (HEPA) and ultra low penetration air (ULPA) filtration media.

Application of this RP is by mutual agreement between the customer and the supplier. Use of this RP should be applied, but not be limited to:

- a) Acceptance criteria for test methods;
- b) Test aerosol and particle size;
- c) Test face velocity.

1.2 Limitations

This RP does not include discussion of special applications testing, such as nuclear, biological, chemical, and other such testing. Although the general approach to testing media outlined in this RP may be used for testing media with lower efficiency than HEPA media, the user is cautioned that specific recommendations noted on aerosols, statistics, instrumentation, and other factors may not be appropriate.

NOTE: Testing in accordance with this RP may involve hazardous materials, operations, and equipment. This RP does not purport to address all of the safety problems associated with its use. It is the responsibility of the user to establish appropriate safety and health practices and to determine the applicability of regulatory limitations prior to use.

2 REFERENCES

The following documents are incorporated into this RP to the extent specified herein. Users should apply the most recent edition of the references.

2.1 Reference documents

ASTM-D 986: Evaluation of Air Assay Media by the Monodispers DOP (Dioctyl Phthalate) Smoke Test

AS1. 1-19: Standard Practice for Secondary Calibration of Airborne Particle Counter Using Comparison Procedures

ASTM-F778: Standard Methods for Gas Flow Resistance Testing of Filtration Media

IEST-RP-CC007: Testing ULPA Filters

IEST-RP-CC014: Calibration and Characterization of Optical Airborne Particle Counters

MIL-STD-282, Method 603.1: Operation of the E13R (Q101) Water-Repellency-Test Apparatus

TAPPI-T410: Grammage of Paper and Paperboard

TAPPI-T411: Thickness (Caliper) of Paper, Paperboard, and Combined Board

TAPPI-T413: Ash in Paper

TAPPI-T494: Tensile Breaking Properties of Paper and Paperboard (Using Constant Rate of Elongation Apparatus)

TAPPI-T543: Bending Resistance of Paper (Gurley Type Stiffness Tester)