

JIS

JAPANESE
INDUSTRIAL
STANDARD

Translated and Published by
Japanese Standards Association

JIS A 1310 : 2015

(CBRD/JSA)

**Test method for fire propagation
over building façades**

ICS 13.220.50;91.060.10

Reference number : **JIS A 1310 : 2015 (E)**

A 1310 : 2015

Date of Establishment: 2015-01-25

Date of Public Notice in Official Gazette: 2015-01-26

Investigated by: Japanese Industrial Standards Committee
Standards Board for ISO area
Technical Committee on Architecture

JIS A 1310:2015, First English edition published in 2015-11

Translated and published by: Japanese Standards Association
Mita MT Building, 3-13-12, Mita, Minato-ku, Tokyo, 108-0073 JAPAN

In the event of any doubts arising as to the contents,
the original JIS is to be the final authority.

© JSA 2015

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

Printed in Japan

KK/AT

PROTECTED BY COPYRIGHT

Contents

	Page
Introduction.....	1
1 Scope.....	1
2 Normative references.....	1
3 Terms and definitions.....	1
4 Principle.....	2
5 Test apparatus.....	2
5.1 General.....	2
5.2 Specimen substrate.....	2
5.3 Specimen support frame.....	2
5.4 Combustion chamber.....	2
6 Test specimen.....	6
7 Test specimen curing.....	6
8 Fire source and exposure.....	6
9 Items to be measured.....	7
10 Test environment.....	7
11 Test procedure.....	7
12 Expression of results.....	8
13 Precision.....	9
14 Test report.....	9
Annex JA (informative) Examples of opening area.....	10
Annex JB (informative) Comparison table between JIS and corresponding International Standard.....	18

Foreword

This translation has been made based on the original Japanese Industrial Standard established by the Minister of Land, Infrastructure, Transport and Tourism through deliberations at the Japanese Industrial Standards Committee according to the proposal for establishment of Japanese Industrial Standard submitted by Consortium for Building Research and Development (CBRD)/Japanese Standards Association (JSA) with the draft being attached, based on the provision of Article 12 Clause 1 of the Industrial Standardization Law.

This **JIS** document is protected by the Copyright Law.

Attention is drawn to the possibility that some parts of this Standard may conflict with patent rights, applications for a patent after opening to the public or utility model rights. The relevant Minister and the Japanese Industrial Standards Committee are not responsible for identifying any of such patent rights, applications for a patent after opening to the public or utility model rights.

Test method for fire propagation over building façades

Introduction

This Japanese Industrial Standard has been prepared based on the first edition of **ISO 13785-1** published in 2002 with some modifications of the technical contents, including the fire source and exposure, and the shape of test specimen.

The portions given sidelines or dotted underlines are the matters in which the contents of the corresponding International Standards have been modified. A list of modifications with the explanations is given in Annex JB.

1 Scope

This Standard specifies a screening method for determining the fire propagation of products and constructions of a building façade when exposed to flames ejected from the opening.

This Standard, however, does not apply to stability, insulation and integrity of the exterior wall.

WARNING Particular attention shall be paid to the fact that hazardous gas may be generated and/or fire propagation of specimen can occur sometimes with possible structural collapse of the specimen in whole or in part and the necessary preventive measures shall be taken. An adequate means of extinguishing the specimen shall be provided.

NOTE : The International Standard corresponding to this Standard and the symbol of degree of correspondence are as follows.

ISO 13785-1:2002 *Reaction-to-fire tests for façades—Part 1: Intermediate-scale test* (MOD)

In addition, symbols which denote the degree of correspondence in the contents between the relevant International Standard and **JIS** are IDT (identical), MOD (modified), and NEQ (not equivalent) according to **ISO/IEC Guide 21-1**.

2 Normative references

The following standards contain provisions which, through reference in this text, constitute provisions of this Standard. For those without the indication of the year, the most recent edition (including amendments) shall be applied.

JIS A 5430 *Fibre reinforced cement boards*

JIS K 2240 *Liquefied petroleum gases*

JIS R 3311 *Ceramic fiber blanket*

3 Terms and definitions

For the purpose of this Standard, the following terms and definitions apply.