

# JIS

JAPANESE  
INDUSTRIAL  
STANDARD

Translated and Published by  
Japanese Standards Association

---

JIS A 1450 : 2021

(JAFA/JSA)

**Test methods for raised access floor**

---

ICS 91.060.30

Reference number : JIS A 1450 : 2021 (E)

A 1450 : 2021

Date of Establishment: 1997-04-20

Date of Revision: 2021-11-22

Date of Public Notice in Official Gazette: 2021-11-22

Investigated by: Japanese Industrial Standards Committee

Standards Board for ISO area

Technical Committee on Architecture

---

JIS A 1450 : 2021, First English edition published in 2022-07

Translated and published by: Japanese Standards Association  
Mita MT Building, 3-13-12, Mita, Minato-ku, Tokyo, 108-0073 JAPAN

---

In the event of any doubts arising as to the contents,  
the original JIS is to be the final authority.

© JSA 2022

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

Printed in Japan

HN

PROTECTED BY COPYRIGHT

## Contents

		Page
1	Scope .....	1
2	Normative references .....	1
3	Terms and definitions .....	1
4	Test items .....	2
5	General conditions of tests .....	3
5.1	Conditions of test location and conditioning of test specimen .....	3
5.2	Surface finishing material .....	3
5.3	Measuring instruments .....	3
5.4	Test specimen .....	4
5.5	Expression of test results .....	4
6	Tests .....	4
6.1	Dimensional measurement .....	4
6.2	Static load test .....	5
6.3	Impact test .....	7
6.4	Rolling load test .....	10
6.5	Combustion test .....	13
6.6	Electrostatic propensity test .....	15
6.7	Leakage resistance test .....	16
6.8	Vibration test .....	17
7	Additional information to be included in the test report .....	22
	Annex A (normative) Dimensional measurement of the floor for which dimensional precision is required .....	23
	Annex B (informative) List of technically significant revisions from the previous edition .....	26

## Foreword

This Japanese Industrial Standard has been revised by the Minister of Economy, Trade and Industry through deliberations at the Japanese Industrial Standards Committee as the result of proposal for revision of Japanese Industrial Standard submitted by Japan Access Floor Association (JAFA)/Japanese Standards Association (JSA) with a draft being attached, based on the provision of Article 12, paragraph (1) of the Industrial Standardization Act applied mutatis mutandis pursuant to the provision of Article 16 of the said Act. This edition replaces the previous edition (**JIS A 1450** : 2015), which has been technically revised.

This **JIS** document is protected by the Copyright Act.

Attention is drawn to the possibility that some parts of this Standard may conflict with patent rights, published patent application or utility model rights. The relevant Minister and the Japanese Industrial Standards Committee are not responsible for identifying any of such patent rights, published patent application or utility model rights.

## Test methods for raised access floor

### 1 Scope

This Japanese Industrial Standard specifies the test methods for raised access floor (hereafter referred to as floor).

A list of technically significant revisions from the previous edition with reasons is given in Annex B.

### 2 Normative references

Part or all of the provisions of the following standards, through reference in this text, constitute provisions of this Standard. The most recent editions of the standards (including amendments) indicated below shall be applied.

JIS A 1455 *Anti-static effect of floor coverings and installed floors — Methods of measurement and evaluation*

JIS B 7503 *Mechanical dial gauges*

JIS B 7507 *Vernier, dial and digital callipers*

JIS B 7512 *Steel tape measures*

JIS B 7514 *Steel straightedges*

JIS B 7524 *Feeler gauges*

JIS B 7534 *Carpenter's squares*

JIS B 8922 *Industrial wheels*

JIS K 8101 *Ethanol (99.5) (Reagent)*

JIS L 1021-16 *Traffic floor coverings — Part 16 : Assessment of static electrical propensity — Walking test*

JIS L 4406 *Tile carpet*

JIS R 5201 *Physical testing methods for cement*

### 3 Terms and definitions

For the purpose of this Standard, the following terms and definitions apply.

#### 3.1

#### **raised access floor**

Alternative term : floor

double flooring system of which the floor top panels, etc. can be easily detached to allow access to the equipment, etc. in the underfloor space for maintenance purposes