

JIS

JAPANESE
INDUSTRIAL
STANDARD

Translated and Published by
Japanese Standards Association

JIS A 1487 : 2018

**Test method of thermal transmission
properties for vacuum insulated building
components**

ICS 91.100.60

Reference number : JIS A 1487 : 2018 (E)

A 1487 : 2018

Date of Establishment: 2018-05-21

Date of Public Notice in Official Gazette: 2018-05-21

Investigated by: Japanese Industrial Standards Committee

Standards Board for ISO area

Technical Committee on Architecture

JIS A 1487 : 2018, First English edition published in 2019-01

Translated and published by: Japanese Standards Association
Mita MT Building, 3-13-12, Mita, Minato-ku, Tokyo, 108-0073 JAPAN

In the event of any doubts arising as to the contents,
the original JIS is to be the final authority.

© JSA 2019

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

Printed in Japan

KK/HN

PROTECTED BY COPYRIGHT

Contents

| | | Page |
|-----|---------------------------------------------------------------------------------------------------------------|------|
| 1 | Scope | 1 |
| 2 | Normative references | 1 |
| 3 | Terms, definitions, symbols and units | 1 |
| 3.1 | Terms and definitions | 1 |
| 3.2 | Symbols and units | 2 |
| 4 | Apparatus and test specimens | 3 |
| 4.1 | General | 3 |
| 4.2 | Calibration panels | 4 |
| 4.3 | Surround panels | 4 |
| 4.4 | Test specimens | 4 |
| 5 | Calibration procedure | 5 |
| 6 | Test procedure | 6 |
| 6.1 | General | 6 |
| 6.2 | Installation of test specimen | 6 |
| 6.3 | Heat transfer area | 8 |
| 6.4 | Calculation of thermal transmittance | 8 |
| 6.5 | Calculation of equivalent thermal resistance | 9 |
| 7 | Report | 9 |
| | Annex A (normative) Calculation method of thermal resistance correction linear thermal transmittance | 10 |
| | Annex B (informative) Passage heat flow rate at the edge | 15 |

Foreword

This Japanese Industrial Standard has been established by the Minister of Economy, Trade and Industry, through deliberations at the Japanese Industrial Standards Committee in accordance with the Industrial Standardization Law.

This **JIS** document is protected by the Copyright Law.

Attention is drawn to the possibility that some parts of this Standard may conflict with patent rights, applications for a patent after opening to the public or utility model rights. The relevant Minister and the Japanese Industrial Standards Committee are not responsible for identifying any of such patent rights, applications for a patent after opening to the public or utility model rights.

Test method of thermal transmission properties for vacuum insulated building components

1 Scope

This Japanese Industrial Standard specifies the test method of thermal transmission properties for vacuum insulation and vacuum insulated composite products (hereafter generically referred to as vacuum insulated building components) which are used mainly at ordinary temperature in residences and buildings.

NOTE 1 This Standard describes the procedure for measuring the thermal transmittance of vacuum insulated building components using the calibrated hot box method, and also describes the method for calculating the equivalent thermal resistance from the thermal transmittance.

NOTE 2 The accuracy of measurement is determined by the dimensions of a test apparatus and the specifications of a test specimen.

2 Normative references

The following standards contain provisions which, through reference in this text, constitute provisions of this Standard. The most recent editions of the standards (including amendments) indicated below shall be applied.

JIS A 0202 *Thermal insulation — Vocabulary*

JIS A 1412-1 *Test method for thermal resistance and related properties of thermal insulations — Part 1: Guarded hot plate apparatus*

JIS A 1412-2 *Test method for thermal resistance and related properties of thermal insulations — Part 2: Heat flow meter apparatus*

JIS A 1420 *Determination of steady-state thermal transmission properties — Hot box method*

JIS A 4710 *Windows and doorsets — Thermal resistance test*

JIS B 7519 *Steel tape measures*

JIS Z 0108 *Packaging — Vocabulary*

3 Terms, definitions, symbols and units

3.1 Terms and definitions

For the purpose of this Standard, the terms and definitions given in JIS A 0202, JIS A 1420 and JIS Z 0108, and the following apply.

3.1.1

vacuum insulation

porous core material such as fibre and powder which is covered by the covering mate-