

JIS

JAPANESE
INDUSTRIAL
STANDARD

Translated and Published by
Japanese Standards Association

JIS C 3611 : 2020

(JSA)

Insulated wires for cubicle type unit
substation for 6.6 kV receiving

ICS 29.060.10

Reference number : JIS C 3611 : 2020 (E)

Date of Establishment: 1975-04-01

Date of Revision: 2020-11-20

Date of Public Notice in Official Gazette: 2020-11-20

Developed by: Japanese Standards Association

Investigated by: JIS Development Committee on Electricity Technology

JIS C 3611:2020, First English edition published in 2021-06

Translated and published by: Japanese Standards Association
Mita MT Building, 3-13-12, Mita, Minato-ku, Tokyo, 108-0073 JAPAN

In the event of any doubts arising as to the contents,
the original JIS is to be the final authority.

© JSA 2021

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

Printed in Japan

AT

Contents

		Page
1	Scope	1
2	Normative references	1
3	Terms and definitions	1
4	Classification and symbols	1
5	Characteristics	1
6	Materials, construction and manufacturing method	2
7	Test methods	3
7.1	Appearance	3
7.2	Construction	3
7.3	Conductor resistance	3
7.4	Dielectric withstand voltage	3
7.5	Insulation resistance	3
7.6	Creepage withstand voltage	3
7.7	Resistance to tracking	3
7.8	Pulling of insulation	3
7.9	Thermal ageing	3
7.10	Heat deformation	4
7.11	Resistance to ozone	4
8	Inspection	4
9	Packaging	4
10	Designation of product	5
11	Marking	5
11.1	Marking on wire	5
11.2	Marking on package	5

Foreword

This Japanese Industrial Standard has been revised by the Minister of Economy, Trade and Industry based on the provision of Article 14, paragraph (1) of the Industrial Standardization Act applied mutatis mutandis pursuant to the provision of Article 16 of the said Act in response to a proposal for revision of Japanese Industrial Standard with a draft being attached, submitted by Japanese Standards Association (JSA), an accredited standards development organization. This edition replaces the previous edition (**JIS C 3611:1991**), which has been technically revised.

This **JIS** document is protected by the Copyright Act.

Attention is drawn to the possibility that some parts of this Standard may conflict with patent rights, published patent application or utility model rights. The relevant Minister is not responsible for identifying any of such patent rights, published patent application or utility model rights.

Insulated wires for cubicle type unit substation for 6.6 kV receiving

1 Scope

This Japanese Industrial Standard specifies requirements for wires insulated with ethylene propylene rubber (hereafter referred to as EP rubber) or cross-linked polyethylene that are used for wiring in cubicle type unit substations for 6.6 kV receiving (hereafter referred to as wires).

2 Normative references

Part or all of the provisions of the following standards, through reference in this text, constitute provisions of this Standard. The most recent edition of the standards (including amendments) indicated below shall be applied.

JIS C 3005 *Test methods for rubber or plastic insulated wires and cables*

JIS C 3102 *Annealed copper wires for electrical purposes*

JIS C 3152 *Tin coated annealed copper wires*

3 Terms and definitions

No terms and definitions are listed in this Standard.

4 Classification and symbols

Classification and symbols of wires are as given in Table 1.

Table 1 Classification and symbols

Classification	Symbol
EP rubber wire	KIP
Cross-linked polyethylene wire	KIC

5 Characteristics

Characteristics, when tested in accordance with the methods specified in Clause 7, shall conform to the requirements given in Table 2.