

Determination of Phosphonate Concentration in Water

This NACE International standard represents a consensus of those individual members who have reviewed this document, its scope, and provisions. Its acceptance does not in any respect preclude anyone, whether he has adopted the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not in conformance with this standard. Nothing contained in this NACE International standard is to be construed as granting any right, by implication or otherwise, to manufacture, sell, or use in connection with any method, apparatus, or product covered by Letters Patent, or as indemnifying or protecting anyone against liability for infringement of Letters Patent. This standard represents minimum requirements and should in no way be interpreted as a restriction on the use of better procedures or materials. Neither is this standard intended to apply in all cases relating to the subject. Unpredictable circumstances may negate the usefulness of this standard in specific instances. NACE International assumes no responsibility for the interpretation or use of this standard by other parties and accepts responsibility for only those official NACE International interpretations issued by NACE International in accordance with its governing procedures and policies which preclude the issuance of interpretations by individual volunteers.

Users of this NACE International standard are responsible for reviewing appropriate health, safety, environmental, and regulatory documents and for determining their applicability in relation to this standard prior to its use. This NACE International standard may not necessarily address all potential health and safety problems or environmental hazards associated with the use of materials, equipment, and/or operations detailed or referred to within this standard. Users of this NACE International standard are also responsible for establishing appropriate health, safety, and environmental protection practices, in consultation with appropriate regulatory authorities if necessary, to achieve compliance with any existing applicable regulatory requirements prior to the use of this standard.

CAUTIONARY NOTICE: NACE International standards are subject to periodic review, and may be revised or withdrawn at any time without prior notice. NACE International requires that a notice be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of initial publication. The user is cautioned to obtain the latest edition. Purchasers of NACE International standards may receive current information on all standards and other NACE International publications by contacting the NACE International FirstService Department, 15835 Park Ten Place, Houston, Texas 77084, telephone +1 (281) 228-6223.

ABSTRACT

This standard test method is a colorimetric determination of low concentrations of phosphonate residuals in water from oil and gas production, water injection/disposal, and other industrial applications. This standard is maintained by Task Group (TG) 414.

KEYWORDS

Oil and gas, water, phosphonate

In NACE standards, the terms shall, must, should, and may are used in accordance with the definitions of these terms in the NACE Publications Style Manual. The terms shall and must are used to state a requirement, and are considered mandatory. The term should is used to state something good and is recommended, but is not considered mandatory. The term may is used to state something considered optional.

Foreword

This standard test method is a colorimetric determination of low concentrations of phosphonate residuals in water. Organic phosphonates are used as mineral scale and corrosion inhibitors in oil and gas operations, water injection/disposal operations, and other industrial applications. This test method is intended for use by oil and gas operators and service companies to determine residual phosphonate concentrations in waters that are treated with phosphonate inhibitors.

This test method was developed at Rice University under the direction of Dr. Mason Tomson¹ with funding from the Gas Research Institute Group.

This standard was originally prepared by Task Group (TG) T-1D-52, a component of Unit Committee T-1D, "Corrosion Monitoring and Control of Corrosion Environments in Petroleum Production Operations" in 1973, and it was reaffirmed in 2005 by Specific Technology Group (STG) 31, "Oil and Gas Production—Corrosion and Scale Inhibition." The standard was stabilized in 2018 by TG 114, "Review and Revise as Necessary NACE Standard TM0399-2005." It is issued by NACE International under the auspices of STG 31.

Determination of Phosphonate Concentration in Water

1.	General	4
2.	Interferences	4
3.	Test Apparatus	5
4.	Reagents	5
5.	Precautions	6
6.	Sampling	6
7.	Calibration and Standardization of Spectrophotometer	7
8.	Test Procedure	7
9.	Standard Addition Procedure	9
10.	Calculation and Reporting of Test Results	9
	References	10
	Bibliography	11
	Appendix A: (Nonmandatory)Phosphonate Calibration Curve	11

Figures

A1:	Figure A1: Typical Phosphonate Calibration Curve.....	11
-----	---	----

Tables

1:	Common Phosphonate-Based Scale Inhibitors.....	10
----	--	----