



2017 NBIC

NATIONAL BOARD INSPECTION CODE

PART 1 INSTALLATION

NATIONAL BOARD INSPECTION CODE
2017 EDITION
DATE OF ISSUE — JULY 1, 2017

This code was developed under procedures accredited as meeting the criteria for American National Standards. The Consensus Committee that approved the code was balanced to ensure that individuals from competent and concerned interests had an opportunity to participate. The proposed code was made available for public review and comment, which provided an opportunity for additional public input from industry, academia, regulatory and jurisdictional agencies, and the public-at-large.


The National Board does not “approve,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

The National Board does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure a work utilizing a standard against liability for infringement of any applicable Letters Patent, nor assume any such liability. Users of a code are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code.

The National Board accepts responsibility for only those interpretations issued in accordance with governing National Board procedures and policies that preclude the issuance of interpretations by individual committee members.

The footnotes in this document are part of this American National Standard.



The above National Board symbols are registered with the US Patent Office.

“National Board” is the abbreviation for The National Board of Boiler and Pressure Vessel Inspectors.

No part of this document may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

All charts, graphs, tables, and other criteria that have been reprinted from the *ASME Boiler and Pressure Vessel Code*, Sections I, IV, VIII, and X are used with the permission of the American Society of Mechanical Engineers. All Rights Reserved.

Library of Congress Catalog Card No. 52-44738
 Printed in the United States of America
 All Rights Reserved

www.nationalboard.org

Copyright © 2017 by
 THE NATIONAL BOARD OF BOILER & PRESSURE VESSEL INSPECTORS
 All rights reserved
 Printed in U.S.A.

PART 1 — INSTALLATION

TABLE OF CONTENTS

Introduction		VIII
Foreword		XII
Personnel		XIV
Section 1	General Guidelines	1
1.1	Scope	1
1.2	Purpose	1
1.3	Application of these Rules	1
1.4	Certification, Inspection, and Jurisdictional Requirements	1
1.4.1	Responsibility	1
1.4.2	Equipment Certification	2
1.4.3	Jurisdictional Review	2
1.4.4	Inspection	2
1.4.5	Boiler Installation Report	2
1.4.5.1	Boiler Installation Report Form	3
1.4.5.1.1	Guide for Completing National Board Boiler Installation Report	3
1.5	Change of Service	6
1.6	General Requirements	6
1.6.1	Supports, Foundations, and Settings	6
1.6.2	Structural Steel	6
1.6.3	Exit	6
1.6.4	Ladders and Runways	6
1.6.5	Fuel	7
1.6.6	Ventilation and Combustion Air	7
1.6.7	Lighting	8
1.6.8	Chimney or Stack	8
1.6.9	Final Acceptance	8
Section 2	Power Boilers	9
2.1	Scope	9
2.2	Definitions	9
2.3	General Requirements	9
2.3.1	Supports, Foundations, and Settings	9
2.3.2	Structural Steel	9
2.3.3	Clearances	9
2.4	Equipment Room Requirements	9
2.4.1	Exit	9
2.4.2	Ladders and Runways	10
2.4.3	Drains	10
2.4.4	Water (Cleaning)	10
2.5	Source Requirements	10
2.5.1	Fedwater	10
2.5.1.1	Volume	10
2.5.1.2	Connection	10
2.5.1.3	Pumps	11
2.5.1.4	Valves	11
2.5.2	Fuel	12
2.5.3	Electrical	12
2.5.3.1	Wiring	12
2.5.3.2	Remote Emergency Shutdown Switches	12
2.5.3.3	Controls and Heat-Generating Apparatus	12
2.5.4	Ventilation and Combustion Air	13
2.5.5	Lighting	13
2.5.6	Emergency Valves and Controls	13
2.6	Discharge Requirements	13

2.6.1	Chimney or Stack	13
2.6.2	Ash Removal	13
2.6.3	Drains	13
2.6.3.1	Connection	13
2.6.3.2	Pressure Rating	13
2.6.3.3	Parts	13
2.7	Operating Systems	14
2.7.1	Breeching and Dampers	14
2.7.2	Burners and Stokers	14
2.7.3	Steam Supply	14
2.7.4	Condensate and Return	15
2.7.5	Blowoff	15
2.8	Controls and Gages	16
2.8.1	Water	16
2.8.2	Pressure Gage	17
2.8.2.1	Connection	17
2.8.3	Temperature	18
2.8.4	Pressure Control	18
2.8.5	Automatic Low-Water Fuel Cutoff and/or Water Feeding Device for Steam or Vapor System Boilers	18
2.9	Pressure Relief Valves	19
2.9.1	Valve Requirements — General	19
2.9.1.1	Number	19
2.9.1.2	Location	19
2.9.1.3	Capacity	19
2.9.1.4	Set Pressure	21
2.9.2	Forced-Flow Steam Generator	22
2.9.3	Superheaters	22
2.9.4	Economizers	23
2.9.5	Pressure-Reducing Valves	23
2.9.6	Installation and Discharge Requirements	23
2.10	Testing and Acceptance	24
2.10.1	General	24
2.10.2	Pressure Test	25
2.10.3	Nondestructive Examination	25
2.10.4	System Testing	25
2.10.5	Final Acceptance	25
2.10.6	Boiler Installation Report	25
2.11	Tables and Figures	25
Section 3	Steam Heating Boilers, Hot-Water Heating Boilers, Hot-Water Supply Boilers, and Potable Water Heaters	26
3.1	Scope	26
3.2	Definitions	26
3.3	General Requirements	26
3.3.1	Support	26
3.3.1.1	Methods of Support for Steam Heating, Hot-Water Heating, and Hot-Water Supply Boilers	26
3.3.2	Settings	28
3.3.3	Structural Steel	28
3.3.4	Clearances	28
3.4	Equipment Room Requirements	28
3.4.1	Exit	28
3.4.2	Ladders and Runways	28
3.5	Source Requirements	29
3.5.1	Water	29
3.5.2	Fuel	29
3.5.3	Electrical	29
3.5.3.1	Steam Heating, Hot Water Heating, and Hot Water Supply Boilers	29

3.5.3.2	Potable Water Heaters	29
3.5.3.3	Controls and Heat Generating Apparatus	30
3.5.4	Ventilation and Combustion Air	30
3.5.5	Lighting	30
3.5.6	Emergency Valves and Controls	30
3.6	Discharge Requirements	30
3.6.1	Chimney or Stack	30
3.6.2	Ash Removal	30
3.6.3	Drains	31
3.7	Operating Systems	31
3.7.1	Oil Heaters	31
3.7.2	Breeching and Dampers	31
3.7.3	Burners and Stokers	31
3.7.4	Feedwater, Makeup Water, and Water Supply	31
3.7.5	Stop Valves	32
3.7.5.1	Steam Heating, Hot-Water Heating, and Hot-Water Supply Boilers	32
3.7.5.2	Potable Water Heaters	36
3.7.6	Return Pipe Connections	37
3.7.7	Bottom Blowoff and Drain Valves	37
3.7.7.1	Steam Heating, Hot-Water Heating, and Hot-Water Supply Boilers	37
3.7.7.2	Potable Water Heaters	38
3.7.8	Modular Steam Heating and Hot-Water Heating Boilers	39
3.7.8.1	Individual Modules	39
3.7.8.2	Assembled Modular Boilers	39
3.7.9	Provisions for Thermal Expansion	39
3.7.9.1	Expansion Tanks and Piping for Steam Heating, Hot-Water Heating, Hot-Water Supply Boilers	39
3.7.9.2	Expansion Tanks and Piping For Potable Water Heaters	42
3.8	Instruments, Fittings, and Controls	43
3.8.1	Steam Heating Boilers	43
3.8.1.1	Steam Gages	43
3.8.1.2	Water-Gage Glasses	43
3.8.1.3	Water Column and Water Level Control Pipes	44
3.8.1.4	Pressure Control	44
3.8.1.5	Automatic Low-Water Fuel Cutoff and/or Water Feeding Device	44
3.8.1.6	Modular Steam Heating Boilers	45
3.8.1.7	Instruments, Fittings, and Controls Mounted Inside Boiler Jackets	45
3.8.2	Hot-Water Heating or Hot-Water Supply Boilers	45
3.8.2.1	Pressure or Altitude Gage	45
3.8.2.2	Thermometers	45
3.8.2.3	Temperature Controls	46
3.8.2.4	Low-Water Fuel Cutoff	46
3.8.2.5	Modular Hot-Water Heating Boilers	46
3.8.2.6	Instruments, Fittings, and Controls Mounted Inside Boiler Jackets	47
3.8.3	Potable Water Heaters	47
3.8.3.1	Temperature Controls	47
3.8.3.2	Thermometer	47
3.9	Pressure Relief Valves	47
3.9.1	Pressure Relief Valve Requirements — General	47
3.9.1.1	Installation of Pressure Relief Valves for Steam Heating, Hot-Water Heating, and Hot-Water Supply Boilers	47
3.9.1.1.1	Permissible Mounting	47
3.9.1.1.2	Requirements for Common Connections for Two or More Valves	48
3.9.1.2	Threaded Connections	48
3.9.1.3	Prohibited Installations	48
3.9.1.4	Use of Shutoff Valves Prohibited	48
3.9.1.5	Pressure Relief Valve Discharge Piping	48
3.9.1.6	Temperature and Pressure Relief Valves	48
3.9.2	Pressure Relief Valve Requirements for Steam Heating Boilers	49

3.9.3	Pressure Relief Valve Requirements for Hot-Water Heating or Hot-Water Supply Boilers	49
3.9.4	Pressure Relief Valve Requirements for Potable Water Heaters	50
3.9.4.1	Installation	51
3.9.4.2	Permissible Installations	51
3.9.4.3	Requirements for Common Connection for Two or More Valves	51
3.9.4.4	Threaded Connections	51
3.9.4.5	Prohibited Installations	51
3.9.4.6	Use of Shutoff Valves Prohibited	51
3.9.4.7	Temperature and Pressure Relief Valve Discharge Piping	51
3.9.5	Pressure Relief Valves for Tanks and Heat Exchangers	52
3.9.5.1	Steam to Hot-Water Supply	52
3.9.5.2	High-Temperature Water to Water Heat Exchanger	52
3.9.5.3	High-Temperature Water to Steam Heat Exchanger	52
3.10	Testing and Acceptance	52
3.10.1	Pressure Test	52
3.10.2	Final Acceptance	52
3.10.3	Boiler Installation Report	52
3.11	Tables and Figures	53
Section 4	Pressure Vessels	54
4.1	Scope	54
4.2	Definitions	54
4.3	General Requirements	54
4.3.1	Supports	54
4.3.2	Clearances	54
4.3.3	Piping	54
4.3.4	Bolting	54
4.4	Instruments and Controls	54
4.4.1	Level Indicating Devices	54
4.4.2	Pressure Indicating Devices	55
4.5	Pressure Relief Devices	55
4.5.1	Device Requirements	55
4.5.2	Number of Devices	55
4.5.3	Location	55
4.5.4	Capacity	55
4.5.5	Set Pressure	56
4.5.6	Installation and Discharge Piping Requirements	56
4.6	Testing and Acceptance	57
4.7	Requirements for Hot Water Storage Tanks	58
4.7.1	Supports	58
4.7.2	Clearance and Accessibility	58
4.7.3	Temperature and Pressure Relief Devices	58
4.7.4	Thermometers	58
4.7.5	Shut Off Valves	58
4.7.6	Testing and Acceptance	58
Section 5	Piping	59
5.1	Scope	59
5.2	General Requirements	59
5.2.1	Additions to Existing Piping	59
5.2.2	Proximity to Other Equipment and Structures	59
5.2.3	Flanges and Other Non-Welded Joints	59
5.2.4	Valves	59
5.2.5	Materials	59
5.2.6	Hangers and Supports	60
5.2.7	Protection and Cleaning	60
5.2.8	Welding and Brazing	60
5.2.9	Bolting	60
5.3	Pressure Relief Devices	60

5.3.1	Device Requirements	60
5.3.2	Number of Devices	61
5.3.3	Location	61
5.3.4	Capacity	61
5.3.5	Set Pressure	61
5.3.6	Inlet and Discharge Piping Requirements	61
5.4	Examination, Inspection, and Testing	62
Section 6	Supplements	63
Supplement 1	Installation of Yankee Dryers (Rotating Cast-Iron Pressure Vessels) with Finished Shell Outer Surfaces	63
S1.1	Scope	63
S1.2	Assessment of Installation.....	64
S1.3	Determination of Allowable Operating Parameters	66
S1.4	ASME Code Primary Membrane Stress Criteria	67
S1.5	Pressure Testing.....	67
S1.6	Nondestructive Examination.....	68
Supplement 2	Pressure Relief Valves on the Low-Pressure Side of Steam Pressure Reducing Valves	69
S2.1	Scope	69
S2.2	Pressure Relief Valve Capacity	69
S2.3	Calculation of Pressure Relief Valve Relieving Capacity	69
S2.4	Steam Flow When Flow Coefficients Are Not Known	77
S2.5	Two-Stage Pressure Reducing Valve Stations	77
Supplement 3	Installation of Liquid Carbon Dioxide Storage Vessels	79
S3.1	Scope	79
S3.2	General Requirements Storage Tank Location	79
S3.2.1	General Requirements (Enclosed and Unenclosed Areas)	79
S3.2.2	Unenclosed Area LCDSV Installations	80
S3.2.3	Enclosed Area LCDSV Installations	80
S3.3	Fillbox Location/Safety Relief/Vent Line Circuit Termination	80
S3.4	Gas Detection Systems	81
S3.5	Signage	81
S3.6	Valves, Piping, Tubing, and Fittings	81
S3.6.1	System Description	84
Supplement 4	Installation of Biomass (Wood/Solid Fuel) Fired Boilers	87
S4.1	Scope	87
S4.2	Purpose	87
S4.3	Determination of Allowable Operating Parameters	87
S4.4	General Requirements	88
S4.5	Fuel System Requirements and Controls.....	88
S4.6	Combustion Requirements.....	89
Supplement 5	Installation of Thermal Fluid Heaters	91
S5.1	Scope	91
S5.2	Definitions.....	91
S5.3	General Requirements	91
S5.3.1	Supports, Foundations, and Settings	91
S5.3.2	Structural Steel	91
S5.3.3	Settings	91
S5.3.4	Clearances	91
S5.4	Thermal Fluid Heater Room Requirements.....	92
S5.4.1	Exit	92
S5.4.2	Ladders and Runways.....	92
S5.5	System Requirements.....	92

S5.5.1	Thermal Liquids (Heat Transfer Fluids).....	92
S5.5.2	Expansion	92
S5.5.3	Connection	93
S5.5.4	Circulating Pump	93
S5.5.5	Piping and Valves	93
S5.5.6	Fuel	94
S5.5.7	Electrical	94
S5.5.8	Ventilation and Combustion Air	96
S5.5.9	Lighting	96
S5.5.10	Emergency Valves and Controls	96
S5.6	Discharge Requirements	96
S5.6.1	Chimney or Stack	96
S5.6.2	Drains	96
S5.6.3	Air Vent	96
S5.7	Overpressure Protection	96
S5.7.1	General Requirements	96
S5.7.2	Pressure Relief Devices	96
S5.7.3	Location	97
S5.7.4	Capacity	97
S5.7.5	Set Pressure	97
S5.7.6	Installation	97
S5.8	Testing and Acceptance	98
S5.8.1	General	98
S5.8.2	Pressure Test	98
S5.8.3	Nondestructive Examination	98
S5.8.4	System Testing	98
S5.8.5	Final Acceptance	98
S5.8.6	Installation Report	98
Supplement 6 Special Requirements for the Installation of Condensing Boilers		
S6.1	Scope	99
S6.2	Determination of Allowable Operating Parameters	99
S6.3	General Requirements	99
S6.4	Flue Gas Venting System Piping Requirements	99
S6.5	Sealed Combustion System Requirements.....	99
S6.6	Condensate Drain System Requirements.....	100
Section 7 NBIC Policy for Metrication 101		
7.1	General	101
7.2	Equivalent Ratios	101
7.3	Procedure for Conversion	101
7.4	Referencing Tables	102
Section 8 Preparation of Technical Inquiries to the National Board Inspection Code Committee 107		
8.1	Introduction	107
8.2	Inquiry Format	107
8.3	Code Revisions or Additions	108
8.4	Code Interpretations	108
8.5	Submittals	109
Section 9 Glossary of Terms 110		
9.1	Definitions	110
Section 10 NBIC Approved Interpretations 117		
10.1	Scope	117
Section 11 Index 126		

INTRODUCTION

It is the purpose of the National Board Inspection Code (NBIC) to maintain the integrity of pressure-retaining items by providing rules for post-construction activities including installation, and after the items have been placed into service, by providing rules for inspection and repair and alteration, thereby ensuring that these items may continue to be safely used.

The NBIC is intended to provide rules, information, and guidance to manufacturers, Jurisdictions, inspectors, owner-users, installers, contractors, and other individuals and organizations performing or involved in post-construction activities, thereby encouraging the uniform administration of rules pertaining to pressure retaining items.

SCOPE

The NBIC recognizes three important areas of post-construction activities where information, understanding, and following specific requirements will promote public and personal safety. These areas include:

- Installation
- Inspection
- Repairs and Alterations

The NBIC provides rules, information, and guidance for post-construction activities but does not provide details for all conditions involving pressure-retaining items. Where complete details are not provided in this code, the code user is advised to seek guidance from the Jurisdiction and from other technical sources.

The words shall, should, and may are used throughout the NBIC and have the following intent:

- Shall – action that is mandatory and required.
- Should – indicates a preferred but not mandatory means to accomplish the requirement unless specified by others such as the Jurisdiction.
- May – permissive, not required or a means to accomplish the specified task.

ORGANIZATION

The NBIC is organized into four parts to coincide with specific post-construction activities involving pressure-retaining items. Each part provides general and specific rules, information, and guidance within each applicable post-construction activity. Other NBIC parts or other published standards may contain additional information or requirements needed to meet the rules of the NBIC. Specific references are provided in each part to direct the user where to find this additional information. NBIC parts are identified as:

- Part 1, Installation – This part provides requirements and guidance to ensure all types of pressure retaining items are installed and function properly. Installation includes meeting specific safety criteria for construction, materials, design, supports, safety devices, operation, testing, and maintenance.
- Part 2, Inspection – This part provides information and guidance needed to perform and document inspections for all types of pressure-retaining items. This part includes information on personnel safety, non-destructive examination, tests, failure mechanisms, types of pressure equipment, fitness for service, risk-based assessments, and performance-based standards.
- Part 3, Repairs and Alterations – This part provides requirements and guidance to perform, verify, and document acceptable repairs or alterations to pressure retaining items regardless of code of construction. Alternative methods for examination, testing, heat treatment, etc., are provided when the original code of construction requirements cannot be met. Specific acceptable and proven repair methods are also provided.
- Part 4, Pressure Relief Devices – This part provides information and guidance to ensure pressure relief devices are installed properly, information and guidance needed to perform and document inspections for pressure relief devices, and information and guidance to perform, verify, and document acceptable repairs to pressure relief devices.

Each NBIC part is divided into major sections as outlined in the Table of Contents.

Tables, charts, and figures provide relevant illustrations or supporting information for text passages, and are designated with numbers corresponding to the paragraph they illustrate or support within each section. Multiple tables, charts, or figures referenced by the same paragraph will have additional letters reflecting the order of reference. Tables, charts, and figures are located in or after each major section within each NBIC part.

TEXT IDENTIFICATION AND NUMBERING

Each page in the text will be designated in the top header with the publication's name, part number, and part title. The numbering sequence for each section begins with the section number followed by a dot to further designate major sections (e.g., 1.1, 1.2, 1.3). Major sections are further subdivided using dots to designate subsections within that major section (e.g., 1.1.1, 1.2.1, 1.3.1). Subsections can further be divided as necessary. Paragraphs under sections or subsections shall be designated with small letters in parenthesis (e.g., a), b), c)) and further subdivided using numbers in parenthesis (e.g., 1), 2), 3)).

Subdivisions of paragraphs beyond this point will be designated using a hierarchical sequence of letters and numbers followed by a dot.

Example: 2.1 Major Section
 2.1.1 Section
 2.1.2 Section
 2.1.2. Subsection
 a) paragraph
 b) paragraph
 1) subparagraph
 2) subparagraph
 a. subdivisions
 1. subdivisions
 2. subdivisions
 b. subdivisions
 1. subdivisions
 2. subdivisions

Tables and figures will be designated with the referencing section or subsection identification. When more than one table or figure is referenced in the same section or subsection, letters or numbers in sequential order will be used following each section or subsection identification.

SUPPLEMENTS

Supplements are contained in each part of the NBIC to provide requirements and guidance only pertaining to a specific type of pressure retaining item (e.g., Locomotive Boilers, Historical Boilers, Graphite Pressure Vessels.) Supplements follow the same numbering system used for the main text only preceded by the Letter "S." Each page of the supplement will be tabbed to identify the supplement number.

EDITIONS

Editions, which include revisions and additions to this code, are published every two years. Editions are permissive on the date issued and become mandatory six months after the date of issue.

CODE STAMPING

ASME Code "Stamping" referenced throughout the NBIC includes the ASME Boiler and Pressure Vessel Code Symbol Stamps used for conformity assessment prior to the 2010 edition/2011 addendum and the equivalent ASME Certification Mark with Designator required to meet the later editions of the ASME Boiler and Pressure Vessel Code Sections. When other construction codes or standards are utilized for repairs or alterations, stamping shall mean the identification symbol stamp required by that code or standard.

INTERPRETATIONS

On request, the NBIC Committee will render an interpretation of any requirement of this code. Interpretations are provided for each part and are specific to the code edition and addenda referenced in the interpretation. Interpretations provide clarification of existing rules in the code only and are not part of this code.

JURISDICTIONAL PRECEDENCE

Reference is made throughout this code to the requirements of the “Jurisdiction.” Where any provision herein presents a direct or implied conflict with any jurisdictional regulation, the Jurisdictional regulation shall govern.

UNITS OF MEASUREMENT

Both U.S. customary units and metric units are used in the NBIC. The value stated in U.S. customary units or metric units are to be regarded separately as the standard. Within the text, the metric units are shown in parentheses. In Part 2, Supplement 6 and Part 3, Supplement 6 regarding DOT Transport Tanks, the metric units are shown first with the U.S. customary units shown in parentheses.

U.S. customary units or metric units may be used with this edition of the NBIC, but one system of units shall be used consistently throughout a repair or alteration of pressure-retaining items. It is the responsibility of National Board accredited repair organizations to ensure the appropriate units are used consistently throughout all phases of work. This includes materials, design, procedures, testing, documentation, and stamping. The NBIC policy for metrication is outlined in each part of the NBIC.

ACCREDITATION PROGRAMS

The National Board administers and four specific accreditation programs, as shown below:

- “R”.....Repairs and Alterations to Pressure-Retaining Items (NB-415)
- “VR”.....Repairs to Pressure Relief Valves (NB-514)
- “NR”.....Repair and Replacement Activities for Nuclear Items (NB-417)
- “T/O”.....Testing of Pressure Relief Valves (NB-528)

The administrative requirements for the accreditation for these accreditation programs can be viewed on the National Board Website at www.nationalboard.org.

The National Board also administers and accredits four specific inspection agency programs as shown below:

New Construction

Criteria for Acceptance of Authorized Inspection Agencies for New Construction (NB-360)

Inservice

Qualifications and Duties for Authorized Inspection Agencies (AIAs) Performing Inservice Inspection Activities and Qualifications for Inspectors of Boilers and Pressure Vessels (NB-369)

Owner-User

Accreditation of Owner-User Inspection Organizations (OUIO) (NB-371)

Owners or users may be accredited for both a repair and inspection program provided the requirements for each accreditation program are met.

Federal Government

Qualifications and Duties for Federal Inspection Agencies Performing Inservice Inspection Activities (FIAs) (NB-390)

These programs can be viewed on the National Board Website at www.nationalboard.org. For questions or further information regarding these programs contact the National Board by phone at (614) 888-8320 or by fax at (614) 847-1828.

CERTIFICATES OF AUTHORIZATION FOR ACCREDITATION PROGRAMS

Any organization seeking an accredited program may apply to the National Board to obtain a Certificate of Authorization for the requested scope of activities. A confidential review shall be conducted to evaluate the organization's quality system. Upon completion of the evaluation, a recommendation will be made to the National Board regarding issuance of a Certificate of Authorization.

Certificate of Authorization scope, issuance, and revisions for National Board accreditation programs are specified in the applicable National Board procedures. When the quality system requirements of the appropriate accreditation program have been met, a Certificate of Authorization and appropriate National Board symbol stamp shall be issued.

FOREWORD

The National Board of Boiler and Pressure Vessel Inspectors is an organization comprised of Chief Inspectors for the states, cities, and territories of the United States and provinces and territories of Canada. It is organized for the purpose of promoting greater safety to life and property by securing concerted action and maintaining uniformity in post-construction activities of pressure-retaining items, thereby ensuring acceptance and interchangeability among Jurisdictional authorities responsible for the administration and enforcement of various codes and standards.

In keeping with the principles of promoting safety and maintaining uniformity, the National Board originally published the NBIC in 1946, establishing rules for inspection and repairs to boilers and pressure vessels. The *National Board Inspection Code* (NBIC) Committee is charged with the responsibility for maintaining and revising the NBIC. In the interest of public safety, the NBIC Committee decided, in 1995, to revise the scope of the NBIC to include rules for installation, inspection, and repair or alteration to boilers, pressure vessels, piping, and nonmetallic materials.

In 2007, the NBIC was restructured into three parts specifically identifying important post-construction activities involving safety of pressure-retaining items. This restructuring provides for future expansion, transparency, uniformity, and ultimately improving public safety.

In 2017, the NBIC was once again restructured into 4 parts, adding a new Part 4, Pressure Relief Devices. This purpose of this restructuring was to provide one distinct integrated part for pressure relief devices compiled from all PRD information referenced in Part 1, Installation; Part 2, Inspection; and Part 3, Repairs and Alterations.

The NBIC Committee's function is to establish rules of safety governing post-construction activities for the installation, inspection, and repair and alteration of pressure-retaining items, and to interpret these rules when questions arise regarding their intent. In formulating the rules, the NBIC Committee considers the needs and concerns of individuals and organizations involved in the safety of pressure-retaining items. The objective of the rules is to afford reasonably certain protection of life and property, so as to give a reasonably long, safe period of usefulness. Advancements in design and material and the evidence of experience are recognized.

The rules established by the NBIC Committee are not to be interpreted as approving, recommending, or endorsing any proprietary or specific design, or as limiting in any way an organization's freedom to choose any method that conforms to the NBIC rules.

The NBIC Committee meets regularly to consider revisions of existing rules, formulation of new rules, and respond to requests for interpretations. Requests for interpretation must be addressed to the NBIC Secretary in writing and must give full particulars in order to receive Committee consideration and a written reply. Proposed revisions to the code resulting from inquiries will be presented to the NBIC Committee for appropriate action.

Proposed revisions to the code approved by the NBIC Committee are submitted to the American National Standards Institute and published on the National Board web-site to invite comments from all interested persons. After the allotted time for public review and final approval, the new edition is published. The Foreword, Introduction, Personnel and Index Sections of the NBIC are provided for guidance and informational purposes only and shall not be considered a part of the Code. These sections are not approved by the NBIC Committee or submitted to the American National Standards Institute.

Organizations or users of pressure-retaining items are cautioned against making use of revisions that are less restrictive than former requirements without having assurance that they have been accepted by the Jurisdiction where the pressure-retaining item is installed.

The general philosophy underlying the NBIC is to parallel those provisions of the original code of construction, as they can be applied to post-construction activities. The NBIC does not contain rules to cover all details of post-construction activities. Where complete details are not given, it is intended that individuals or organizations, subject to the acceptance of the Inspector and Jurisdiction when applicable, provide details

for post-construction activities that will be as safe as otherwise provided by the rules in the original code of construction.

Activities not conforming to the rules of the original code of construction or the NBIC must receive specific approval from the Jurisdiction, who may establish requirements for design, construction, inspection, testing, and documentation.

There are instances where the NBIC serves to warn against pitfalls; but the code is not a handbook, and cannot substitute for education, experience, and sound engineering judgment. It is intended that this edition of the NBIC not be retroactive. Unless the Jurisdiction imposes the use of an earlier edition, the latest effective edition is the governing document.

PERSONNEL

The National Board of Boiler and Pressure Vessel Inspectors

Board of Trustees

J. Burpee
Chairman

J. Amato
First Vice Chairman

D. Cook
Second Vice Chairman

C. Cantrell
Member at Large

E. Creaser
Member at Large

A. Oda
Member at Large

M. Washington
Member at Large

D. Douin
Secretary/Treasurer

Advisory Committee

J. Pillow
Representing welding industries

C. Hopkins
Representing National Board stamp holders

H. Richards
Representing boiler and pressure vessel users

B. Berquist
Representing pressure vessel manufacturers

R. Wielgoszinski
Representing authorized inspection agencies
(insurance companies)

P. Molvie
Representing boiler manufacturers

National Board Members

Alabama	Marvin Byrum
Alaska	Kenneth Lane
Arizona	Randall Austin
Arkansas	Dennis Hannon
California	Donald Cook
Colorado	Steve Nelson
Delaware	John Esch
Florida	Andrew Frazier
Georgia	Benjamin Crawford
Hawaii	Julius Dacanay
Illinois	Michael Vogel
Indiana	Larry Parkey
Kansas	Robert Stimson
Kentucky	Mark Jordan
Louisiana	Joseph LeSage
Maine	John Burpee
Maryland	Karl Kraft
Massachusetts	Edward Kawa
Michigan	David Stenrose
Minnesota	Joel Amato
Mississippi	William Anderson
Missouri	Ronald Brockman
Nebraska	Christopher B. Cantrell
Nevada	David Sandfoss
New Hampshire	Darrell Mallory
New Jersey	Milton Washington
New York	Matthew Sansone
North Carolina	Clifford Dautrich
North Dakota	Trevor Seime
Ohio	John Sharier
Oklahoma	Thomas Granneman
Oregon	Mark Perdue
Pennsylvania	Nathaniel Smith
South Carolina	Ronald W. Spiker
South Dakota	Aaron Lorimor
Tennessee	Sam Chapman
Texas	Rob Troutt
Utah	Rick Sturm
Virginia	Edward Hilton
Washington	Tony Oda
West Virginia	John Porcella
Wisconsin	Terrence Waldbillig
Chicago, IL	Michael Ryan
Detroit, MI	Cortney Jackson
Los Angeles, CA	Cirilo Reyes
Milwaukee, WI	Jillian Klug
New York, NY	William McGivney
Seattle, WA	Larry Leet
Alberta	Michael Pohlmann
British Columbia	Anthony Scholl
Manitoba	Ryan DeLury
New Brunswick	Eben Creaser
Newfoundland & Labrador	Dennis Eastman
Northwest Territories	Matthias Mailman
Nova Scotia	Peter Dodge
Ontario	Michael Adams
Prince Edward Island	Steven Townsend
Quebec	Aziz Khssassi
Saskatchewan	Christopher Selinger

National Board Inspection Code Main Committee

D. Cook, Chair
State of California

R. Wielgoszinski, Vice Chair
*Hartford Steam Boiler Inspection and
Insurance Company*

B. Besserman, Secretary
National Board

J. Amato
State of Minnesota

R. Austin
State of Arizona

S. Cammeresi
Furmanite

P. Edwards
WECTEC

G. Galanes
Diamond Technical Services, Inc.

J. Getter
Worthington Industries

C. Hopkins
Seattle Boiler Works, Inc.

L. McManoman
Great Lakes Area Apprenticeship Program

M. Mooney
Liberty Mutual Insurance Company

B. Morelock
Eastman Chemical Company

V. Newton
XL Insurance

J. Pillow
Common Arc

M. Richards
Consultant

J. Riley
Phillips 66

J. Sekely
Consultant

K. Simmons
Pentair

S. Staniszewski Jr.
U.S. Department of Transportation

R. Troutt
State of Texas

M. Wadkinson
Fulton Boiler Works, Inc.

M. Webb
Xcel Energy Services

P. Welch
Arise Boiler Inspection and Insurance Company

**National Board Inspection Code
Subcommittee Installation (Part 1)**

H. Richards, Chair
Consultant

D. Patten, Vice Chair
Bay City Boiler

J. Bock, Secretary
National Board

R. Austin
State of Arizona

G. Halley
ABMA

S. Konopacki
NRG

B. Moore
*Hartford Steam Boiler Inspection and
Insurance Company*

P. Schuelke
Well-McLain

R. Smith
Authorized Inspection Associates

M. Wadkinson
Fulton Boiler Works, Inc.

E. Wiggins
Liberty Mutual Insurance Company

**National Board Inspection Code
Subcommittee Inspection (Part 2)**

M. Mooney, Chair
Liberty Mutual Insurance Company

S. Staniszewski, Vice Chair
US Department of Transportation

J. Metzmaier, Secretary
National Board

T. Barker
FM Global

E. Brantley
XL Insurance

D. Buechel
*Hartford Steam Boiler Inspection and
Insurance Company*

D. Ford
U.S. Department of Transportation

J. Getter
Worthington Cylinders

D. Graf
Air Products and Chemicals, Inc.

M. Horbaczewski
Diamond Technical Services

G. McRae
Trinity Industries, Inc.

V. Newton
XL Insurance

J. Riley
Phillips 66

M. Schwartzwalder
Stress Engineering Services

T. Vandini
Quality Steel Corporation

P. Welch
ARISE

**National Board Inspection Code
Subcommittee for Repairs and Alterations
(Part 3)**

G. Galanes, Chair
Diamond Technical Services, Inc.

J. Pillow, Vice Chair
Common Arc Corporation

W. Vallance, Secretary
National Board

J. Amato
State of Minnesota

B. Boseo
Graycor Services LLC

A. Bramucci
GE Renewable Energy

P. Edwards
WECTEC

C. Hopkins
Seattle Boiler Works, Inc.

W. Jones
Arise, Inc.

L. McManoman
Great Lakes Area Apprenticeship Program

R. Miletti
Babcock and Wilcox Construction Company, Inc.

L. Moedinger
Strasburg Railroad Company

K. Moore
Joe Moore Company

B. Morelock
Eastman Chemical Company

B. Schaefer
AEP

J. Sekely
Consultant

M. Toth
Boiler Supply Company, Inc.

R. Troutt
State of Texas

M. Webb
Xcel Energy

**National Board Inspection Code
Subcommittee Pressure Relief Devices
(Part 4)**

S. Cammeresi, Chair
Furmanite

A. Cox, Vice Chair
JAC Consulting

T. Beirne, Secretary
National Board

K. Beise
Dowco Valve Company, Inc.

M. Brodeur
International Valve & Instr. Corp.

D. DeMichael
Chemours Co.

R. Donalson
Pentair

B. Hart
FM Global

D. Marek
Mainthia Technologies

R. McCaffrey
Quality Valve

D. McHugh
Allied Valve, Inc.

B. Nutter
E.I. Dupont De Nemours & Co.

T. Patel
Farris Engineering

A. Renaldo
Praxair, Inc.

K. Simmons
Pentair

National Board Inspection Code Subgroup Installation (Part 1)

M. Wadkinson, Chair
Fulton Boiler Works, Inc.

D. Patten, Vice Chair
Bay City Boiler

J. Bock, Secretary
National Board

R. Austin
State of Arizona

T. Creacy
Zurich Services Corporation

G. Halley
ABMA

S. Konopacki
NRG Energy

J. Millette
UAB

B. Moore
*Hartford Steam Boiler Inspection and
Insurance Company*

H. Richards
Consultant

P. Schuelke
Well-McLain

R. Smith
Authorized Inspection Associates

M. Washington
State of New Jersey

E. Wiggins
Liberty Mutual Insurance Company

National Board Inspection Code Subgroup Inspection (Part 2)

J. Getter, Chair
Worthington Industries

M. Schwartzwalder, Vice Chair
AEP

J. Metzmaier, Secretary
National Board

T. Barker
FM Global

E. Brantley
XL Insurance America, Inc.

D. Ford
US Department of Transportation

D. Graf
Air Products and Chemicals, Inc.

B. Hart
Factory Mutual Insurance Company

M. Horbaczewski
Midwest Generation

G. McRae
Trinity Industries, Inc.

M. Mooney
Liberty Mutual Insurance

V. Newton
XL Insurance America

J. Riley
Phillips 66

S. Staniszewski
US Department of Transportation

T. Vandini
Quality Steel Corporation

P. Welch
Arise, Inc.

National Board Inspection Code Subgroup for Repairs and Alterations (Part 3)

A. Bramucci, Chair
GE Renewable Energy

W. Vallance, Secretary
National Board

J. Amato
State of Minnesota

B. Boseo
Graycor Services LLC

N. Carter
*Hartford Steam Boiler Inspection and
Insurance Company*

R. Cauthon
Alstom Power

P. Edwards
WECTEC

G. Galanes
Diamond Technical Services, Inc.

C. Hopkins
Seattle Boiler Works, Inc.

F. Johnson
PBF Energy

W. Jones
Arise, Inc.

D. Martinez
FM Global

L. McManoman
Great Lakes Area Apprenticeship Program

R. Miletti
Babcock and Wilcox Construction Company, Inc.

K. Moore
Joe Moore Company

B. Morelock
Eastman Chemical

J. Pillow
Common Arc Corporation

B. Schaefer
AEP

J. Sekely
Consultant

W. Sperko
Sperko Engineering Services

M. Toth
Boiler Supply Company, Inc.

R. Troutt
State of Texas

R. Valdez
ARB, Inc.

J. Walker
Hayes Mechanical

M. Webb
Xcel Energy

T. White
NRG Energy

National Board Inspection Code Subgroup Graphite

E. Soltow, Chair
SGL Carbon Technic

B. Besserman, Secretary
National Board

G. Becherer
CG Thermal

F. Brown
Consultant

C. Cary
Dow Corning

J. Clemens
Graphite Maintenance

K. Cummins
Louisville Graphite

B. Dickerson
Mersen

B. Jones
Mersen

R. Selvaraj
Mersen

D. Sholar
Mersen

A. Stupica
SGL Carbon Technic

A. Viet
CG Thermal

National Board Inspection Code Subgroup Fiber-Reinforced Pressure Vessels

B. Shelley, Chair
Chemours

B. Besserman, Secretary
National Board

F. Brown
Consultant

J. Bustillos
Bustillos and Associates

T. Cowley
FRP Consulting

D. Eisberg
Avista Technologies

M. Gorman
Digital Wave

D. Hodgkinson
Consultant

D. Keeler
The Dow Chemical Company

D. McCauley
Chemours

N. Newhouse
Hexagon Lincoln

A. Pollock
Mistras Group

J. Richter
Thorpe Plant Services

N. Sirosh
LightSail Energy

National Board Inspection Code Subgroup Locomotive Boilers

L. Moedinger, Chair
Strasburg Railroad

M. Janssen, Vice Chair
Vapor Locomotive Company

B. Ferrel, Secretary
National Board

S. Butler
Midwest Locomotive & Machine Works

D. Conrad
Valley Railroad Co.

R. Franzen
Steam Services of America

D. Griner
Arizona Mechanical Engineering

S. Lee
Union Pacific Railroad

D. McCormack
Consultant

G. Ray
Tennessee Valley Authority

R. Stone
ARVOS, Inc.

National Board Inspection Code Subgroup Historical Boiler

J. Amato, Chair
State of Minnesota

T. Dillon, Vice Chair
MSEA

B. Ferrell, Secretary
National Board

J. Getter
Worthington Industries

F. Johnson
PBF Energy

M. Jordan
State of Kentucky

D. Rose
T&T Inspections

D. Rupert
Consultant

R. Underwood
*Hartford Steam Boiler Inspection and
Insurance Company*

M. Wahl
WHSEA

PART 1, SECTION 1

INSTALLATION — GENERAL GUIDELINES

(17) 1.1 SCOPE

This part provides requirements and guidelines for the installation of power boilers, steam heating boilers, hot-water heating boilers, hot-water supply boilers, potable water heaters, pressure vessels and piping.

The proper installation of boilers, pressure vessels, piping, and other pressure-retaining items is essential for safe and satisfactory operation. The owner-user is responsible for ensuring that installations meet all the requirements of the Jurisdiction at the point of installation including licensing, registration, or certification of those performing installations. NBIC Part 1 identifies minimum safety requirements for installing pressure-retaining items when NBIC Part 1 is mandated by a Jurisdiction. Otherwise, the requirements specified in NBIC Part 1 provide information and guidance for installers, contractors, owners, inspectors, and Jurisdictions to ensure safe and satisfactory installation of specified pressure-retaining items. Jurisdictions may require other safety standards, including following manufacturer's recommendations. When a Jurisdiction establishes different requirements or where a conflict exists, the rules of the Jurisdiction prevail. Users of NBIC Part 1 are cautioned that other requirements may apply for a particular installation and NBIC Part 1 is not a substitute for sound engineering evaluations.

1.2 PURPOSE

- a) The purpose of these rules are to establish minimum requirements, which, if followed, will ensure that pressure-retaining items, when installed, may be safely operated, inspected, and maintained.
- b) It should be recognized that many of the requirements included in these rules must be considered in the design of the pressure-retaining item by the manufacturer. However, the owner-user is responsible for ensuring that the installation complies with all the applicable requirements contained herein. Further, the installer is responsible for complying with the applicable sections when performing work on behalf of the owner-user.

1.3 APPLICATION OF THESE RULES

- a) As referenced in lower case letters, the terms "owner," "user," or "owner-user" means any person, firm, or corporation legally responsible for the safe operation of the boiler, pressure vessel, piping, or other pressure-retaining item. Further, where the term "owner" is used, it shall mean the owner, or user, or the owner's or user's designee.
- b) Where the owner is required to perform an activity, it is intended that the owner or the owner's designee may perform the activity; however, the owner retains responsibility for compliance with these rules.
- c) These rules refer to documentation obtained from the Jurisdiction (installation permit, operating permit). It is not intended to require the Jurisdiction to issue such permits but rather a caution to owners and installers that such permits may be required.

1.4 CERTIFICATION, INSPECTION, AND JURISDICTIONAL REQUIREMENTS

1.4.1 RESPONSIBILITY

- a) The owner is responsible for satisfying jurisdictional requirements for certification and documentation. When required by jurisdictional rules applicable to the location of installation, the boilers, pressure vessels, piping, and other pressure-retaining items shall not be operated until the required documentation has been provided by the installer to the owner and the Jurisdiction.



2017 NBIC

NATIONAL BOARD INSPECTION CODE

PART 2 INSPECTION

NATIONAL BOARD INSPECTION CODE
2017 EDITION
DATE OF ISSUE — JULY 1, 2017

This code was developed under procedures accredited as meeting the criteria for American National Standards. The Consensus Committee that approved the code was balanced to ensure that individuals from competent and concerned interests had an opportunity to participate. The proposed code was made available for public review and comment, which provided an opportunity for additional public input from industry, academia, regulatory and jurisdictional agencies, and the public-at-large.


The National Board does not “approve,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

The National Board does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable Letters Patent, nor assume any such liability. Users of a code are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code.

The National Board accepts responsibility for only those interpretations issued in accordance with governing National Board procedures and policies that preclude the issuance of interpretations by individual committee members.

The footnotes in this document are part of this American National Standard.



The above National Board symbols are registered with the US Patent Office.

“National Board” is the abbreviation for The National Board of Boiler and Pressure Vessel Inspectors.

No part of this document may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

All charts, graphs, tables, and other criteria that have been reprinted from the *ASME Boiler and Pressure Vessel Code*, Sections I, IV, VIII, and X are used with the permission of the American Society of Mechanical Engineers. All Rights Reserved.

Library of Congress Catalog Card No. 52-44738
 Printed in the United States of America
 All Rights Reserved

www.nationalboard.org

Copyright © 2017 by
 THE NATIONAL BOARD OF BOILER & PRESSURE VESSEL INSPECTORS
 All rights reserved
 Printed in U.S.A.

PART 2 — INSPECTION TABLE OF CONTENTS

Introduction		XIV
Foreword		XVIII
Personnel		XX
Section 1	General Requirements for Inservice Inspection of Pressure-Retaining Items	1
1.1	Scope	1
1.2	Administration	1
1.3	References to Other Codes and Standards	1
1.4	Personnel Safety	2
1.4.1	Personal Safety Requirements for Entering Confined Spaces	3
1.4.2	Equipment Operation	3
1.5	Inspection Activities	3
1.5.1	Inservice Inspection Activities	4
1.5.2	Pre-Inspection Activities	4
1.5.2.1	Inspection Planning	4
1.5.3	Preparation for Internal Inspection	5
1.5.4	Post-Inspection Activities	6
1.6	Change of Service	6
Section 2	Detailed Requirements for Inservice Inspection of Pressure-Retaining Items	7
2.1	Scope	7
2.2	Boilers	7
2.2.1	Scope	7
2.2.2	Service Conditions	7
2.2.3	Pre-Inspection Activities	7
2.2.4	Condition of Boiler Room or Boiler Location	7
2.2.5	External Inspection	7
2.2.6	Internal Inspection	8
2.2.7	Evidence of Leakage	8
2.2.8	Boiler Corrosion Considerations	8
2.2.9	Waterside Deposits	9
2.2.10	Inspection of Boiler Piping, Parts, and Appurtenances	9
2.2.10.1	Boiler Piping	9
2.2.10.2	Flanged or Other Connections	9
2.2.10.3	Miscellaneous	10
2.2.10.4	Gages	10
2.2.10.5	Pressure Relief Devices	11
2.2.10.6	Controls	11
2.2.11	Records Review	12
2.2.12	Description and Concerns of Specific Types of Boilers	12
2.2.12.1	Cast-Iron Boilers	12
2.2.12.2	Firetube Boilers	13
2.2.12.3	Watertube Boilers	15
2.2.12.4	Electric Boilers	16
2.2.12.5	Fired Coil Water Heaters	16
2.2.12.6	Fired Storage Water Heaters	17
2.2.12.7	Thermal Fluid Heaters	17
2.2.12.8	Waste Heat Boilers	19
2.2.12.9	Kraft or Sulfate Black Liquor Recovery Boilers	20
2.3	Pressure Vessels	22
2.3.1	Scope	22
2.3.2	Service Conditions	22
2.3.3	External Inspection	22
2.3.4	Internal Inspection	23

2.3.5	Inspection of Pressure Vessel Parts and Appurtenances	24
2.3.5.1	Gages	24
2.3.5.2	Safety Devices	25
2.3.5.3	Controls/Devices	25
2.3.5.4	Records Review	25
2.3.6	Description and Concerns of Specific Types of Pressure Vessels	26
2.3.6.1	Deaerators	26
2.3.6.2	Compressed Air Vessels	26
2.3.6.3	Expansion Tanks	27
2.3.6.4	Liquid Ammonia Vessels	27
2.3.6.5	Inspection of Pressure Vessels with Quick-Actuating Closures	31
2.3.6.6	Transport Tanks.....	33
2.3.6.7	Anhydrous Ammonia Nurse Tanks	33
2.3.6.8	Inspection of Pressure Vessels for Human Occupancy (PVHO'S).....	34
2.3.6.9	Inspection of Static Vacuum Insulated Cryogenic Vessels.....	36
2.3.6.10	Inspection of Wire Wound Pressure Vessels	37
2.4	Piping and Piping Systems.....	39
2.4.1	Scope	39
2.4.2	Service Conditions	40
2.4.3	Assessment of Piping Design	40
2.4.4	External Inspection of Piping	40
2.4.5	Internal Inspection of Piping	41
2.4.6	Evidence of Leakage	41
2.4.7	Provisions for Expansion and Support	41
2.4.8	Inspection of Gages, Safety Devices, and Controls	41
2.4.8.1	Gages	41
2.4.8.2	Safety Devices	41
2.4.8.3	Quick-Disconnect Coupling.....	42
2.4.9	Covered Piping Systems.....	42
2.5	Pressure Relief Devices	42
2.5.1	Scope	42
2.5.2	Pressure Relief Device Data	43
2.5.3	Inservice Inspection Requirements for Pressure Relief Device Conditions	43
2.5.4	Inservice Inspection Requirements for Pressure Relief Devices Installation Condition	43
2.5.5	Additional Inspection Requirements	44
2.5.5.1	Boilers	44
2.5.5.2	Hot Water Supply Boilers, and Potable Water Heaters	44
2.5.5.3	Pressure Vessels and Piping	44
2.5.5.4	Rupture Disks	45
2.5.6	Packaging, Shipping, and Transportation.....	46
2.5.7	Testing and Operational Inspection of Pressure Relief Devices.....	47
2.5.7.1	Corrective Action	48
2.5.7.2	Valve Adjustments	48
2.5.8	Recommended Inspection and Test Frequencies for Pressure Relief Devices	48
2.5.8.1	Establishment of Inspection and Test Intervals	49
2.5.8.2	Establishment of Service Intervals	50
Section 3	Corrosion and Failure Mechanisms	51
3.1	Scope	51
3.2	General	51
3.3	Corrosion	51
3.3.1	Macroscopic Corrosion Environments	51
3.3.2	Microscopic Corrosion Environments	53
3.3.3	Control of Corrosion	53
3.3.3.1	Process Variables	53
3.3.3.2	Protection	54
3.3.3.3	Material Selection	54
3.3.3.4	Coatings	54
3.3.3.5	Engineering Design	55

3.3.3.6	Conclusion	55
3.4	Failure Mechanisms	55
3.4.1	Fatigue	55
3.4.2	Creep	56
3.4.3	Temperature Effects	56
3.4.4	Hydrogen Embrittlement	56
3.4.5	High-Temperature Hydrogen Attack	57
3.4.6	Hydrogen Damage	57
3.4.7	Bulges and Blisters	58
3.4.8	Overheating	58
3.4.9	Cracks	58
Section 4	Examinations, Test Methods, and Evaluations	59
4.1	Scope	59
4.2	Nondestructive Examination Methods (NDE).....	59
4.2.1	Visual	59
4.2.2	Magnetic Particle	59
4.2.3	Liquid Penetrant	60
4.2.4	Ultrasonic	60
4.2.5	Radiography	60
4.2.6	Eddy Current	61
4.2.7	Metallographic	61
4.2.8	Acoustic Emission	61
4.3	Testing Methods	61
4.3.1	Pressure Testing	61
4.3.1.1	All Pressure Testing	62
4.3.1.2	Liquid Pressure Testing	62
4.3.1.3	Pneumatic Pressure Testing.....	62
4.4	Methods to Assess Damage Mechanisms and Inspection Frequency for Pressure-Retaining Items.....	63
4.4.1	Scope	63
4.4.2	General Requirements	63
4.4.3	Responsibilities	64
4.4.4	Remaining Service Life Assessment Methodology	64
4.4.5	Data Requirements for Remaining Service Life Assessments	65
4.4.6	Identification of Damage Mechanisms	65
4.4.7	Determining Inspection Intervals	66
4.4.7.1	Method for Estimating Inspection Intervals for Pressure-Retaining Items Subject to Erosion or Corrosion.....	66
4.4.7.2	Method for Estimating Inspection Intervals for Exposure to Corrosion	67
4.4.7.3	Estimating Inspection Intervals for Pressure-Retaining Items Where Corrosion Is Not a Factor.....	69
4.4.8	Evaluating Inspection Intervals of Pressure-Retaining Items Exposed to Inservice Failure Mechanisms.....	70
4.4.8.1	Exposure to Elevated Temperature (Creep).....	70
4.4.8.2	Exposure to Brittle Fracture.....	71
4.4.8.3	Evaluating Conditions That Cause Bulges/Blisters/Laminations.....	71
4.4.8.4	Evaluating Crack-Like Indications in Pressure-Retaining Items.....	71
4.4.8.5	Evaluating Exposure of a Pressure-Retaining Item to Fire Damage.....	71
4.4.8.6	Evaluating Exposure of Pressure-Retaining Items to Cyclic Fatigue	72
4.4.8.7	Evaluating Pressure-Retaining Items Containing Local Thin Areas	73
4.5	Risk-Based Inspection Assessment Programs.....	74
4.5.1	Scope	74
4.5.2	Definitions.....	74
4.5.3	General.....	74
4.5.4	Considerations	75
4.5.5	Key Elements of an RBI Assessment Program	76
4.5.6	RBI Assessment.....	76
4.5.6.1	Probability of Failure.....	76

4.5.6.2	Consequence of Failure	76
4.5.6.3	Risk Evaluation.....	77
4.5.6.4	Risk Management	77
4.5.7	Jurisdictional Relationships.....	77
4.6	Quantitative Engineering Assessments Including Finite Element Analysis (FEA)	78
4.6.1	Calculations.....	78
4.6.2	Engineer Experience	78
4.6.3	Finite Element Analysis (FEA) Engineer Experience	78
Section 5	Stamping, Documentation, and Forms	79
5.1	Scope	79
5.2	Replacement of Stamping or Nameplate	79
5.2.1	Authorization	79
5.2.2	Replacement of Nameplate or Stamped Data.....	79
5.2.3	Reporting.....	79
5.2.4	Replacement of Duplicate Nameplates.....	80
5.3	National Board Inspection Forms	80
5.3.1	Scope	80
5.3.2	Forms	80
5.3.3	Guide for Completing Fitness for Service Assessment Reports.....	80
Section 6	Supplements	92
Supplement 1	Steam Locomotive Firetube Boiler Inspection and Storage.....	92
S1.1	Scope	92
S1.2	Special Jurisdictional Requirements	93
S1.3	Federal Railroad Administration (FRA)	93
S1.4	Locomotive Firetube Boiler Inspection	93
S1.4.1	Inspection Methods	93
S1.4.2	Inspection Zones	94
S1.4.2.1	Riveted Seams and Rivet Heads	94
S1.4.2.2	Welded and Riveted Repairs.....	95
S1.4.2.3	Boiler Shell Course.....	96
S1.4.2.4	Dome and Dome Lid	96
S1.4.2.5	Mudring	96
S1.4.2.6	Flue Sheets	97
S1.4.2.7	Flanged Sheets	97
S1.4.2.8	Stayed Sheets.....	97
S1.4.2.8.1	Bulged Stayed Sheets.....	98
S1.4.2.9	Staybolts.....	98
S1.4.2.10	Flexible Staybolts and Sleeves	99
S1.4.2.11	Girder Stay and Crown Bars	100
S1.4.2.12	Sling Stays	100
S1.4.2.13	Crown Stays and Expansion Stays	101
S1.4.2.14	Diagonal and Gusset Braces.....	102
S1.4.2.15	Flues.....	102
S1.4.2.16	Superheater Units and Header.....	102
S1.4.2.17	Arch Tubes, Water Bar Tubes, and Circulators	103
S1.4.2.18	Thermic Syphons	103
S1.4.2.19	Firebox Refractory.....	104
S1.4.2.20	Dry Pipe.....	104
S1.4.2.21	Throttle and Throttle Valve	104
S1.4.2.22	Screw-Type Washout Plugs, Holes, and Sleeves	104
S1.4.2.23	Handhole Washout Doors	105
S1.4.2.24	Threaded and Welded Attachment Studs.....	105
S1.4.2.25	Fusible Plugs.....	106
S1.4.2.26	Water Glass, Water Column, and Gage Cocks	106
S1.4.2.27	Steam Pressure Gage.....	106
S1.4.2.28	Boiler Fittings and Piping.....	107

S1.4.2.29	Boiler Attachment Brackets	107
S1.4.2.30	Fire Door	107
S1.4.2.31	Grates and Grate Operating Mechanism	108
S1.4.2.32	Smokebox	108
S1.4.2.33	Smokebox Steam Pipes	108
S1.4.2.34	Ash Pan and Fire Pan	109
S1.4.3	Method of Checking Height of Water Gage Glass	109
S1.4.3.1	Water Height Measurement Method.....	109
S1.4.3.2	Flexible Spirit Level Method	110
S1.5	Guidelines for Steam Locomotive Storage	111
S1.5.1	Storage Methods	112
S1.5.2	Wet Storage Method	112
S1.5.3	Dry Storage Method	112
S1.5.4	Recommended General Preservation Procedures	113
S1.5.5	Use of Compressed Air to Drain Locomotive Components	116
S1.5.6	Return to Service	116
S1.6	Safety Valves	117
S1.7	Tables and Figures	117
Supplement 2 Historical Boilers		118
S2.1	Scope	118
S2.2	Introduction.....	118
S2.3	Responsibilities	118
S2.4	General Inspection Requirements	118
S2.4.1	Pre-Inspection Requirements	118
S2.4.2	Post-Inspection Activities	119
S2.4.3	Boiler Operators	119
S2.4.4	Examinations and Tests	120
S2.4.4.1	Nondestructive Examination Methods.....	120
S2.4.4.2	Testing Methods	120
S2.5	Specific Examination and Test Methods	120
S2.5.1	Specific Examination Methods	120
S2.5.2	Visual Examination.....	121
S2.5.2.1	Preparation for Visual Inspection	121
S2.5.2.2	Visual Examination Requirements	121
S2.5.3	Ultrasonic Examination.....	121
S2.5.4	Liquid Penetrant Examination	121
S2.5.5	Magnetic Particle Examination	122
S2.6	Specific Testing Methods	122
S2.6.1	Hydrostatic Pressure Testing.....	122
S2.6.2	Ultrasonic Thickness Testing.....	122
S2.6.3	Evaluation of Corrosion	123
S2.6.3.1	Line and Crevice Corrosion.....	123
S2.6.3.2	Randomly Scattered Pits.....	123
S2.6.3.3	Locally Thinned Areas	123
S2.6.3.4	Generalized Thinned Areas.....	124
S2.7	Inspections	124
S2.7.1	Inservice Inspections.....	124
S2.7.2	Inservice Inspection Documentation	125
S2.7.3	Inspection Intervals	125
S2.7.3.1	Initial Inspection.....	125
S2.7.3.2	Subsequent Inspections	126
S2.8	Safety Devices — General Requirements.....	126
S2.8.1	Safety Valves.....	126
S2.8.2	Gage Glass	127
S2.8.3	Try-Cocks	127
S2.8.4	Fusible Plug.....	128
S2.8.5	Pressure Gage	128
S2.9	Appurtenances – Piping, Fittings, and Valves	128

S2.9.1	Piping, Fittings, and Valve Replacements	129
S2.10	Maximum Allowable Working Pressure (MAWP).....	129
S2.10.1	Strength.....	129
S2.10.2	Rivets and Rivet Heads.....	130
S2.10.2.1	Rivet Head Types	130
S2.10.2.2	Inspection of Corroded Rivets	130
S2.10.3	Cylindrical Components	131
S2.10.4	Stayed Surfaces	151
S2.10.4.1	Staybolts	151
S2.10.4.2	Bulging	151
S2.10.5	Construction Code.....	160
S2.10.6	Nomenclature	160
S2.10.7	Limitations	161
S2.10.8	Boiler Insulation and Jacketing.....	161
S2.11	Boiler Inspection Guideline.....	161
S2.12	Initial Boiler Certification Report Form	166
S2.13	Guidelines for Historical Boiler Storage.....	166
S2.13.1	Storage Methods	166
S2.13.1.1	Wet Storage Method	167
S2.13.1.2	Dry Storage Method	167
S2.13.2	Recommended General Preservation Procedures.....	168
S2.13.3	Use of Compressed Air to Drain Historical Boiler Components	170
S2.13.4	Return to Service.....	170
S2.14	Safety Procedures.....	171
S2.14.1	Experience	171
S2.14.2	Stopping Engine in an Emergency.....	171
S2.14.3	Water Glass Breakage	172
S2.14.4	Runaway Engine and Governor Over Speed	172
S2.14.5	Killing a Fire.....	173
S2.14.6	Injector Problems	173
S2.14.7	Foaming or Priming Boiler.....	174
S2.14.8	Handhole Gasket Blows Out	175
S2.14.9	Tube Burst.....	175
S2.14.10	Leaking Valves	175
S2.14.11	Broken Pipes.....	176
S2.14.12	Safety Valve Problems	176
S2.14.13	Safety Valve Opens But Will Not Close.....	176
S2.14.14	Leaking Pipe Plugs.....	176
S2.14.15	Melted Grates.....	176
S2.15	Tables and Figures	176
Supplement 3 Inspection of Graphite Pressure Equipment		181
S3.1	Scope	181
S3.2	Application	181
S3.3	Operations	181
S3.4	Inservice Inspection	181
Supplement 4 Inspection of Fiber-Reinforced Thermosetting Plastic Pressure Equipment.....		183
S4.1	Scope	183
S4.2	Inservice Inspection	183
S4.3	General	183
S4.4	Visual Examination	184
S4.5	Inspector Qualifications	185
S4.6	Assessment of Installation	185
S4.6.1	Preparation	186
S4.6.2	Leakage	186
S4.6.3	Tools	186
S4.7	External Inspection	186
S4.7.1	Insulation or Other Coverings	186

S4.7.2	Exposed Surfaces	186
S4.7.3	Structural Attachments	187
S4.8	Internal Inspection	187
S4.8.1	General	187
S4.8.2	Specific Areas of Concern	188
S4.9	Inspection Frequency	188
S4.9.1	Newly Installed Equipment	188
S4.9.2	Previously Repaired or Altered Equipment	189
S4.10	Photographs of Typical Conditions	190
S4.11	Tables and Figures	205
Supplement 5 Inspection of Yankee Dryers (Rotating Cast-Iron Pressure Vessels) with Finished Shell Outer Surfaces		206
S5.1	Scope	206
S5.2	Assessment of Installation	206
S5.2.1	Determination of Allowable Operating Parameters	208
S5.2.2	Adjusting the Maximum Allowable Operating Parameters of the Yankee Dryer Due to a Reduction in Shell Thickness from Grinding or Machining	209
S5.2.3	Documentation of Shell Thickness and Adjusted Maximum Allowable Operating Parameters.....	209
S5.3	Causes of Deterioration and Damage	210
S5.3.1	Local Thinning	210
S5.3.2	Cracking	211
S5.3.2.1	Through Joints and Bolted Connections	211
S5.3.2.2	Through-Wall Leakage	211
S5.3.2.3	Impact From Objects Passing Through The Yankee/Pressure Roll Nip.....	211
S5.3.2.4	Stress Magnification Around Drilled Holes	212
S5.3.2.5	Thermal Stress and/or Micro-Structural Change From Excessive Local Heating and Cooling	212
S5.3.2.6	Joint Interface Corrosion	212
S5.3.2.7	Stress-Corrosion Cracking of Structural Bolts	212
S5.3.3	Corrosion	212
S5.4	Inspections	213
S5.5	Nondestructive Examination.....	213
S5.6	Pressure Testing.....	213
S5.7	Tables and Figures	214
Supplement 6 Continued Service and Inspection of DOT Transport Tanks		215
S6.1	Scope	215
S6.2	Terminology	215
S6.3	Administration	215
S6.4	Inspection	215
S6.4.1	Scope	215
S6.4.2	General Requirements for Inspectors	215
S6.4.3	Registration of Inspectors.....	216
S6.4.4	Qualifications of Inspectors	216
S6.4.5	Codes of Construction.....	217
S6.4.6	Inspector Duties for Continued Service Inspections.....	217
S6.4.6.1	Inspector Duties for Continued Service Inspection of Cargo Tanks	217
S6.4.6.2	Inspector Duties for Continued Service Inspection of Portable Tanks	218
S6.4.6.3	Inspector Duties for Continued Service Inspections of Ton Tanks	218
S6.4.7	Continued Service, Inspection for DOT Transport Tanks Scope	218
S6.4.7.1	Administration.....	218
S6.4.7.2	Inspection and Test Required Frequencies	219
S6.4.7.3	External Visual and Pressure Tests.....	219
S6.4.7.4	Leak Tightness Testing of Transport Tanks	219
S6.4.7.4.1	Cargo Tanks	219
S6.4.7.4.2	Portable Tanks	219
S6.4.7.4.3	Ton Tanks	219

S6.4.7.4.4	Leak Tightness Testing of Valves	220
S6.4.7.4.4.1	Cargo Tanks	220
S6.4.7.4.4.2	Portable Tanks.....	220
S6.4.7.4.4.3	Ton Tanks	220
S6.4.7.5	Leak Tightness Testing of Safety Relief Devices.....	220
S6.4.7.5.1	Cargo Tanks	220
S6.4.7.5.2	Portable Tanks.....	221
S6.4.7.5.3	Ton Tanks	221
S6.4.7.6	Testing of Miscellaneous Pressure Parts	221
S6.4.7.6.1	Cargo Tanks	221
S6.4.7.6.2	Portable Tanks.....	222
S6.4.7.6.3	Ton Tanks	222
S6.4.7.7	Acceptance Criteria	222
S6.4.7.8	Inspection Report	222
S6.4.7.8.1	Cargo Tanks	222
S6.4.7.8.2	Portable Tanks.....	222
S6.4.7.8.3	Ton Tanks	222
S6.5	Stamping and Record Requirements for DOT Transport Tanks in Continued Service	223
S6.5.1	General.....	223
S6.5.2	Stamping	223
S6.5.3	Owner or User Required Records For Cargo Tanks	224
S6.5.3.1	Reporting Requirements by the Owner or User of Tests and Inspections of DOT Specification Cargo Tanks.....	225
S6.5.3.2	DOT Marking Requirements for Test and Inspections of DOT Specification Cargo Tanks	225
S6.5.4	Owner or User Required Records for Portable Tanks	226
S6.5.4.1	Reporting of Periodic and Intermediate Periodic Inspection and Tests of DOT Specification Portable Tanks.....	226
S6.5.4.2	Marking Requirements for Periodic and Intermediate Inspection and Test for IM or UN Portable Tanks	226
S6.5.4.3	DOT Marking Requirements for Periodic and Intermediate Inspection and Tests of DOT Specification 51, 56, 57, or 60 Portable Tanks	227
S6.5.5	Owner or User Required Reports for DOT Specification 106A and DOT 110A Ton Tanks.....	227
S6.5.5.1	Reporting of Inspection and Tests for DOT Specification 106A and DOT 110A Ton Tanks	227
S6.5.5.2	DOT Marking Requirements for Tests and Inspection of DOT Specification 106A and 110A Ton Tanks	228
S6.6	Corrosion and Failure Mechanisms in Transport Tanks	228
S6.6.1	Scope	228
S6.6.2	General.....	228
S6.6.3	Internal and/or External Corrosion	229
S6.6.3.1	Types of Corrosion	229
S6.6.4	Failure Mechanisms	231
S6.7	Classification Boundaries	232
S6.8	Pressure, Temperature, and Capacity Requirements for Transport Tanks	232
S6.9	References to Other Codes and Standards	233
S6.10	Conclusion	234
S6.11	Personnel Safety and Inspection Activities	234
S6.12	Transport Tank Entry Requirements.....	234
S6.12.1	Pre-Inspection Activities	235
S6.12.2	Preparation for Internal Inspection	235
S6.12.3	Post-Inspection Activities	236
S6.13	Inspection and Tests of Cargo Tanks	236
S6.13.1	Visual External Inspection	238
S6.13.2	Inspection of Piping, Valves, and Manholes	240
S6.13.3	Inspection of Appurtenances and Structural Attachments	241
S6.13.4	Visual Internal Inspection	242

S6.13.5	Lining Inspections	243
S6.13.6	Pressure Tests	244
S6.13.6.1	Hydrostatic or Pneumatic Test Method	245
S6.13.6.2	Pressure Testing Insulated Cargo Tanks	246
S6.13.6.3	Pressure Testing Cargo Tanks Constructed of Quenched and Tempered Steels	246
S6.13.6.4	Pressure Testing Cargo Tanks Equipped with a Heating System	246
S6.13.6.5	Exceptions to Pressure Testing	247
S6.13.6.6	Acceptance Criteria	247
S6.13.6.7	Inspection Report	247
S6.13.7	Additional Requirements for MC 330 and MC 331 Cargo Tanks	248
S6.13.8	Certificates and Reports	249
S6.13.9	Leakage Test	249
S6.13.10	New or Replaced Delivery Hose Assemblies	252
S6.13.10.1	Thickness Testing	252
S6.13.10.2	Testing Criteria	252
S6.13.10.3	Thickness Requirements	253
S6.13.11	Cargo Tanks That No Longer Conform to the Minimum Thickness Requirements in NBIC Part 2, Tables S6.13.1-a and S6.13.1-b	253
S6.13.11.1	Minimum Thickness for 400 - Series Cargo Tanks	254
S6.13.11.2	DOT 406 Cargo Tanks	254
S6.13.11.3	DOT 407 Cargo Tanks	255
S6.13.11.4	DOT 412 Cargo Tanks	256
S6.14	Inspection and Tests of Portable Tanks	260
S6.14.1	Periodic Inspection and Test	261
S6.14.2	Intermediate Periodic Inspection and Test	261
S6.14.3	Internal and External Inspections	262
S6.14.4	Exceptional Inspection and Test	262
S6.14.5	Internal and External Inspection Procedure	263
S6.14.6	Pressure Tests Procedures for Specification 51, 57, 60, IM or UN Portable Tanks	263
S6.14.6.1	Specification 57 Portable Tanks	264
S6.14.6.2	Specification 51 or 56 Portable Tanks	264
S6.14.6.3	Specification 60 Portable Tanks	265
S6.14.6.4	Specification IM or UN Portable Tanks	266
S6.14.7	Inspection and Test Markings for IM or UN Portable Tanks	267
S6.14.8	Inspection and Test Markings for Specification DOT 51, 56, 57, or 60	267
S6.14.9	Record Retention	268
S6.15	General Requirements for DOT Specification 106A and 110A Tank Cars (Ton Tanks)	268
S6.15.1	Special Provisions for Ton Tanks	268
S6.15.2	Visual Inspection of Ton Tanks	270
S6.15.3	Inspection and Tests of DOT Specification 106A and DOT Specification 110A Ton Tanks	271
S6.15.3.1	Air Tests	272
S6.15.3.2	Pressure Relief Device Testing	272
S6.15.3.3	Rupture Discs and Fusible Plugs	272
S6.15.3.4	Successful Completion of the Periodic Retesting	272
S6.15.3.5	Exemptions to Periodic Hydrostatic Retesting	272
S6.15.3.6	Record of Retest Inspection	273
S6.15.4	Stamping Requirements of DOT 106A and DOT 110A Ton Tanks	273
S6.16	Pressure Relief Devices	274
S6.16.1	Scope	274
S6.16.2	Safety Considerations	274
S6.16.3	Installation Provisions	274
S6.16.4	Pressure Relief Device Inspection	275
S6.16.5	Schedule of Inspections	275
S6.16.6	External Visual Inspection of Pressure Relief Devices	275
S6.16.7	Pressure Testing of Pressure Relief Valves	276
S6.16.8	Correction of Defects	276
S6.16.9	Inspection of Rupture Disks and Non-Reclosing Devices	277

S6.17	Definitions	277
S6.18	Tables and Figures	284
Supplement 7 Inspection of Pressure Vessels in Liquefied Petroleum Gas Service.....		285
S7.1	Scope	285
S7.2	Pre-Inspection Activities	285
S7.3	Inservice Inspection for Pressure Vessels in LP Gas Service	285
S7.3.1	Nondestructive Examination (NDE).....	285
S7.4	External Inspection	286
S7.5	Internal Inspection	286
S7.6	Leaks	286
S7.7	Fire Damage	287
S7.8	Acceptance Criteria	287
S7.8.1	Cracks	287
S7.8.2	Dents	287
S7.8.3	Bulges	288
S7.8.4	Cuts or Gouges	288
S7.8.5	Corrosion	288
S7.8.6	Anhydrous Ammonia Service	289
S7.9	ASME LPG Pressure Vessels less than 2000 Gallons being Refurbished by a Commercial Source	289
S7.10	Requirements for Change of Service from Above Ground to Underground Service	289
Supplement 8 Pressure Differential Between Safety or Safety Relief Valve Setting and Boiler or Pressure Vessel Operating Pressure.....		291
S8.1	Scope	291
S8.2	Hot-Water Heating Boilers	291
S8.3	Steam Heating Boilers	291
S8.4	Power Boilers	291
S8.5	Pressure Vessels	292
Supplement 9 Requirements for Change of Service.....		294
S9.1	Scope	294
S9.2	Classification of Service Change.....	294
S9.2.1	Service Contents.....	294
S9.2.2	Service Type or Change of Usage	294
S9.3	Factors to Consider	294
S9.4	Some Examples for Change of Service	296
S9.5	Documentation of Change of Service.....	297
Supplement 10 Inspection of Stationary High-Pressure (3,000-15,000 psi) (21-103 MPa) Composite Pressure Vessels		298
S10.1	Scope	298
S10.2	General	298
S10.3	Inspector Qualifications	298
S10.4	Inspection Frequency	299
S10.5	Inservice Inspection	299
S10.6	Assessment of Installation.....	299
S10.7	Visual Examination	300
S10.8	External Inspection	305
S10.9	Internal Examination	306
S10.10	Acoustic Emission Examination	307
S10.10.1	Use and Test Objectives	307
S10.10.2	AE Technician Requirements	307
S10.10.3	Test Procedure	307
S10.10.4	Equipment	307
S10.10.5	Sensor Placement	310
S10.10.6	Test Procedure	311
S10.10.7	Accept/Reject Criteria	312

S10.10.8	Fiber Breakage Criterion	313
S10.10.9	Friction Between Fracture Surfaces	315
S10.10.10	Background Energy	315
S10.11	Document Retention	315
Supplement 11 Inspector Review Guidelines for Finite Element Analysis (FEA)		316
S11.1	Scope	316
S11.2	Terminology	316
S11.3	Checklist	316
S11.3.1	Pressure Retaining Item Information	316
S11.3.2	Scope of the FEA	316
S11.3.3	FEA Software and Modelling	317
S11.4	Report Requirements	317
S11.4.1	Sections to be Included in the Report	317
S11.4.2	Listing of Information that may be Included in the FEA Report	317
S11.4.2.1	Analysis Method	317
S11.4.2.2	Structural Description/Mesh/Stress/Classification Line Locations	318
S11.4.2.3	Material Properties	318
S11.4.2.4	Restraints and Loads	318
S11.4.2.5	Validation	318
S11.4.2.6	Results	319
S11.4.2.7	Reference Documents Used	319
Supplement 12 Inspection of Liquid Carbon Dioxide Storage Vessels		320
S12.1	Scope	320
S12.2	General Requirements (Enclosed and Unenclosed Areas)	320
S12.3	Enclosed Area LCDSV Installations	320
S12.4	Fill Box Location/Safety Relief/Vent Valve Circuit Termination	321
S12.5	Gas Detection Systems	321
S12.6	Signage	321
S12.7	Valves, Piping, Tubing and Fittings	322
Supplement 13 Inspection of Biomass Fired Boiler Installations		324
S13.1	Scope	324
S13.2	Assessment of Installation	324
S13.3	Boiler Room Cleanliness	325
S13.4	Emission Control Requirements	325
Section 7 NBIC Policy for Metrication		326
7.1	General	326
7.2	Equivalent Rationale	326
7.3	Procedure for Conversion	326
7.4	Referencing Tables	327
Section 8 Preparation of Technical Inquiries to the National Board Inspection Code Committee		332
8.1	Introduction	332
8.2	Inquiry Format	332
8.3	Code Revisions or Additions	333
8.4	Code Interpretations	333
8.5	Submittals	334
Section 9 Glossary of Terms		335
9.1	Definitions	335
Section 10 NBIC Approved Interpretations		342
10.1	Scope	342
Section 11 Index		351

INTRODUCTION

It is the purpose of the National Board Inspection Code (NBIC) to maintain the integrity of pressure-retaining items by providing rules for post-construction activities including installation, and after the items have been placed into service, by providing rules for inspection and repair and alteration, thereby ensuring that these items may continue to be safely used.

The NBIC is intended to provide rules, information, and guidance to manufacturers, Jurisdictions, inspectors, owner-users, installers, contractors, and other individuals and organizations performing or involved in post-construction activities, thereby encouraging the uniform administration of rules pertaining to pressure retaining items.

SCOPE

The NBIC recognizes three important areas of post-construction activities where information, understanding, and following specific requirements will promote public and personal safety. These areas include:

- Installation
- Inspection
- Repairs and Alterations

The NBIC provides rules, information, and guidance for post-construction activities, but does not provide details for all conditions involving pressure-retaining items. Where complete details are not provided in this code, the code user is advised to seek guidance from the Jurisdiction and from other technical sources.

The words shall, should, and may are used throughout the NBIC and have the following intent:

- Shall – action that is mandatory and required.
- Should – indicates a preferred but not mandatory means to accomplish the requirement unless specified by others such as the Jurisdiction.
- May – permissive, not required or a means to accomplish the specified task.

ORGANIZATION

The NBIC is organized into four parts to coincide with specific post-construction activities involving pressure-retaining items. Each part provides general and specific rules, information, and guidance within each applicable post-construction activity. Other NBIC parts or other published standards may contain additional information or requirements needed to meet the rules of the NBIC. Specific references are provided in each part to direct the user where to find this additional information. NBIC parts are identified as:

- Part 1, Installation – This part provides requirements and guidance to ensure all types of pressure retaining items are installed and function properly. Installation includes meeting specific safety criteria for construction, materials, design, supports, safety devices, operation, testing, and maintenance.
- Part 2, Inspection – This part provides information and guidance needed to perform and document inspections for all types of pressure-retaining items. This part includes information on personnel safety, non-destructive examination, tests, failure mechanisms, types of pressure equipment, fitness for service, risk-based assessments, and performance-based standards.
- Part 3, Repairs and Alterations – This part provides requirements and guidance to perform, verify, and document acceptable repairs or alterations to pressure retaining items regardless of code of construction. Alternative methods for examination, testing, heat treatment, etc., are provided when the original code of construction requirements cannot be met. Specific acceptable and proven repair methods are also provided.
- Part 4, Pressure Relief Devices – This part provides information and guidance to ensure pressure relief devices are installed properly, information and guidance needed to perform and document inspections for pressure relief devices, and information and guidance to perform, verify, and document acceptable repairs to pressure relief devices.

Each NBIC part is divided into major sections as outlined in the Table of Contents.

Tables, charts, and figures provide relevant illustrations or supporting information for text passages, and are designated with numbers corresponding to the paragraph they illustrate or support within each section. Multiple tables, charts, or figures referenced by the same paragraph will have additional letters reflecting the order of reference. Tables, charts, and figures are located in or after each major section within each NBIC part.

TEXT IDENTIFICATION AND NUMBERING

Each page in the text will be designated in the top header with the publication's name, part number, and part title. The numbering sequence for each section begins with the section number followed by a dot to further designate major sections (e.g., 1.1, 1.2, 1.3). Major sections are further subdivided using dots to designate subsections within that major section (e.g., 1.1.1, 1.2.1, 1.3.1). Subsections can further be divided as necessary. Paragraphs under sections or subsections shall be designated with small letters in parenthesis (e.g., a), b), c)) and further subdivided using numbers in parenthesis (e.g., 1), 2), 3)).

Subdivisions of paragraphs beyond this point will be designated using a hierarchical sequence of letters and numbers followed by a dot.

Example: 2.1 Major Section
 2.1.1 Section
 2.1.2 Section
 2.1.2. Subsection
 a) paragraph
 b) paragraph
 1) subparagraph
 2) subparagraph
 a. subdivisions
 1. subdivisions
 2. subdivisions
 b. subdivisions
 1. subdivisions
 2. subdivisions

Tables and figures will be designated with the referencing section or subsection identification. When more than one table or figure is referenced in the same section or subsection, letters or numbers in sequential order will be used following each section or subsection identification.

SUPPLEMENTS

Supplements are contained in each part of the NBIC to provide requirements and guidance only pertaining to a specific type of pressure-retaining item (e.g., Locomotive Boilers, Historical Boilers, Graphite Pressure Vessels.) Supplements follow the same numbering system used for the main text only preceded by the Letter "S." Each page of the supplement will be tabbed to identify the supplement number.

EDITIONS

Editions, which include revisions and additions to this code, are published every two years. Editions are permissive on the date issued and become mandatory six months after the date of issue.

CODE STAMPING

ASME Code "Stamping" referenced throughout the NBIC includes the ASME Boiler and Pressure Vessel Code Symbol Stamps used for conformity assessment prior to the 2010 edition/2011 addendum and the equivalent ASME Certification Mark with Designator required to meet the later editions of the ASME Boiler and Pressure Vessel Code Sections. When other construction codes or standards are utilized for repairs or alterations, stamping shall mean the identification symbol stamp required by that code or standard.

INTERPRETATIONS

On request, the NBIC Committee will render an interpretation of any requirement of this code. Interpretations are provided for each part and are specific to the code edition and addenda referenced in the interpretation. Interpretations provide clarification of existing rules in the code only and are not part of this code.

JURISDICTIONAL PRECEDENCE

Reference is made throughout this code to the requirements of the “Jurisdiction.” Where any provision herein presents a direct or implied conflict with any jurisdictional regulation, the Jurisdictional regulation shall govern.

UNITS OF MEASUREMENT

Both U.S. customary units and metric units are used in the NBIC. The value stated in U.S. customary units or metric units are to be regarded separately as the standard. Within the text, the metric units are shown in parentheses. In Part 2, Supplement 6 and Part 3, Supplement 6 regarding DOT Transport Tanks, the metric units are shown first with the U.S. customary units shown in parentheses.

U.S. customary units or metric units may be used with this edition of the NBIC, but one system of units shall be used consistently throughout a repair or alteration of pressure-retaining items. It is the responsibility of National Board accredited repair organizations to ensure the appropriate units are used consistently throughout all phases of work. This includes materials, design, procedures, testing, documentation, and stamping. The NBIC policy for metrication is outlined in each part of the NBIC.

ACCREDITATION PROGRAMS

The National Board administers and four specific accreditation programs, as shown below:

- “R”.....Repairs and Alterations to Pressure-Retaining Items (NB-415)
- “VR”.....Repairs to Pressure Relief Valves (NB-514)
- “NR”.....Repair and Replacement Activities for Nuclear Items (NB-417)
- “T/O”.....Testing of Pressure Relief Valves (NB-528)

The administrative requirements for the accreditation for these accreditation programs can be viewed on the National Board Website at www.nationalboard.org.

The National Board also administers and accredits four specific inspection agency programs as shown below:

New Construction

Criteria for Acceptance of Authorized Inspection Agencies for New Construction (NB-360)

Inservice

Qualifications and Duties for Authorized Inspection Agencies (AIAs) Performing Inservice Inspection Activities and Qualifications for Inspectors of Boilers and Pressure Vessels (NB-369)

Owner-User

Accreditation of Owner-User Inspection Organizations (OUIO) (NB-371)

Owners or users may be accredited for both a repair and inspection program provided the requirements for each accreditation program are met.

Federal Government

Qualifications and Duties for Federal Inspection Agencies Performing Inservice Inspection Activities (FIAs) (NB-390)

These programs can be viewed on the National Board Website at www.nationalboard.org. For questions or further information regarding these programs contact the National Board by phone at (614) 888-8320 or by fax at (614) 847-1828.

CERTIFICATES OF AUTHORIZATION FOR ACCREDITATION PROGRAMS

Any organization seeking an accredited program may apply to the National Board to obtain a Certificate of Authorization for the requested scope of activities. A confidential review shall be conducted to evaluate the organization's quality system. Upon completion of the evaluation, a recommendation will be made to the National Board regarding issuance of a Certificate of Authorization.

Certificate of Authorization scope, issuance, and revisions for National Board accreditation programs are specified in the applicable National Board procedures. When the quality system requirements of the appropriate accreditation program have been met, a Certificate of Authorization and appropriate National Board symbol stamp shall be issued.

FOREWORD

The National Board of Boiler and Pressure Vessel Inspectors is an organization comprised of Chief Inspectors for the states, cities, and territories of the United States and provinces and territories of Canada. It is organized for the purpose of promoting greater safety to life and property by securing concerted action and maintaining uniformity in post-construction activities of pressure-retaining items, thereby ensuring acceptance and interchangeability among Jurisdictional authorities responsible for the administration and enforcement of various codes and standards.

In keeping with the principles of promoting safety and maintaining uniformity, the National Board originally published the NBIC in 1946, establishing rules for inspection and repairs to boilers and pressure vessels. The *National Board Inspection Code* (NBIC) Committee is charged with the responsibility for maintaining and revising the NBIC. In the interest of public safety, the NBIC Committee decided, in 1995, to revise the scope of the NBIC to include rules for installation, inspection, and repair or alteration to boilers, pressure vessels, piping, and nonmetallic materials.

In 2007, the NBIC was restructured into three parts specifically identifying important post-construction activities involving safety of pressure-retaining items. This restructuring provides for future expansion, transparency, uniformity, and ultimately improving public safety.

In 2017, the NBIC was once again restructured into 4 parts, adding a new Part 4, Pressure Relief Devices. This purpose of this restructuring was to provide one distinct integrated part for pressure relief devices compiled from all PRD information referenced in Part 1, Installation; Part 2, Inspection; and Part 3, Repairs and Alterations.

The NBIC Committee's function is to establish rules of safety governing post-construction activities for the installation, inspection, and repair and alteration of pressure-retaining items, and to interpret these rules when questions arise regarding their intent. In formulating the rules, the NBIC Committee considers the needs and concerns of individuals and organizations involved in the safety of pressure-retaining items. The objective of the rules is to afford reasonably certain protection of life and property, so as to give a reasonably long, safe period of usefulness. Advancements in design and material and the evidence of experience are recognized.

The rules established by the NBIC Committee are not to be interpreted as approving, recommending, or endorsing any proprietary or specific design, or as limiting in any way an organization's freedom to choose any method that conforms to the NBIC rules.

The NBIC Committee meets regularly to consider revisions of existing rules, formulation of new rules, and respond to requests for interpretations. Requests for interpretation must be addressed to the NBIC Secretary in writing and must give full particulars in order to receive Committee consideration and a written reply. Proposed revisions to the code resulting from inquiries will be presented to the NBIC Committee for appropriate action.

Proposed revisions to the code approved by the NBIC Committee are submitted to the American National Standards Institute and published on the National Board web-site to invite comments from all interested persons. After the allotted time for public review and final approval, the new edition is published. The Foreword, Introduction, Personnel and Index Sections of the NBIC are provided for guidance and informational purposes only and shall not be considered a part of the Code. These sections are not approved by the NBIC Committee or submitted to the American National Standards Institute.

Organizations or users of pressure-retaining items are cautioned against making use of revisions that are less restrictive than former requirements without having assurance that they have been accepted by the Jurisdiction where the pressure-retaining item is installed.

The general philosophy underlying the NBIC is to parallel those provisions of the original code of construction, as they can be applied to post-construction activities. The NBIC does not contain rules to cover all details of post-construction activities. Where complete details are not given, it is intended that individuals or organizations, subject to the acceptance of the Inspector and Jurisdiction when applicable, provide details

for post-construction activities that will be as safe as otherwise provided by the rules in the original code of construction.

Activities not conforming to the rules of the original code of construction or the NBIC must receive specific approval from the Jurisdiction, who may establish requirements for design, construction, inspection, testing, and documentation.

There are instances where the NBIC serves to warn against pitfalls; but the code is not a handbook, and cannot substitute for education, experience, and sound engineering judgment. It is intended that this edition of the NBIC not be retroactive. Unless the Jurisdiction imposes the use of an earlier edition, the latest effective edition is the governing document.

PERSONNEL

The National Board of Boiler and Pressure Vessel Inspectors

Board of Trustees

J. Burpee
Chairman

J. Amato
First Vice Chairman

D. Cook
Second Vice Chairman

C. Cantrell
Member at Large

E. Creaser
Member at Large

A. Oda
Member at Large

M. Washington
Member at Large

D. Douin
Secretary/Treasurer

Advisory Committee

J. Pillow
Representing welding industries

C. Hopkins
Representing National Board stamp holders

H. Richards
Representing boiler and pressure vessel users

B. Berquist
Representing pressure vessel manufacturers

R. Wielgoszinski
Representing authorized inspection agencies
(insurance companies)

P. Molvie
Representing boiler manufacturers

National Board Members

Alabama	Marvin Byrum
Alaska	Kenneth Lane
Arizona	Randall Austin
Arkansas	Dennis Hannon
California	Donald Cook
Colorado	Steve Nelson
Delaware	John Esch
Florida	Andrew Frazier
Georgia	Benjamin Crawford
Hawaii	Julius Dacanay
Illinois	Michael Vogel
Indiana	Larry Parkey
Kansas	Robert Stimson
Kentucky	Mark Jordan
Louisiana	Joseph LeSage
Maine	John Burpee
Maryland	Karl Kraft
Massachusetts	Edward Kawa
Michigan	David Stenrose
Minnesota	Joel Amato
Mississippi	William Anderson
Missouri	Ronald Brockman
Nebraska	Christopher B. Cantrell
Nevada	David Sandfoss
New Hampshire	Darrell Mallory
New Jersey	Milton Washington
New York	Matthew Sansone
North Carolina	Clifford Dautrich
North Dakota	Trevor Seime
Ohio	John Sharier
Oklahoma	Thomas Granneman
Oregon	Mark Perdue
Pennsylvania	Nathaniel Smith
South Carolina	Ronald W. Spiker
South Dakota	Aaron Lorimor
Tennessee	Sam Chapman
Texas	Rob Troutt
Utah	Rick Sturm
Virginia	Edward Hilton
Washington	Tony Oda
West Virginia	John Porcella
Wisconsin	Terrence Waldbillig
Chicago, IL	Michael Ryan
Detroit, MI	Cortney Jackson
Los Angeles, CA	Cirilo Reyes
Milwaukee, WI	Jillian Klug
New York, NY	William McGivney
Seattle, WA	Larry Leet
Alberta	Michael Pohlmann
British Columbia	Anthony Scholl
Manitoba	Ryan DeLury
New Brunswick	Eben Creaser
Newfoundland & Labrador	Dennis Eastman
Northwest Territories	Matthias Mailman
Nova Scotia	Peter Dodge
Ontario	Michael Adams
Prince Edward Island	Steven Townsend
Quebec	Aziz Khssassi
Saskatchewan	Christopher Selinger

National Board Inspection Code Main Committee

D. Cook, Chair
State of California

R. Wielgoszinski, Vice Chair
*Hartford Steam Boiler Inspection and
Insurance Company*

B. Besserman, Secretary
National Board

J. Amato
State of Minnesota

R. Austin
State of Arizona

S. Cammeresi
Furmanite

P. Edwards
WECTEC

G. Galanes
Diamond Technical Services, Inc.

J. Getter
Worthington Industries

C. Hopkins
Seattle Boiler Works, Inc.

L. McManoman
Great Lakes Area Apprenticeship Program

M. Mooney
Liberty Mutual Insurance Company

B. Morelock
Eastman Chemical Company

V. Newton
XL Insurance

J. Pillow
Common Arc

M. Richards
Consultant

J. Riley
Phillips 66

J. Sekely
Consultant

K. Simmons
Pentair

S. Staniszewski Jr.
U.S. Department of Transportation

R. Troutt
State of Texas

M. Wadkinson
Fulton Boiler Works, Inc.

M. Webb
Xcel Energy Services

P. Welch
Arise Boiler Inspection and Insurance Company

**National Board Inspection Code
Subcommittee Installation (Part 1)**

H. Richards, Chair
Consultant

D. Patten, Vice Chair
Bay City Boiler

J. Bock, Secretary
National Board

R. Austin
State of Arizona

G. Halley
ABMA

S. Konopacki
NRG

B. Moore
*Hartford Steam Boiler Inspection and
Insurance Company*

P. Schuelke
Well-McLain

R. Smith
Authorized Inspection Associates

M. Wadkinson
Fulton Boiler Works, Inc.

E. Wiggins
Liberty Mutual Insurance Company

**National Board Inspection Code
Subcommittee Inspection (Part 2)**

M. Mooney, Chair
Liberty Mutual Insurance Company

S. Staniszewski, Vice Chair
US Department of Transportation

J. Metzmaier, Secretary
National Board

T. Barker
FM Global

E. Brantley
XL Insurance

D. Buechel
*Hartford Steam Boiler Inspection and
Insurance Company*

D. Ford
U.S. Department of Transportation

J. Getter
Worthington Cylinders

D. Graf
Air Products and Chemicals, Inc.

M. Horbaczewski
Diamond Technical Services

G. McRae
Trinity Industries, Inc.

V. Newton
XL Insurance

J. Riley
Phillips 66

M. Schwartzwalder
Stress Engineering Services

T. Vandini
Quality Steel Corporation

P. Welch
ARISE

**National Board Inspection Code
Subcommittee for Repairs and Alterations
(Part 3)**

G. Galanes, Chair
Diamond Technical Services, Inc.

J. Pillow, Vice Chair
Common Arc Corporation

W. Vallance, Secretary
National Board

J. Amato
State of Minnesota

B. Boseo
Graycor Services LLC

A. Bramucci
GE Renewable Energy

P. Edwards
WECTEC

C. Hopkins
Seattle Boiler Works, Inc.

W. Jones
Arise, Inc.

L. McManoman
Great Lakes Area Apprenticeship Program

R. Miletti
Babcock and Wilcox Construction Company, Inc.

L. Moedinger
Strasburg Railroad Company

K. Moore
Joe Moore Company

B. Morelock
Eastman Chemical Company

B. Schaefer
AEP

J. Sekely
Consultant

M. Toth
Boiler Supply Company, Inc.

R. Troutt
State of Texas

M. Webb
Xcel Energy

**National Board Inspection Code
Subcommittee Pressure Relief Devices
(Part 4)**

S. Cammeresi, Chair
Furmanite

A. Cox, Vice Chair
JAC Consulting

T. Beirne, Secretary
National Board

K. Beise
Dowco Valve Company, Inc.

M. Brodeur
International Valve & Instr. Corp.

D. DeMichael
Chemours Co.

R. Donalson
Pentair

B. Hart
FM Global

D. Marek
Mainthia Technologies

R. McCaffrey
Quality Valve

D. McHugh
Allied Valve, Inc.

B. Nutter
E.I. Dupont De Nemours & Co.

T. Patel
Farris Engineering

A. Renaldo
Praxair, Inc.

K. Simmons
Pentair

National Board Inspection Code Subgroup Installation (Part 1)

M. Wadkinson, Chair
Fulton Boiler Works, Inc.

D. Patten, Vice Chair
Bay City Boiler

J. Bock, Secretary
National Board

R. Austin
State of Arizona

T. Creacy
Zurich Services Corporation

G. Halley
ABMA

S. Konopacki
NRG Energy

J. Millette
UAB

B. Moore
*Hartford Steam Boiler Inspection and
Insurance Company*

H. Richards
Consultant

P. Schuelke
Well-McLain

R. Smith
Authorized Inspection Associates

M. Washington
State of New Jersey

E. Wiggins
Liberty Mutual Insurance Company

National Board Inspection Code Subgroup Inspection (Part 2)

J. Getter, Chair
Worthington Industries

M. Schwartzwalder, Vice Chair
AEP

J. Metzmaier, Secretary
National Board

T. Barker
FM Global

E. Brantley
XL Insurance America, Inc.

D. Ford
US Department of Transportation

D. Graf
Air Products and Chemicals, Inc.

B. Hart
Factory Mutual Insurance Company

M. Horbaczewski
Midwest Generation

G. McRae
Trinity Industries, Inc.

M. Mooney
Liberty Mutual Insurance

V. Newton
XL Insurance America

J. Riley
Phillips 66

S. Staniszewski
US Department of Transportation

T. Vandini
Quality Steel Corporation

P. Welch
Arise, Inc.

National Board Inspection Code Subgroup for Repairs and Alterations (Part 3)

A. Bramucci, Chair
GE Renewable Energy

W. Vallance, Secretary
National Board

J. Amato
State of Minnesota

B. Boseo
Graycor Services LLC

N. Carter
*Hartford Steam Boiler Inspection and
Insurance Company*

R. Cauthon
Alstom Power

P. Edwards
WECTEC

G. Galanes
Diamond Technical Services, Inc.

C. Hopkins
Seattle Boiler Works, Inc.

F. Johnson
PBF Energy

W. Jones
Arise, Inc.

D. Martinez
FM Global

L. McManoman
Great Lakes Area Apprenticeship Program

R. Miletti
Babcock and Wilcox Construction Company, Inc.

K. Moore
Joe Moore Company

B. Morelock
Eastman Chemical

J. Pillow
Common Arc Corporation

B. Schaefer
AEP

J. Sekely
Consultant

W. Sperko
Sperko Engineering Services

M. Toth
Boiler Supply Company, Inc.

R. Troutt
State of Texas

R. Valdez
ARB, Inc.

J. Walker
Hayes Mechanical

M. Webb
Xcel Energy

T. White
NRG Energy

National Board Inspection Code Subgroup Graphite

E. Soltow, Chair
SGL Carbon Technic

B. Besserman, Secretary
National Board

G. Becherer
CG Thermal

F. Brown
Consultant

C. Cary
Dow Corning

J. Clemens
Graphite Maintenance

K. Cummins
Louisville Graphite

B. Dickerson
Mersen

B. Jones
Mersen

R. Selvaraj
Mersen

D. Sholar
Mersen

A. Stupica
SGL Carbon Technic

A. Viet
CG Thermal

National Board Inspection Code Subgroup Fiber-Reinforced Pressure Vessels

B. Shelley, Chair
Chemours

B. Besserman, Secretary
National Board

F. Brown
Consultant

J. Bustillos
Bustillos and Associates

T. Cowley
FRP Consulting

D. Eisberg
Avista Technologies

M. Gorman
Digital Wave

D. Hodgkinson
Consultant

D. Keeler
The Dow Chemical Company

D. McCauley
Chemours

N. Newhouse
Hexagon Lincoln

A. Pollock
Mistras Group

J. Richter
Thorpe Plant Services

N. Sirosh
LightSail Energy

National Board Inspection Code Subgroup Locomotive Boilers

L. Moedinger, Chair
Strasburg Railroad

M. Janssen, Vice Chair
Vapor Locomotive Company

B. Ferrel, Secretary
National Board

S. Butler
Midwest Locomotive & Machine Works

D. Conrad
Valley Railroad Co.

R. Franzen
Steam Services of America

D. Griner
Arizona Mechanical Engineering

S. Lee
Union Pacific Railroad

D. McCormack
Consultant

G. Ray
Tennessee Valley Authority

R. Stone
ARVOS, Inc.

**National Board Inspection Code
Subgroup Historical Boiler**

J. Amato, Chair
State of Minnesota

T. Dillon, Vice Chair
MSEA

B. Ferrell, Secretary
National Board

J. Getter
Worthington Industries

F. Johnson
PBF Energy

M. Jordan
State of Kentucky

D. Rose
T&T Inspections

D. Rupert
Consultant

R. Underwood
*Hartford Steam Boiler Inspection and
Insurance Company*

M. Wahl
WHSEA

PART 2, SECTION 1

INSPECTION — GENERAL REQUIREMENTS FOR INSERVICE INSPECTION OF PRESSURE-RETAINING ITEMS

1.1 SCOPE (17)

This part provides requirements and guidelines for conducting inservice inspection of pressure-retaining items.

This section provides general requirements and guidelines for inservice inspection. This section includes precautions for the safety of inspection personnel. The safety of the public and the Inspector is the most important aspect of any inspection activity.

1.2 ADMINISTRATION (17)

Jurisdictional requirements describe the frequency, scope, type of inspection, whether internal, external, or both, and type of documentation required for the inspection. The Inspector shall have a thorough knowledge of jurisdictional regulations where the item is installed, as jurisdictional or regulatory inspection requirements do vary.

Unless otherwise specifically required by the jurisdiction, the duties of the Inspector do not include inspection to other standards and requirements (e.g., environmental, construction, electrical, operational, undefined industry standards, etc.) for which other regulatory agencies have authority and responsibility to oversee.

1.3 REFERENCE TO OTHER CODES AND STANDARDS

Other existing inspection codes, standards, and practices pertaining to the inservice inspection of pressure-retaining items can provide useful information and references relative to the inspection techniques listed in this part. Use of these codes, standards, and practices are subject to review and acceptance by the Inspector, and when required by the Jurisdiction. Any inconsistency or discrepancy between the requirements of the NBIC and these inspection codes, standards, and practices shall be resolved by giving precedence to requirements in the following order:

- a) The requirements of the Jurisdiction having authority.
- b) The requirements of the NBIC supersede general and specific requirements of other inspection codes, standards, and practices.
- c) The general and specific requirements of the references to other codes and standards listed herein that are recognized and generally accepted good engineering practices.

Some examples are as follows:

- a) National Board *Bulletin* - National Board Classic Articles Series
- b) American Society of Mechanical Engineers - *ASME Boiler and Pressure Vessel Code Section V* (Nondestructive Examination)
- c) American Society of Mechanical Engineers - *ASME Boiler and Pressure Vessel Code Section VI* (Recommended Rules for the Care and Operation of Heating Boilers) this section when performing inspections of heating boilers. There may be occasions where more detailed procedures will be required.
- d) American Society of Mechanical Engineers- *ASME Boiler and Pressure Vessel Code Section VII* (Recommended Guidelines for the Care of Power Boilers)



2017 NBIC

NATIONAL BOARD INSPECTION CODE

PART 3

REPAIRS AND ALTERATIONS

NATIONAL BOARD INSPECTION CODE
2017 EDITION
DATE OF ISSUE — JULY 1, 2017

This code was developed under procedures accredited as meeting the criteria for American National Standards. The Consensus Committee that approved the code was balanced to ensure that individuals from competent and concerned interests had an opportunity to participate. The proposed code was made available for public review and comment, which provided an opportunity for additional public input from industry, academia, regulatory and jurisdictional agencies, and the public-at-large.


The National Board does not “approve,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

The National Board does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable Letters Patent, nor assume any such liability. Users of a code are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code.

The National Board accepts responsibility for only those interpretations issued in accordance with governing National Board procedures and policies that preclude the issuance of interpretations by individual committee members.

The footnotes in this document are part of this American National Standard.



The above National Board symbols are registered with the US Patent Office.

“National Board” is the abbreviation for The National Board of Boiler and Pressure Vessel Inspectors.

No part of this document may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

All charts, graphs, tables, and other criteria that have been reprinted from the *ASME Boiler and Pressure Vessel Code*, Sections I, IV, VIII, and X are used with the permission of the American Society of Mechanical Engineers. All Rights Reserved.

Library of Congress Catalog Card No. 52-44738
 Printed in the United States of America
 All Rights Reserved

www.nationalboard.org

Copyright © 2017 by
 THE NATIONAL BOARD OF BOILER & PRESSURE VESSEL INSPECTORS
 All rights reserved
 Printed in U.S.A.

PART 3 — REPAIRS AND ALTERATIONS

TABLE OF CONTENTS

Introduction	X
Foreword	XIV
Personnel	XVI
Section 1	General and Administrative Requirements	1
1.1	Scope	1
1.2	Construction Standards for Pressure-Retaining Items	1
1.3	Inspector	2
1.3.1	Authorization	2
1.3.2	Acceptance Inspection	2
1.4	Accreditation.....	2
1.4.1	Accreditation Process.....	3
1.4.2	National Board “R” Symbol Stamp	3
1.5	Quality System	3
1.5.1	Outline of Requirements for a Quality System for Qualification for the National Board “R” <i>Certificate of Authorization</i>	3
1.6	“NR” Program Requirements.....	8
1.6.1	Scope	8
1.6.2	General	8
1.6.2.1	Definitions	9
1.6.3	Prerequisites for Issuing a National Board “NR” <i>Certificate of Authorization</i>	10
1.6.4	Obtaining or Renewing a National Board “NR” <i>Certificate of Authorization</i>	11
1.6.5	Quality Assurance Program	11
1.6.6	Quality Assurance Program Requirements for Category 1 Activities	12
1.6.6.1	Scope	12
1.6.6.2	Quality Program Elements	12
1.6.7	Quality Assurance Program Requirements for Category 2 Activities	18
1.6.7.1	Scope	18
1.6.7.2	Quality Program Elements	18
1.6.8	Quality Assurance Program Requirements for Category 3 Activities	25
1.6.8.1	Scope	25
1.6.8.2	Quality Program Elements	25
1.6.9	Interface with the Owner’s Repair/Replacement Program (For Categories 1, 2, and 3 as Applicable).....	27
Section 2	Welding and Heat Treatment	29
2.1	Scope	29
2.2	Welding	29
2.2.1	Welding Procedure Specifications	29
2.2.2	Standard Welding Procedure Specifications	29
2.2.3	Performance Qualification	29
2.2.4	Welding Records	29
2.2.5	Welder’s Identification	29
2.2.6	Welder’s Continuity	30
2.2.6.1	Welder’s Continuity Records.....	30
2.3	Standard Welding Procedure Specifications	30
2.4	AWS Reference Standards	36
2.5	Heat Treatment	36
2.5.1	Preheating	36
2.5.2	Postweld Heat Treatment (PWHT).....	38
2.5.3	Alternative Welding Methods Without Postweld Heat Treatment	40
2.5.3.1	Welding Method 1	41
2.5.3.2	Welding Method 2	42

2.5.3.3	Welding Method 3	43
2.5.3.4	Welding Method 4	44
2.5.3.5	Welding Method 5	45
2.5.3.6	Welding Method 6	46
Section 3	Requirements for Repairs and Alterations	48
3.1	Scope	48
3.2	General Requirements for Repairs and Alterations	48
3.2.1	Material Requirements for Repairs and Alterations	48
3.2.2	Replacement Parts	48
3.2.3	Drawings	49
3.2.4	Design Requirements for Repairs and Alterations	49
3.2.5	Calculations	50
3.2.6	Reference to Other Codes and Standards	50
3.2.7	Change of Service	50
3.3	Repairs to Pressure-Retaining Items	50
3.3.1	Defect Repairs	50
3.3.2	Routine Repairs	50
3.3.3	Examples of Repairs	51
3.3.4	Repair Methods	52
3.3.4.1	Scope	52
3.3.4.2	Defect Repairs	52
3.3.4.3	Wasted Areas	55
3.3.4.4	Seal Welding	60
3.3.4.5	Re-Ending or Piecing Pipes or Tubes	61
3.3.4.6	Patches	62
3.3.4.7	Stays	64
3.3.4.8	Repair of Pressure-Retaining Items Without Complete Removal of Defects	64
3.3.4.9	Tube Plugging in Firetube Boilers	65
3.3.5	Repair of ASME Section VIII, Division 2 or 3, Pressure Vessels	65
3.3.5.1	Scope	65
3.3.5.2	Repair Plan	65
3.4	Alterations	66
3.4.1	Re-Rating	66
3.4.2	Alterations Based on Allowable Stress Values	66
3.4.3	Encapsulation	67
3.4.4	Examples of Alterations	68
3.4.5	Alteration of ASME Code Section VIII, Division 2 or 3, Pressure Vessels	68
3.4.5.1	Alteration Plan	68
Section 4	Examination and Testing	70
4.1	Scope	70
4.2	Nondestructive Examination	70
4.3	Pressure Gages, Measurement, Examination, and Test Equipment	70
4.4	Examination and Test for Repairs and Alterations	70
4.4.1	Test or Examination Methods Applicable to Repairs	70
4.4.2	Test or Examination Methods Applicable to Alterations	73
Section 5	Certification/Documentation and Stamping	75
5.1	Scope	75
5.2	Documentation	75
5.2.1	Preparation of Form R-1 (Repairs)	75
5.2.2	Preparation of Form R-2 (Alterations)	75
5.3	Distribution of Form R-1	76
5.4	Distribution of Form R-2	76
5.5	Registration of Forms – General	76
5.5.1	Registration for Repairs	76
5.5.2	Registration for Alterations	77
5.5.3	Registration for Fiber-Reinforced Vessels	77

5.5.4	Registration for Nuclear Repair/Replacement Activities	77
5.5.5	Registration for Graphite Vessels	77
5.6	Form Registration Log	77
5.7	Stamping Requirements for Repairs and Alterations	77
5.7.1	General	77
5.7.2	Stamping Requirements for Repairs	77
5.7.3	Stamping Requirements for Alterations	78
5.7.4	Stamping Requirements for Parts	78
5.7.5	Specific Requirements for Stamping and Nameplates	78
5.8	Stamping for Fiber-Reinforced Vessels	80
5.8.1	Stamping for Repairs	80
5.8.2	Stamping for Alterations	80
5.9	Stamping Requirements for Yankee Dryers	81
5.10	Alternative Marking and Stamping for Graphite Pressure Equipment	81
5.11	Removal of Original Stamping or Nameplate	82
5.12	Repair and Alteration Forms and Instructions for Completing Forms	82
5.12.1	Form R-1, <i>Report of Repair</i>	82
5.12.2	Form R-2, <i>Report of Alteration</i>	82
5.12.3	Form R-3, <i>Report of Parts Fabricated By Welding</i>	82
5.12.4	Form R-4, <i>Report Supplementary Sheet</i>	82
5.12.4.1	Instructions for Completing National Board Form "R" Reports	82
5.12.5	Form NR-1, <i>Nuclear Components and Systems in Nuclear Power Plants</i>	85
5.12.5.1	Guide for Completing National Board Form NR-1 Reports of Repair/Replacement Activities for Nuclear Facilities	85
5.12.6	Form NVR-1, <i>Nuclear Pressure Relief Devices</i>	87
5.12.6.1	Guide for Completing National Board Form NVR-1 Reports of Repair/Replacement Activities for Nuclear Pressure Relief Devices	87
Section 6	Supplements	102
Supplement 1	Steam Locomotive Firetube Boiler Repairs	102
S1.1	Scope	102
S1.1.1	Federal Railroad Administration (FRA)	102
S1.1.2	Requirements for Welding Activities	102
S1.1.3	Materials	102
S1.1.3.1	Material List for Steam Locomotive Boilers	102
S1.1.4	Formula and Calculations for Steam Locomotive Boilers	103
S1.2	Locomotive Firetube Boiler Repairs	104
S1.2.1	Repair of Staybolt Holes	104
S1.2.2	Threaded Staybolts	104
S1.2.3	Ball Socket-Type Flexible Staybolts, Sleeves, and Caps	106
S1.2.4	Seal Welded Staybolts	109
S1.2.5	Welded Installation of Staybolts	110
S1.2.5.1	Un-Threaded Fillet-Welded Staybolts	110
S1.2.6	Diagonal Braces, Gusset Braces, and Throat Sheet/Tubesheet Braces	110
S1.2.6.1	Girder Stays and Crown Bars	112
S1.2.6.2	Sling Stays	113
S1.2.6.3	Expansion Stays	114
S1.2.7	Threaded Studs	116
S1.2.8	Patch Bolts	116
S1.2.9	Flues, Arch Tubes, Circulators, Thermic Syphons	117
S1.2.9.1	Flue and Tube Re-Ending	118
S1.2.9.2	Arch Tubes	118
S1.2.9.3	Tube Wall Thickness for Arch Tubes	120
S1.2.9.4	Thermic Syphons	120
S1.2.9.5	Circulators	121
S1.2.9.6	Re-Rolling of Flue-Tubes after Seal Welding	121
S1.2.9.7	Ferrules	121
S1.2.9.8	Flues Smaller Than 3 Inches	121

S1.2.10	Repairs and Alterations to Boiler Barrel Unstayed Areas	122
S1.2.11	Repairs and Alterations to Boiler Barrel Stayed Area	122
S1.2.11.1	Firebox Sheet Repair	122
S1.2.11.2	Fireboxes and Other Stayed Area Patches	124
S1.2.11.3	Repair of Stayed Firebox Sheets Grooved or Wasted at the Mudring	124
S1.2.11.4	Mudring Repairs	125
S1.2.11.5	Repair of Firebox and Tubesheet Knuckles	126
S1.2.11.6	Tubesheet Repairs	130
S1.2.12	Seams and Joints	131
S1.2.12.1	Caulking Riveted Seams and Rivet Heads	131
S1.2.12.2	Threaded Openings in Vessel Walls, Bushings, and Welded Nozzles (Washout Plug Holes and Other Connections)	132
S1.2.13	Fittings and Gages	133
S1.2.13.1	Water Gage Connection	133
Supplement 2 Historical Boilers	134
S2.1	Scope	134
S2.2	Introduction	134
S2.3	Responsibilities	134
S2.4	Repairs and Alterations	134
S2.5	Construction Standards	134
S2.6	Accreditation	135
S2.7	Materials	135
S2.7.1	Material List for Historical Boiler Repairs	135
S2.7.2	Replacement Parts	136
S2.8	Welded Repair Inspection	136
S2.9	Welding	136
S2.10	Heat Treatment	136
S2.11	Nondestructive Examination	137
S2.12	Documentation	137
S2.13	Repair Methods	137
S2.13.1	Repair of Threaded Staybolt Holes	137
S2.13.2	Installation of Threaded Staybolts	138
S2.13.3	Seal Welding of Threaded Staybolts	139
S2.13.4	Installation of Welded Staybolts	140
S2.13.5	Threaded Studs	141
S2.13.6	Patch Bolts	141
S2.13.7	Flue and Tube Re-Ending	142
S2.13.8	Flue and Tube Installation	144
S2.13.9	Repairs and Alterations to Unstayed Areas	146
S2.13.9.1	Weld Buildup of Wastage and Grooving in Unstayed Areas	146
S2.13.9.2	Welded Repair of Cracks in Unstayed Areas	147
S2.13.9.3	Welded Flush Patches in Unstayed Areas	147
S2.13.9.4	Repair of Cracks, Grooving, and Wastage Using a Riveted Patch in Unstayed Areas	148
S2.13.9.5	Barrel Replacement	149
S2.13.10	Repairs and Alterations to Stayed Areas	150
S2.13.10.1	Weld Buildup of Wastage and Grooving in Stayed Areas	150
S2.13.10.2	Welded Repair of Cracks in Stayed Areas	150
S2.13.10.3	Welded Flush Patches in Stayed Areas	150
S2.13.10.4	Repair of Stayed Firebox Sheets Grooved or Wasted at the Mudring	151
S2.13.11	Repair of Firebox and Tubesheet Knuckles	153
S2.13.11.1	Weld Buildup of Wastage and Grooving in Firebox and Tubesheet Knuckles	153
S2.13.11.2	Welded Repair of Cracks in Firebox and Tubesheet Knuckles	153
S2.13.11.3	Welded Flush Patches in Firebox and Tubesheet Knuckles	154
S2.13.12	Repair of Tubesheets	156
S2.13.12.1	Weld Buildup of Wastage and Grooving in Tubesheets	156
S2.13.12.2	Welded Repair of Cracks in Tubesheets	156
S2.13.12.3	Welded Flush Patches in Tubesheets	157
S2.13.13	Seams, Joints, and Rivets	158

S2.13.13.1	Caulking Riveted Seams and Rivet Heads	158
S2.13.13.2	Rivet Holes	159
S2.13.13.3	Assembly of Riveted Joints	159
S2.13.13.4	Riveting	159
S2.13.13.5	Seal Welding Seam, Joints, and Rivet Heads	162
S2.13.14	Repair of Openings	163
S2.13.14.1	Repair of Threaded Openings	163
S2.13.14.2	Repair of Handhole Openings	163
S2.13.14.3	Repair of Fusible Plug Opening	164
S2.13.14.4	Repair of Handhole Doors	165
Supplement 3 Repair and Alteration of Graphite Pressure Equipment		166
S3.1	Scope	166
S3.2	Repairs	166
S3.3	Repairs of a Routine Nature	168
S3.4	Alterations	168
S3.5	Repair Guide for Impervious Graphite	169
S3.5.1	Introduction	169
S3.5.2	Typical Graphite Fractures	173
S3.5.2.1	Major Fracture	173
S3.5.2.2	Intermediate Fracture	173
S3.5.2.3	Minor Fracture	174
S3.5.2.4	Finishing the Repair	175
S3.5.3	Graphite Repair by Plug Stitching	175
S3.5.3.1	Plug Stitching Procedure	176
S3.5.3.2	Figures – Typical Plug Stitching Procedure	177
S3.5.4	Reimpregnation of Graphite Parts (Tubesheets, Heads, and Blocks)	177
S3.5.4.1	Control of Impregnation Material	178
S3.5.4.2	Finishing the Repair	178
S3.5.5	Plugging or Leaking of Damaged Tubes	179
S3.5.6	Tube Replacement	179
S3.5.7	Reimpregnation of Graphite Parts (Tubesheets, Heads, and Blocks).....	182
S3.5.7.1	Control of Impregnation Material	183
Supplement 4 Repair and Alteration of Fiber-Reinforced Thermosetting Plastic Pressure Equipment		184
S4.1	Scope	184
S4.2	Inspector Qualifications	184
S4.3	Tools	185
S4.4	Limitations	185
S4.5	Repair Limitations for Filament Wound Vessels	185
S4.6	Vessels Fabricated Using Elevated Temperature Cured Resin Systems	185
S4.7	Code of Construction.....	186
S4.8	Materials.....	186
S4.9	Replacement Parts.....	186
S4.10	Secondary Bonding	186
S4.10.1	Secondary Bonding Procedure Specifications	186
S4.10.2	Performance Qualifications	187
S4.10.3	Records	187
S4.10.4	Secondary Bonder's Identification	187
S4.10.5	Secondary Bonder's Continuity	187
S4.11	Curing.....	187
S4.12	Nondestructive Examination.....	187
S4.13	Pressure and Acoustic Emission Tests.....	192
S4.13.1	Pressure Gages, Measurement, and Examination and Test Equipment.....	192
S4.14	Acceptance Inspection	192
S4.14.1	Stamping	192
S4.14.2	Documentation	192
S4.14.3	Registration of Documentation	192

S4.14.4	Distribution of Documentation	192
S4.15	Pressure Testing For Repairs	192
S4.16	Additional Requirements for Repairs	193
S4.16.1	Scope	193
S4.16.2	Drawings	193
S4.16.3	Repair Plan	193
S4.16.4	Routine Repairs	194
S4.16.5	Repair Methods	194
S4.17	Additional Requirements for Alterations	194
S4.17.1	Scope	194
S4.17.2	Design	194
S4.17.3	Alteration Plan	195
S4.17.4	Calculations	195
S4.17.5	Re-Rating	195
S4.17.6	Pressure Testing.....	196
S4.18	Repair and Alteration Methods	197
S4.18.1	General Requirements	197
S4.18.2	Classification of Repairs	197
S4.18.2.1	Type 1A – Repair of the Corrosion Barrier	197
S4.18.2.2	Type 1B – Repair of the Corrosion Barrier for Vessels with Precision Bores	199
S4.18.2.3	Type 2 – Corrosion Barrier and Internal Structural Layer Repairs	201
S4.18.2.4	Type 3 – External Structural Layer Repairs	201
S4.18.2.5	Type 4 – Alterations	203
S4.18.2.6	Type 5 – Miscellaneous General External Repairs or Alterations	203
S4.18.2.7	Type 6 – Thermoplastic Repairs	203
S4.18.2.8	Type 7 – Gel Coat Repairs	204
Supplement 5	General Requirements for Repairs and Alterations to Yankee Dryers	205
S5.1	Scope	205
S5.2	Examinations and Test Methods	205
S5.3	Yankee Dryer Repair Methods	205
S5.3.1	Replacement Parts for Yankee Dryers	205
S5.4	Repair Guide for Yankee Dryers	205
S5.5	Procedures That Do Not Require Stamping or Nameplate Attachment	206
S5.6	Damage Repair	206
S5.6.1	Repair of Local Thinning	206
S5.6.2	Treatment of Crack-Like Flaws	207
S5.6.3	Driven Plug Repair	208
S5.6.4	Threaded Plug Repair	208
S5.7	Alterations to Yankee Dryers	208
S5.7.1	Scope	208
S5.7.2	Alteration Types	208
Supplement 6	Repair, Alteration, and Modification of DOT Transport Tanks	210
S6.1	Scope	210
S6.2	Definitions.....	210
S6.3	Construction Standards.....	210
S6.4	Accreditation and Registration	210
S6.5	Materials.....	210
S6.6	Replacement Parts.....	210
S6.7	Authorization	211
S6.8	Inspection.....	211
S6.8.1	Inspector Duties for Repairs, Alterations, and Modifications	211
S6.9	Welding	212
S6.9.1	Welding Procedure Specification	212
S6.9.2	Standard Welding Procedure Specifications	212
S6.9.3	Performance Qualification	212
S6.9.4	Welding Records.....	212
S6.9.5	Welders' Identification	213

S6.9.6	Welders' Continuity	213
S6.10	Heat Treatment.....	213
S6.10.1	Preheating.....	213
S6.10.2	Postweld Heat Treatment	213
S6.10.3	Alternatives to Postweld Heat Treatment	213
S6.11	Nondestructive Examination.....	214
S6.12	Coatings and Linings.....	214
S6.13	Measurement, Examination, and Test Equipment	214
S6.14	Acceptance Inspection	214
S6.15	General Stamping Requirements	214
S6.15.1	Specific "R" Stamping and Nameplate Requirements.....	215
S6.15.2	Removal of Original Stamping or Nameplate	215
S6.16	"R" Forms	216
S6.16.1	Documentation	216
S6.16.2	Preparation of "R" Forms.....	216
S6.16.3	Distribution	216
S6.16.4	Registration of Form R-1 and Form R-2.....	216
S6.17	Additional Requirements for Repairs, Alterations, or Modifications.....	216
S6.17.1	Scope	216
S6.17.2	Repairs of Defects.....	216
S6.17.3	Modifications	217
S6.17.4	Drawings	217
S6.17.5	Authorization	217
S6.18	Examination and Test.....	217
S6.18.1	Methods.....	217
S6.19	Repairs, Alterations, or Modification Reports	218
Supplement 7 Repair and Alterations of Pressure Vessels in Liquefied Petroleum Gas Service		219
S7.1	Scope	219
S7.2	General and Administrative Requirements	219
S7.3	Welding	219
S7.4	Requirements for Repairs and Alterations	219
S7.5	Requirements for Change of Service from Above Ground to Underground Service.....	219
S7.6	Examination and Testing	219
S7.7	Certification/Documentation and Stamping	220
S7.8	Inspection	220
S7.9	Coatings	220
Supplement 8 Weld and Post Repair Inspection of Creep Strength Enhanced Ferritic Steel		
Pressure Equipment		221
S8.1	Scope	221
S8.2	Weld Repair of Grade 91 Steel	221
S8.2.1	Weld Repair Options	221
S8.3	Application of Controlled Fill Welding Procedure	222
S8.4	Qualification of Controlled Fill Welding Procedure	226
S8.5	Post Repair Inspection	227
Section 7 NBIC Policy for Metrication		228
7.1	General	228
7.2	Equivalent Rationale	228
7.3	Procedure for Conversion	228
7.4	Referencing Tables	229
Section 8 Preparation of Technical Inquiries to the National Board Inspection		
Code Committee.....		234
8.1	Introduction	234
8.2	Inquiry Format	234
8.3	Code Revisions or Additions	235
8.4	Code Interpretations	235

8.5	Submittals	236
Section 9	Glossary of Terms	237
9.1	Definitions	237
Section 10	NBIC Approved Interpretations	244
10.1	Scope	244
Section 11	Index	253

INTRODUCTION

It is the purpose of the National Board Inspection Code (NBIC) to maintain the integrity of pressure-retaining items by providing rules for post-construction activities including installation, and after the items have been placed into service, by providing rules for inspection and repair and alteration, thereby ensuring that these items may continue to be safely used.

The NBIC is intended to provide rules, information, and guidance to manufacturers, Jurisdictions, inspectors, owner-users, installers, contractors, and other individuals and organizations performing or involved in post-construction activities, thereby encouraging the uniform administration of rules pertaining to pressure retaining items.

SCOPE

The NBIC recognizes three important areas of post-construction activities where information, understanding, and following specific requirements will promote public and personal safety. These areas include:

- Installation
- Inspection
- Repairs and Alterations

The NBIC provides rules, information, and guidance for post-construction activities, but does not provide details for all conditions involving pressure-retaining items. Where complete details are not provided in this code, the code user is advised to seek guidance from the Jurisdiction and from other technical sources.

The words shall, should, and may are used throughout the NBIC and have the following intent:

- Shall – action that is mandatory and required.
- Should – indicates a preferred but not mandatory means to accomplish the requirement unless specified by others such as the Jurisdiction.
- May – permissive, not required or a means to accomplish the specified task.

ORGANIZATION

The NBIC is organized into four parts to coincide with specific post-construction activities involving pressure-retaining items. Each part provides general and specific rules, information, and guidance within each applicable post-construction activity. Other NBIC parts or other published standards may contain additional information or requirements needed to meet the rules of the NBIC. Specific references are provided in each part to direct the user where to find this additional information. NBIC parts are identified as:

- Part 1, Installation – This part provides requirements and guidance to ensure all types of pressure retaining items are installed and function properly. Installation includes meeting specific safety criteria for construction, materials, design, supports, safety devices, operation, testing, and maintenance.
- Part 2, Inspection – This part provides information and guidance needed to perform and document inspections for all types of pressure-retaining items. This part includes information on personnel safety, non-destructive examination, tests, failure mechanisms, types of pressure equipment, fitness for service, risk-based assessments, and performance-based standards.
- Part 3, Repairs and Alterations – This part provides requirements and guidance to perform, verify, and document acceptable repairs or alterations to pressure retaining items regardless of code of construction. Alternative methods for examination, testing, heat treatment, etc., are provided when the original code of construction requirements cannot be met. Specific acceptable and proven repair methods are also provided.
- Part 4, Pressure Relief Devices – This part provides information and guidance to ensure pressure relief devices are installed properly, information and guidance needed to perform and document inspections for pressure relief devices, and information and guidance to perform, verify, and document acceptable repairs to pressure relief devices.

Each NBIC part is divided into major sections as outlined in the Table of Contents.

Tables, charts, and figures provide relevant illustrations or supporting information for text passages, and are designated with numbers corresponding to the paragraph they illustrate or support within each section. Multiple tables, charts, or figures referenced by the same paragraph will have additional letters reflecting the order of reference. Tables, charts, and figures are located in or after each major section within each NBIC part.

TEXT IDENTIFICATION AND NUMBERING

Each page in the text will be designated in the top header with the publication's name, part number, and part title. The numbering sequence for each section begins with the section number followed by a dot to further designate major sections (e.g., 1.1, 1.2, 1.3). Major sections are further subdivided using dots to designate subsections within that major section (e.g., 1.1.1, 1.2.1, 1.3.1). Subsections can further be divided as necessary. Paragraphs under sections or subsections shall be designated with small letters in parenthesis (e.g., a), b), c)) and further subdivided using numbers in parenthesis (e.g., 1), 2), 3)).

Subdivisions of paragraphs beyond this point will be designated using a hierarchical sequence of letters and numbers followed by a dot.

Example: 2.1 Major Section
 2.1.1 Section
 2.1.2 Section
 2.1.2. Subsection
 a) paragraph
 b) paragraph
 1) subparagraph
 2) subparagraph
 a. subdivisions
 1. subdivisions
 2. subdivisions
 b. subdivisions
 1. subdivisions
 2. subdivisions

Tables and figures will be designated with the referencing section or subsection identification. When more than one table or figure is referenced in the same section or subsection, letters or numbers in sequential order will be used following each section or subsection identification.

SUPPLEMENTS

Supplements are contained in each part of the NBIC to provide requirements and guidance only pertaining to a specific type of pressure-retaining item (e.g., Locomotive Boilers, Historical Boilers, Graphite Pressure Vessels.) Supplements follow the same numbering system used for the main text only preceded by the Letter "S." Each page of the supplement will be tabbed to identify the supplement number.

EDITIONS

Editions, which include revisions and additions to this code, are published every two years. Editions are permissive on the date issued and become mandatory six months after the date of issue.

CODE STAMPING

ASME Code "Stamping" referenced throughout the NBIC includes the ASME Boiler and Pressure Vessel Code Symbol Stamps used for conformity assessment prior to the 2010 edition/2011 addendum and the equivalent ASME Certification Mark with Designator required to meet the later editions of the ASME Boiler and Pressure Vessel Code Sections. When other construction codes or standards are utilized for repairs or alterations, stamping shall mean the identification symbol stamp required by that code or standard.

INTERPRETATIONS

On request, the NBIC Committee will render an interpretation of any requirement of this code. Interpretations are provided for each part and are specific to the code edition and addenda referenced in the interpretation. Interpretations provide clarification of existing rules in the code only and are not part of this code.

JURISDICTIONAL PRECEDENCE

Reference is made throughout this code to the requirements of the “Jurisdiction.” Where any provision herein presents a direct or implied conflict with any jurisdictional regulation, the Jurisdictional regulation shall govern.

UNITS OF MEASUREMENT

Both U.S. customary units and metric units are used in the NBIC. The value stated in U.S. customary units or metric units are to be regarded separately as the standard. Within the text, the metric units are shown in parentheses. In Part 2, Supplement 6 and Part 3, Supplement 6 regarding DOT Transport Tanks, the metric units are shown first with the U.S. customary units shown in parentheses.

U.S. customary units or metric units may be used with this edition of the NBIC, but one system of units shall be used consistently throughout a repair or alteration of pressure-retaining items. It is the responsibility of National Board accredited repair organizations to ensure the appropriate units are used consistently throughout all phases of work. This includes materials, design, procedures, testing, documentation, and stamping. The NBIC policy for metrication is outlined in each part of the NBIC.

ACCREDITATION PROGRAMS

The National Board administers and four specific accreditation programs, as shown below:

- “R”.....Repairs and Alterations to Pressure-Retaining Items (NB-415)
- “VR”.....Repairs to Pressure Relief Valves (NB-514)
- “NR”.....Repair and Replacement Activities for Nuclear Items (NB-417)
- “T/O”.....Testing of Pressure Relief Valves (NB-528)

The administrative requirements for the accreditation for these accreditation programs can be viewed on the National Board Website at www.nationalboard.org.

The National Board also administers and accredits four specific inspection agency programs as shown below:

New Construction

Criteria for Acceptance of Authorized Inspection Agencies for New Construction (NB-360)

Inservice

Qualifications and Duties for Authorized Inspection Agencies (AIAs) Performing Inservice Inspection Activities and Qualifications for Inspectors of Boilers and Pressure Vessels (NB-369)

Owner-User

Accreditation of Owner-User Inspection Organizations (OUIO) (NB-371)

Owners or users may be accredited for both a repair and inspection program provided the requirements for each accreditation program are met.

Federal Government

Qualifications and Duties for Federal Inspection Agencies Performing Inservice Inspection Activities (FIAs) (NB-390)

These programs can be viewed on the National Board Website at www.nationalboard.org. For questions or further information regarding these programs contact the National Board by phone at (614) 888-8320 or by fax at (614) 847-1828.

CERTIFICATES OF AUTHORIZATION FOR ACCREDITATION PROGRAMS

Any organization seeking an accredited program may apply to the National Board to obtain a Certificate of Authorization for the requested scope of activities. A confidential review shall be conducted to evaluate the organization's quality system. Upon completion of the evaluation, a recommendation will be made to the National Board regarding issuance of a Certificate of Authorization.

Certificate of Authorization scope, issuance, and revisions for National Board accreditation programs are specified in the applicable National Board procedures. When the quality system requirements of the appropriate accreditation program have been met, a Certificate of Authorization and appropriate National Board symbol stamp shall be issued.

FOREWORD

The National Board of Boiler and Pressure Vessel Inspectors is an organization comprised of Chief Inspectors for the states, cities, and territories of the United States and provinces and territories of Canada. It is organized for the purpose of promoting greater safety to life and property by securing concerted action and maintaining uniformity in post-construction activities of pressure-retaining items, thereby ensuring acceptance and interchangeability among Jurisdictional authorities responsible for the administration and enforcement of various codes and standards.

In keeping with the principles of promoting safety and maintaining uniformity, the National Board originally published the NBIC in 1946, establishing rules for inspection and repairs to boilers and pressure vessels. The *National Board Inspection Code* (NBIC) Committee is charged with the responsibility for maintaining and revising the NBIC. In the interest of public safety, the NBIC Committee decided, in 1995, to revise the scope of the NBIC to include rules for installation, inspection, and repair or alteration to boilers, pressure vessels, piping, and nonmetallic materials.

In 2007, the NBIC was restructured into three parts specifically identifying important post-construction activities involving safety of pressure-retaining items. This restructuring provides for future expansion, transparency, uniformity, and ultimately improving public safety.

In 2017, the NBIC was once again restructured into 4 parts, adding a new Part 4, Pressure Relief Devices. This purpose of this restructuring was to provide one distinct integrated part for pressure relief devices compiled from all PRD information referenced in Part 1, Installation; Part 2, Inspection; and Part 3, Repairs and Alterations.

The NBIC Committee's function is to establish rules of safety governing post-construction activities for the installation, inspection, and repair and alteration of pressure-retaining items, and to interpret these rules when questions arise regarding their intent. In formulating the rules, the NBIC Committee considers the needs and concerns of individuals and organizations involved in the safety of pressure-retaining items. The objective of the rules is to afford reasonably certain protection of life and property, so as to give a reasonably long, safe period of usefulness. Advancements in design and material and the evidence of experience are recognized.

The rules established by the NBIC Committee are not to be interpreted as approving, recommending, or endorsing any proprietary or specific design, or as limiting in any way an organization's freedom to choose any method that conforms to the NBIC rules.

The NBIC Committee meets regularly to consider revisions of existing rules, formulation of new rules, and respond to requests for interpretations. Requests for interpretation must be addressed to the NBIC Secretary in writing and must give full particulars in order to receive Committee consideration and a written reply. Proposed revisions to the code resulting from inquiries will be presented to the NBIC Committee for appropriate action.

Proposed revisions to the code approved by the NBIC Committee are submitted to the American National Standards Institute and published on the National Board web-site to invite comments from all interested persons. After the allotted time for public review and final approval, the new edition is published. The Foreword, Introduction, Personnel and Index Sections of the NBIC are provided for guidance and informational purposes only and shall not be considered a part of the Code. These sections are not approved by the NBIC Committee or submitted to the American National Standards Institute.

Organizations or users of pressure-retaining items are cautioned against making use of revisions that are less restrictive than former requirements without having assurance that they have been accepted by the Jurisdiction where the pressure-retaining item is installed.

The general philosophy underlying the NBIC is to parallel those provisions of the original code of construction, as they can be applied to post-construction activities. The NBIC does not contain rules to cover all details of post-construction activities. Where complete details are not given, it is intended that individuals or organizations, subject to the acceptance of the Inspector and Jurisdiction when applicable, provide details

for post-construction activities that will be as safe as otherwise provided by the rules in the original code of construction.

Activities not conforming to the rules of the original code of construction or the NBIC must receive specific approval from the Jurisdiction, who may establish requirements for design, construction, inspection, testing, and documentation.

There are instances where the NBIC serves to warn against pitfalls; but the code is not a handbook, and cannot substitute for education, experience, and sound engineering judgment. It is intended that this edition of the NBIC not be retroactive. Unless the Jurisdiction imposes the use of an earlier edition, the latest effective edition is the governing document.

PERSONNEL

The National Board of Boiler and Pressure Vessel Inspectors

Board of Trustees

J. Burpee
Chairman

J. Amato
First Vice Chairman

D. Cook
Second Vice Chairman

C. Cantrell
Member at Large

E. Creaser
Member at Large

A. Oda
Member at Large

M. Washington
Member at Large

D. Douin
Secretary/Treasurer

Advisory Committee

J. Pillow
Representing welding industries

C. Hopkins
Representing National Board stamp holders

H. Richards
Representing boiler and pressure vessel users

B. Berquist
Representing pressure vessel manufacturers

R. Wielgoszinski
Representing authorized inspection agencies
(insurance companies)

P. Molvie
Representing boiler manufacturers

National Board Members

Alabama	Marvin Byrum
Alaska	Kenneth Lane
Arizona	Randall Austin
Arkansas	Dennis Hannon
California	Donald Cook
Colorado	Steve Nelson
Delaware	John Esch
Florida	Andrew Frazier
Georgia	Benjamin Crawford
Hawaii	Julius Dacanay
Illinois	Michael Vogel
Indiana	Larry Parkey
Kansas	Robert Stimson
Kentucky	Mark Jordan
Louisiana	Joseph LeSage
Maine	John Burpee
Maryland	Karl Kraft
Massachusetts	Edward Kawa
Michigan	David Stenrose
Minnesota	Joel Amato
Mississippi	William Anderson
Missouri	Ronald Brockman
Nebraska	Christopher B. Cantrell
Nevada	David Sandfoss
New Hampshire	Darrell Mallory
New Jersey	Milton Washington
New York	Matthew Sansone
North Carolina	Clifford Dautrich
North Dakota	Trevor Seime
Ohio	John Sharier
Oklahoma	Thomas Granneman
Oregon	Mark Perdue
Pennsylvania	Nathaniel Smith
South Carolina	Ronald W. Spiker
South Dakota	Aaron Lorimor
Tennessee	Sam Chapman
Texas	Rob Troutt
Utah	Rick Sturm
Virginia	Edward Hilton
Washington	Tony Oda
West Virginia	John Porcella
Wisconsin	Terrence Waldbillig
Chicago, IL	Michael Ryan
Detroit, MI	Cortney Jackson
Los Angeles, CA	Cirilo Reyes
Milwaukee, WI	Jillian Klug
New York, NY	William McGivney
Seattle, WA	Larry Leet
Alberta	Michael Pohlmann
British Columbia	Anthony Scholl
Manitoba	Ryan DeLury
New Brunswick	Eben Creaser
Newfoundland & Labrador	Dennis Eastman
Northwest Territories	Matthias Mailman
Nova Scotia	Peter Dodge
Ontario	Michael Adams
Prince Edward Island	Steven Townsend
Quebec	Aziz Khssassi
Saskatchewan	Christopher Selinger

National Board Inspection Code Main Committee

D. Cook, Chair
State of California

R. Wielgoszinski, Vice Chair
*Hartford Steam Boiler Inspection and
Insurance Company*

B. Besserman, Secretary
National Board

J. Amato
State of Minnesota

R. Austin
State of Arizona

S. Cammeresi
Furmanite

P. Edwards
WECTEC

G. Galanes
Diamond Technical Services, Inc.

J. Getter
Worthington Industries

C. Hopkins
Seattle Boiler Works, Inc.

L. McManoman
Great Lakes Area Apprenticeship Program

M. Mooney
Liberty Mutual Insurance Company

B. Morelock
Eastman Chemical Company

V. Newton
XL Insurance

J. Pillow
Common Arc

M. Richards
Consultant

J. Riley
Phillips 66

J. Sekely
Consultant

K. Simmons
Pentair

S. Staniszewski Jr.
U.S. Department of Transportation

R. Troutt
State of Texas

M. Wadkinson
Fulton Boiler Works, Inc.

M. Webb
Xcel Energy Services

P. Welch
Arise Boiler Inspection and Insurance Company

**National Board Inspection Code
Subcommittee Installation (Part 1)**

H. Richards, Chair
Consultant

D. Patten, Vice Chair
Bay City Boiler

J. Bock, Secretary
National Board

R. Austin
State of Arizona

G. Halley
ABMA

S. Konopacki
NRG

B. Moore
*Hartford Steam Boiler Inspection and
Insurance Company*

P. Schuelke
Well-McLain

R. Smith
Authorized Inspection Associates

M. Wadkinson
Fulton Boiler Works, Inc.

E. Wiggins
Liberty Mutual Insurance Company

**National Board Inspection Code
Subcommittee Inspection (Part 2)**

M. Mooney, Chair
Liberty Mutual Insurance Company

S. Staniszewski, Vice Chair
US Department of Transportation

J. Metzmaier, Secretary
National Board

T. Barker
FM Global

E. Brantley
XL Insurance

D. Buechel
*Hartford Steam Boiler Inspection and
Insurance Company*

D. Ford
U.S. Department of Transportation

J. Getter
Worthington Cylinders

D. Graf
Air Products and Chemicals, Inc.

M. Horbaczewski
Diamond Technical Services

G. McRae
Trinity Industries, Inc.

V. Newton
XL Insurance

J. Riley
Phillips 66

M. Schwartzwalder
Stress Engineering Services

T. Vandini
Quality Steel Corporation

P. Welch
ARISE

**National Board Inspection Code
Subcommittee for Repairs and Alterations
(Part 3)**

G. Galanes, Chair
Diamond Technical Services, Inc.

J. Pillow, Vice Chair
Common Arc Corporation

W. Vallance, Secretary
National Board

J. Amato
State of Minnesota

B. Boseo
Graycor Services LLC

A. Bramucci
GE Renewable Energy

P. Edwards
WECTEC

C. Hopkins
Seattle Boiler Works, Inc.

W. Jones
Arise, Inc.

L. McManoman
Great Lakes Area Apprenticeship Program

R. Miletti
Babcock and Wilcox Construction Company, Inc.

L. Moedinger
Strasburg Railroad Company

K. Moore
Joe Moore Company

B. Morelock
Eastman Chemical Company

B. Schaefer
AEP

J. Sekely
Consultant

M. Toth
Boiler Supply Company, Inc.

R. Troutt
State of Texas

M. Webb
Xcel Energy

**National Board Inspection Code
Subcommittee Pressure Relief Devices
(Part 4)**

S. Cammeresi, Chair
Furmanite

A. Cox, Vice Chair
JAC Consulting

T. Beirne, Secretary
National Board

K. Beise
Dowco Valve Company, Inc.

M. Brodeur
International Valve & Instr. Corp.

D. DeMichael
Chemours Co.

R. Donalson
Pentair

B. Hart
FM Global

D. Marek
Mainthia Technologies

R. McCaffrey
Quality Valve

D. McHugh
Allied Valve, Inc.

B. Nutter
E.I. Dupont De Nemours & Co.

T. Patel
Farris Engineering

A. Renaldo
Praxair, Inc.

K. Simmons
Pentair

National Board Inspection Code Subgroup Installation (Part 1)

M. Wadkinson, Chair
Fulton Boiler Works, Inc.

D. Patten, Vice Chair
Bay City Boiler

J. Bock, Secretary
National Board

R. Austin
State of Arizona

T. Creacy
Zurich Services Corporation

G. Halley
ABMA

S. Konopacki
NRG Energy

J. Millette
UAB

B. Moore
*Hartford Steam Boiler Inspection and
Insurance Company*

H. Richards
Consultant

P. Schuelke
Well-McLain

R. Smith
Authorized Inspection Associates

M. Washington
State of New Jersey

E. Wiggins
Liberty Mutual Insurance Company

National Board Inspection Code Subgroup Inspection (Part 2)

J. Getter, Chair
Worthington Industries

M. Schwartzwalder, Vice Chair
AEP

J. Metzmaier, Secretary
National Board

T. Barker
FM Global

E. Brantley
XL Insurance America, Inc.

D. Ford
US Department of Transportation

D. Graf
Air Products and Chemicals, Inc.

B. Hart
Factory Mutual Insurance Company

M. Horbaczewski
Midwest Generation

G. McRae
Trinity Industries, Inc.

M. Mooney
Liberty Mutual Insurance

V. Newton
XL Insurance America

J. Riley
Phillips 66

S. Staniszewski
US Department of Transportation

T. Vandini
Quality Steel Corporation

P. Welch
Arise, Inc.

National Board Inspection Code Subgroup for Repairs and Alterations (Part 3)

A. Bramucci, Chair
GE Renewable Energy

W. Vallance, Secretary
National Board

J. Amato
State of Minnesota

B. Boseo
Graycor Services LLC

N. Carter
*Hartford Steam Boiler Inspection and
Insurance Company*

R. Cauthon
Alstom Power

P. Edwards
WECTEC

G. Galanes
Diamond Technical Services, Inc.

C. Hopkins
Seattle Boiler Works, Inc.

F. Johnson
PBF Energy

W. Jones
Arise, Inc.

D. Martinez
FM Global

L. McManoman
Great Lakes Area Apprenticeship Program

R. Miletti
Babcock and Wilcox Construction Company, Inc.

K. Moore
Joe Moore Company

B. Morelock
Eastman Chemical

J. Pillow
Common Arc Corporation

B. Schaefer
AEP

J. Sekely
Consultant

W. Sperko
Sperko Engineering Services

M. Toth
Boiler Supply Company, Inc.

R. Troutt
State of Texas

R. Valdez
ARB, Inc.

J. Walker
Hayes Mechanical

M. Webb
Xcel Energy

T. White
NRG Energy

National Board Inspection Code Subgroup Graphite

E. Soltow, Chair
SGL Carbon Technic

B. Besserman, Secretary
National Board

G. Becherer
CG Thermal

F. Brown
Consultant

C. Cary
Dow Corning

J. Clemens
Graphite Maintenance

K. Cummins
Louisville Graphite

B. Dickerson
Mersen

B. Jones
Mersen

R. Selvaraj
Mersen

D. Sholar
Mersen

A. Stupica
SGL Carbon Technic

A. Viet
CG Thermal

National Board Inspection Code Subgroup Fiber-Reinforced Pressure Vessels

B. Shelley, Chair
Chemours

B. Besserman, Secretary
National Board

F. Brown
Consultant

J. Bustillos
Bustillos and Associates

T. Cowley
FRP Consulting

D. Eisberg
Avista Technologies

M. Gorman
Digital Wave

D. Hodgkinson
Consultant

D. Keeler
The Dow Chemical Company

D. McCauley
Chemours

N. Newhouse
Hexagon Lincoln

A. Pollock
Mistras Group

J. Richter
Thorpe Plant Services

N. Sirosh
LightSail Energy

National Board Inspection Code Subgroup Locomotive Boilers

L. Moedinger, Chair
Strasburg Railroad

M. Janssen, Vice Chair
Vapor Locomotive Company

B. Ferrel, Secretary
National Board

S. Butler
Midwest Locomotive & Machine Works

D. Conrad
Valley Railroad Co.

R. Franzen
Steam Services of America

D. Griner
Arizona Mechanical Engineering

S. Lee
Union Pacific Railroad

D. McCormack
Consultant

G. Ray
Tennessee Valley Authority

R. Stone
ARVOS, Inc.

National Board Inspection Code Subgroup Historical Boiler

J. Amato, Chair
State of Minnesota

T. Dillon, Vice Chair
MSEA

B. Ferrell, Secretary
National Board

J. Getter
Worthington Industries

F. Johnson
PBF Energy

M. Jordan
State of Kentucky

D. Rose
T&T Inspections

D. Rupert
Consultant

R. Underwood
*Hartford Steam Boiler Inspection and
Insurance Company*

M. Wahl
WHSEA

PART 3, SECTION 1 REPAIRS AND ALTERATIONS — GENERAL AND ADMINISTRATIVE REQUIREMENTS

(17) 1.1 SCOPE

- a) This part provides requirements and guidelines that apply when performing repairs and alterations to pressure-retaining items.
- b) The National Board administers three specific accreditation programs:
 - 1) “R” — Repairs and Alterations to Pressure-Retaining Items
 - 2) “NR” — Repair and Replacement Activities for Nuclear Items
 - 3) “VR” — Repairs to Pressure Relief Valves
- c) This part describes some of the administrative requirements for the accreditation of repair organizations. Additional administrative requirements can be found in:
 - 1) NB-415, Accreditation of “R” Repair Organizations
 - 2) NB-417, Accreditation of “NR” Repair Organizations
 - 3) NB-514, Accreditation of “VR” Repair Organizations
- d) Requirements for repairs to pressure relief valves can be found in NBIC Part 4.

(17) 1.2 CONSTRUCTION STANDARDS FOR PRESSURE-RETAINING ITEMS

- a) When the standard governing the original construction is the ASME Code or ASME RTP-1, repairs and alterations to pressure-retaining items shall conform, insofar as possible, to the section and edition of the ASME Code most applicable to the work planned.
- b) If the pressure-retaining item was not constructed to a construction code or standard, or when the standard governing the original construction is not the ASME Code or ASME RTP-1, repairs or alterations shall conform, insofar as possible, to the edition of the construction standard or specification most applicable to the work. Where this is not possible or practicable, it is permissible to use other codes, standards, or specifications, including the ASME Code or ASME RTP-1, provided the “R” or “NR” Certificate Holder has the concurrence of the Inspector and the Jurisdiction where the pressure-retaining item is installed.
- c) For historical boilers, ASME, Section I provides rules for design and features of construction.
- d) Piping systems are designed for a variety of service conditions such as steam, water, oil, gas, or air. Design requirements for repairs and alterations are to meet the original code of construction or the code most appropriate for the repair or alteration. These systems shall be designed for the most severe conditions of pressure, temperature, loadings, and expected transients considered for normal operation. All pipe materials, fittings, and valves shall be rated for the maximum service conditions for normal operation. Design corrosion of piping systems should also be considered when determining types of materials and thicknesses.
- e) For Transport Tanks, the Competent Authority, i.e. the U.S. Department of Transportation (DOT), shall be consulted for any requirements which it has established since they take precedence for repairs.



2017 NBIC

NATIONAL BOARD INSPECTION CODE

PART 4

PRESSURE RELIEF DEVICES

NATIONAL BOARD INSPECTION CODE
2017 EDITION
DATE OF ISSUE — JULY 1, 2017

This code was developed under procedures accredited as meeting the criteria for American National Standards. The Consensus Committee that approved the code was balanced to ensure that individuals from competent and concerned interests had an opportunity to participate. The proposed code was made available for public review and comment, which provided an opportunity for additional public input from industry, academia, regulatory and jurisdictional agencies, and the public-at-large.


The National Board does not “approve,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

The National Board does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable Letters Patent, nor assume any such liability. Users of a code are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code.

The National Board accepts responsibility for only those interpretations issued in accordance with governing National Board procedures and policies that preclude the issuance of interpretations by individual committee members.

The footnotes in this document are part of this American National Standard.



The above National Board symbols are registered with the US Patent Office.

“National Board” is the abbreviation for The National Board of Boiler and Pressure Vessel Inspectors.

No part of this document may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

All charts, graphs, tables, and other criteria that have been reprinted from the *ASME Boiler and Pressure Vessel Code*, Sections I, IV, VIII, and X are used with the permission of the American Society of Mechanical Engineers. All Rights Reserved.

Library of Congress Catalog Card No. 52-44738
 Printed in the United States of America
 All Rights Reserved

www.nationalboard.org

Copyright © 2017 by
 THE NATIONAL BOARD OF BOILER & PRESSURE VESSEL INSPECTORS
 All rights reserved
 Printed in U.S.A.

PART 4 — PRESSURE RELIEF DEVICES

TABLE OF CONTENTS

Introduction		VI
Foreword		X
Personnel		XXII
Section 1	General and Administrative Requirements	1
1.1	Scope	1
1.2	Construction Standards for Pressure-Retaining Items	1
1.3	Pressure Relief Devices—Definitions	1
1.3.1	Additional Definitions Related to Pressure Relief Devices	1
1.4	Accreditation	1
1.4.1	Accreditation Process	1
Section 2	Installation of Pressure Relief Devices	3
2.1	Scope	3
2.2	Pressure Relief Valves for Power Boilers	3
2.2.1	General Requirements	3
2.2.2	Number	3
2.2.3	Location	3
2.2.4	Capacity	4
2.2.5	Set Pressure	5
2.2.6	Forced-Flow Steam Generators	6
2.2.7	Superheaters	6
2.2.8	Economizers	7
2.2.9	Pressure Reducing Valves	7
2.2.10	Installation and Discharge Requirements	7
2.2.11	Supports, Foundations, and Settings	8
2.3	Overpressure Protection for Thermal Fluid Heaters	9
2.3.1	General Requirements	9
2.3.2	Pressure Relief Devices	9
2.3.3	Location	9
2.3.4	Capacity	9
2.3.5	Set Pressure	9
2.3.6	Installation	9
2.4	Pressure Relief Valves for Steam Heating, Hot Water Heating, and Hot Water Supply Boiler	11
2.4.1	General Requirements	11
2.4.1.1	Installation of Pressure Relief Valves for Heating Boilers	11
2.4.1.1.1	Permissible Installation	11
2.4.1.1.2	Requirements for Common Connections for Two or More Valves	11
2.4.1.2	Threaded Connections	12
2.4.1.3	Prohibited Installations	12
2.4.1.4	Use of Shutoff Valves Prohibited	12
2.4.1.5	Pressure Relief Valve Discharge Piping	12
2.4.1.6	Temperature and Pressure Relief Valves	12
2.4.2	Pressure Relief Valve Requirements for Steam Heating Boilers	12
2.4.3	Pressure Relief Valve Requirements for Hot Water Heating or Hot Water Supply Boilers	13
2.4.4	Temperature and Pressure Relief Valve Requirements for Potable Water Heaters	14
2.4.4.1	Installation	14
2.4.4.2	Permissible Installations	14
2.4.4.3	Requirements for Common Connection for Two or More Valves	15
2.4.4.4	Threaded Connections	15
2.4.4.5	Prohibited Installations	15
2.4.4.6	Use of Shutoff Valves Prohibited	15
2.4.4.7	Temperature and Pressure Relief Valve Discharge Piping	15
2.4.5	Pressure Relief Valves for Tanks and Heat Exchangers	16

2.4.5.1	Steam to Hot-Water Supply	16
2.4.5.2	High Temperature Water to Water Heat Exchanger	16
2.4.5.3	High Temperature Water to Steam Heat Exchanger	16
2.5	Pressure Vessel Pressure Relief Devices	16
2.5.1	Device Requirements	16
2.5.2	Number of Devices	16
2.5.3	Location	17
2.5.4	Capacity	17
2.5.5	Set Pressure	17
2.5.6	Installation and Discharge Piping Requirements	18
2.5.7	Temperature and Pressure Relief Devices for Hot Water Storage Tanks	19
2.6	Piping System Pressure Relief Devices	19
2.6.1	Device Requirements	19
2.6.2	Number of Devices	19
2.6.3	Location	20
2.6.4	Capacity	20
2.6.5	Set Pressure	20
2.6.6	Inlet and Discharge Piping Requirements	20
Section 3	In-service Inspection of Pressure Relief Devices	22
3.1	Scope	22
3.2	General	22
3.2.1	Pressure Relief Device Data	22
3.2.2	Inspection Requirements for Device Condition	23
3.2.3	Inspection Requirements for Installation Condition	23
3.2.4	Additional Inspection Requirements	24
3.2.4.1	Power Boilers	24
3.2.4.2	Hot-Water Heating Boilers, Hot Water Supply Boilers, and Water Heaters	24
3.2.4.3	Pressure Vessels and Piping	24
3.2.4.4	Rupture Disks	24
3.2.5	Testing and Operational Inspection of Pressure Relief Devices	26
3.2.5.1	Corrective Action	27
3.2.5.2	Valve Adjustments	27
3.2.6	Recommended Inspection and Testing Frequencies for Pressure Relief Devices	28
3.2.6.1	Establishment of Inspection and Test Intervals	29
3.2.6.2	Establishment of Service Intervals	29
Section 4	Repair of Pressure Relief Valves	31
4.1	Scope	31
4.2	General Requirements	31
4.2.1	VR Repair	31
4.2.2	Construction Standards for Pressure Relief Devices	32
4.2.3	Installation of Pressure Relief Devices	32
4.2.4	Initial Adjustments to Pressure Relief Valves	32
4.3	Materials for Pressure Relief Valve Repair.....	32
4.3.1	Replacement Parts for Pressure Relief Devices	32
4.4	Welding for Pressure Relief Valves	33
4.4.1	Welding Procedure Specifications.....	33
4.4.2	Standard Welding Procedure Specifications	34
4.4.3	Performance Qualification	34
4.4.4	Welding Records	34
4.4.5	Welder's Identification	34
4.4.6	Welder's Continuity	34
4.4.7	Weld Repairs to Pressure Relief Valve Parts by an "R" Stamp Holder	34
4.5	Heat Treatment.....	35
4.5.1	Preheating	35
4.5.2	Postweld Heat Treatment	35
4.6	Pressure Relief Valve Performance Testing and Testing Equipment	35
4.6.1	Test Medium and Testing Equipment	35

4.6.2	Owner-User ASME Code Section VIII Steam Testing	36
4.6.3	Lift Assist Testing	36
4.6.4	Pressure Test of Parts	37
4.7	Stamping Requirements for Pressure Relief Devices	38
4.7.1	Nameplates	38
4.7.2	Repair Nameplates	38
4.7.3	Changes to Original Pressure Relief Valve Nameplate Information	39
4.7.4	Test Only Nameplate	40
4.7.5	Replacement of Illegible or Missing Nameplates	40
4.8	Accreditation of "VR" Repair Organizations	40
4.8.1	Scope	40
4.8.2	Jurisdictional Participation	41
4.8.3	Issuance and Renewal of the "VR" <i>Certificate of Authorization</i>	41
4.8.3.1	General.....	41
4.8.3.2	Issuance of Certificate	41
4.8.4	Use of the "VR" Authorization	41
4.8.4.1	Technical Requirements	41
4.8.4.2	Stamp Use	41
4.8.5	Quality System	41
4.8.5.1	General	41
4.8.5.2	Written Description	41
4.8.5.3	Maintenance of Controlled Copy	42
4.8.5.4	Outline of Requirements for a Quality System	42
4.8.6	Field Repair	47
4.8.6.1	Audit Requirements	47
4.8.6.2	Use of Owner or User Personnel	47
4.9	Training and Qualification of Personnel	47
4.9.1	Contents of Training Program	47
4.9.2	Qualification of Personnel	48
4.9.3	Annual Review of Qualification	48
Section 5	INTENTIONALLY LEFT BLANK	49
Section 6	Supplements	50
Supplement 1	Pressure Relief Valves on the Low Pressure side of Steam Pressure	
	Reducing Valves	50
S1.1	Scope	50
S1.2	Pressure Relief Valve Capacity	50
S1.3	Calculation of Pressure Relief Valve Relieving Capacity	51
S1.4	Steam Flow When Flow Coefficients Are Not Known.....	58
S1.5	Two-Stage Pressure Reducing Valve Stations	58
Supplement 2	Pressure Differential Between Pressure Relief Valve Setting	
	and Boiler or Pressure Vessel Operating Pressure	60
S2.1	Scope	60
S2.2	Hot Water Heating Boilers	60
S2.3	Steam Heating Boilers.....	60
S2.4	Power Boilers	60
S2.5	Pressure Vessels.....	61
Supplement 3	Guide to Jurisdictions for Authorization of Owners	
	or Users to Make Adjustments to Pressure Relief Valves	63
S3.1	General	63
S3.2	Training	63
S3.3	Documentation	63
S3.4	Quality System	63
S3.5	External Adjustments	64
S3.6	Repairs	64

Supplement 4 Recommended Procedures for Repairing Pressure Relief Valves	65
S4.1 Introduction	65
S4.2 Spring-Loaded Pressure Relief Valves	65
S4.3 Pilot Operated Pressure Relief Valves	67
S4.4 Packaging, Shipping and Transportation of Pressure Relief Devices	69
Supplement 5 Recommended Guide for the Design of a Test System for Pressure Relief Devices in Compressible Fluid Service	70
S5.1 Scope	70
S5.2 General	70
S5.3 Test System Description	70
S5.4 Test Vessel Sizing Data	72
Supplement 6 Procedures for Repairs to ASME “NV” Stamped Pressure Relief Devices	74
S6.1 Introduction.....	74
S6.2 Administrative Procedures	74
S6.3 General Rules	74
Section 7 NBIC Policy for Metrication	76
7.1 General	76
7.2 Equivalent Rationale	76
7.3 Procedure for Conversion	76
7.4 Referencing Tables	77
Section 8 Preparation of Technical Inquiries to the <i>National Board Inspection Code Committee</i>	82
8.1 Introduction	82
8.2 Inquiry Format	82
8.3 Code Revisions or Additions	83
8.4 Code Interpretations	83
8.5 Submittals	84
Section 9 Glossary of Terms	85
9.1 Definitions	85
Section 10 NBIC Approved Interpretations	92
10.1 Scope	92
Section 11 Index	101

INTRODUCTION

It is the purpose of the National Board Inspection Code (NBIC) to maintain the integrity of pressure-retaining items by providing rules for post-construction activities including installation, and after the items have been placed into service, by providing rules for inspection and repair and alteration, thereby ensuring that these items may continue to be safely used.

The NBIC is intended to provide rules, information, and guidance to manufacturers, Jurisdictions, inspectors, owner-users, installers, contractors, and other individuals and organizations performing or involved in post-construction activities, thereby encouraging the uniform administration of rules pertaining to pressure retaining items.

SCOPE

The NBIC recognizes three important areas of post-construction activities where information, understanding, and following specific requirements will promote public and personal safety. These areas include:

- Installation
- Inspection
- Repairs and Alterations

The NBIC provides rules, information, and guidance for post-construction activities, but does not provide details for all conditions involving pressure-retaining items. Where complete details are not provided in this code, the code user is advised to seek guidance from the Jurisdiction and from other technical sources.

The words shall, should, and may are used throughout the NBIC and have the following intent:

- Shall – action that is mandatory and required.
- Should – indicates a preferred but not mandatory means to accomplish the requirement unless specified by others such as the Jurisdiction.
- May – permissive, not required or a means to accomplish the specified task.

ORGANIZATION

The NBIC is organized into four parts to coincide with specific post-construction activities involving pressure-retaining items. Each part provides general and specific rules, information, and guidance within each applicable post-construction activity. Other NBIC parts or other published standards may contain additional information or requirements needed to meet the rules of the NBIC. Specific references are provided in each part to direct the user where to find this additional information. NBIC parts are identified as:

- Part 1, Installation – This part provides requirements and guidance to ensure all types of pressure retaining items are installed and function properly. Installation includes meeting specific safety criteria for construction, materials, design, supports, safety devices, operation, testing, and maintenance.
- Part 2, Inspection – This part provides information and guidance needed to perform and document inspections for all types of pressure-retaining items. This part includes information on personnel safety, non-destructive examination, tests, failure mechanisms, types of pressure equipment, fitness for service, risk-based assessments, and performance-based standards.
- Part 3, Repairs and Alterations – This part provides requirements and guidance to perform, verify, and document acceptable repairs or alterations to pressure retaining items regardless of code of construction. Alternative methods for examination, testing, heat treatment, etc., are provided when the original code of construction requirements cannot be met. Specific acceptable and proven repair methods are also provided.
- Part 4, Pressure Relief Devices – This part provides information and guidance to ensure pressure relief devices are installed properly, information and guidance needed to perform and document inspections for pressure relief devices, and information and guidance to perform, verify, and document acceptable repairs to pressure relief devices.

Each NBIC part is divided into major sections as outlined in the Table of Contents.

Tables, charts, and figures provide relevant illustrations or supporting information for text passages, and are designated with numbers corresponding to the paragraph they illustrate or support within each section. Multiple tables, charts, or figures referenced by the same paragraph will have additional letters reflecting the order of reference. Tables, charts, and figures are located in or after each major section within each NBIC part.

TEXT IDENTIFICATION AND NUMBERING

Each page in the text will be designated in the top header with the publication's name, part number, and part title. The numbering sequence for each section begins with the section number followed by a dot to further designate major sections (e.g., 1.1, 1.2, 1.3). Major sections are further subdivided using dots to designate subsections within that major section (e.g., 1.1.1, 1.2.1, 1.3.1). Subsections can further be divided as necessary. Paragraphs under sections or subsections shall be designated with small letters in parenthesis (e.g., a), b), c)) and further subdivided using numbers in parenthesis (e.g., 1), 2), 3)).

Subdivisions of paragraphs beyond this point will be designated using a hierarchical sequence of letters and numbers followed by a dot.

Example: 2.1 Major Section
 2.1.1 Section
 2.1.2 Section
 2.1.2. Subsection
 a) paragraph
 b) paragraph
 1) subparagraph
 2) subparagraph
 a. subdivisions
 1. subdivisions
 2. subdivisions
 b. subdivisions
 1. subdivisions
 2. subdivisions

Tables and figures will be designated with the referencing section or subsection identification. When more than one table or figure is referenced in the same section or subsection, letters or numbers in sequential order will be used following each section or subsection identification.

SUPPLEMENTS

Supplements are contained in each part of the NBIC to provide requirements and guidance only pertaining to a specific type of pressure-retaining item (e.g., Locomotive Boilers, Historical Boilers, Graphite Pressure Vessels.) Supplements follow the same numbering system used for the main text only preceded by the Letter "S." Each page of the supplement will be tabbed to identify the supplement number.

EDITIONS

Editions, which include revisions and additions to this code, are published every two years. Editions are permissive on the date issued and become mandatory six months after the date of issue.

CODE STAMPING

ASME Code "Stamping" referenced throughout the NBIC includes the ASME Boiler and Pressure Vessel Code Symbol Stamps used for conformity assessment prior to the 2010 edition/2011 addendum and the equivalent ASME Certification Mark with Designator required to meet the later editions of the ASME Boiler and Pressure Vessel Code Sections. When other construction codes or standards are utilized for repairs or alterations, stamping shall mean the identification symbol stamp required by that code or standard.

INTERPRETATIONS

On request, the NBIC Committee will render an interpretation of any requirement of this code. Interpretations are provided for each part and are specific to the code edition and addenda referenced in the interpretation. Interpretations provide clarification of existing rules in the code only and are not part of this code.

JURISDICTIONAL PRECEDENCE

Reference is made throughout this code to the requirements of the “Jurisdiction.” Where any provision herein presents a direct or implied conflict with any jurisdictional regulation, the Jurisdictional regulation shall govern.

UNITS OF MEASUREMENT

Both U.S. customary units and metric units are used in the NBIC. The value stated in U.S. customary units or metric units are to be regarded separately as the standard. Within the text, the metric units are shown in parentheses. In Part 2, Supplement 6 and Part 3, Supplement 6 regarding DOT Transport Tanks, the metric units are shown first with the U.S. customary units shown in parentheses.

U.S. customary units or metric units may be used with this edition of the NBIC, but one system of units shall be used consistently throughout a repair or alteration of pressure-retaining items. It is the responsibility of National Board accredited repair organizations to ensure the appropriate units are used consistently throughout all phases of work. This includes materials, design, procedures, testing, documentation, and stamping. The NBIC policy for metrication is outlined in each part of the NBIC.

ACCREDITATION PROGRAMS

The National Board administers and four specific accreditation programs, as shown below:

- “R”.....Repairs and Alterations to Pressure-Retaining Items (NB-415)
- “VR”.....Repairs to Pressure Relief Valves (NB-514)
- “NR”.....Repair and Replacement Activities for Nuclear Items (NB-417)
- “T/O”.....Testing of Pressure Relief Valves (NB-528)

The administrative requirements for the accreditation for these accreditation programs can be viewed on the National Board Website at www.nationalboard.org.

The National Board also administers and accredits four specific inspection agency programs as shown below:

New Construction

Criteria for Acceptance of Authorized Inspection Agencies for New Construction (NB-360)

Inservice

Qualifications and Duties for Authorized Inspection Agencies (AIAs) Performing Inservice Inspection Activities and Qualifications for Inspectors of Boilers and Pressure Vessels (NB-369)

Owner-User

Accreditation of Owner-User Inspection Organizations (OUIO) (NB-371)

Owners or users may be accredited for both a repair and inspection program provided the requirements for each accreditation program are met.

Federal Government

Qualifications and Duties for Federal Inspection Agencies Performing Inservice Inspection Activities (FIAs) (NB-390)

These programs can be viewed on the National Board Website at www.nationalboard.org. For questions or further information regarding these programs contact the National Board by phone at (614) 888-8320 or by fax at (614) 847-1828.

CERTIFICATES OF AUTHORIZATION FOR ACCREDITATION PROGRAMS

Any organization seeking an accredited program may apply to the National Board to obtain a Certificate of Authorization for the requested scope of activities. A confidential review shall be conducted to evaluate the organization's quality system. Upon completion of the evaluation, a recommendation will be made to the National Board regarding issuance of a Certificate of Authorization.

Certificate of Authorization scope, issuance, and revisions for National Board accreditation programs are specified in the applicable National Board procedures. When the quality system requirements of the appropriate accreditation program have been met, a Certificate of Authorization and appropriate National Board symbol stamp shall be issued.

FOREWORD

The National Board of Boiler and Pressure Vessel Inspectors is an organization comprised of Chief Inspectors for the states, cities, and territories of the United States and provinces and territories of Canada. It is organized for the purpose of promoting greater safety to life and property by securing concerted action and maintaining uniformity in post-construction activities of pressure-retaining items, thereby ensuring acceptance and interchangeability among Jurisdictional authorities responsible for the administration and enforcement of various codes and standards.

In keeping with the principles of promoting safety and maintaining uniformity, the National Board originally published the NBIC in 1946, establishing rules for inspection and repairs to boilers and pressure vessels. The *National Board Inspection Code* (NBIC) Committee is charged with the responsibility for maintaining and revising the NBIC. In the interest of public safety, the NBIC Committee decided, in 1995, to revise the scope of the NBIC to include rules for installation, inspection, and repair or alteration to boilers, pressure vessels, piping, and nonmetallic materials.

In 2007, the NBIC was restructured into three parts specifically identifying important post-construction activities involving safety of pressure-retaining items. This restructuring provides for future expansion, transparency, uniformity, and ultimately improving public safety.

In 2017, the NBIC was once again restructured into 4 parts, adding a new Part 4, Pressure Relief Devices. This purpose of this restructuring was to provide one distinct integrated part for pressure relief devices compiled from all PRD information referenced in Part 1, Installation; Part 2, Inspection; and Part 3, Repairs and Alterations.

The NBIC Committee's function is to establish rules of safety governing post-construction activities for the installation, inspection, and repair and alteration of pressure-retaining items, and to interpret these rules when questions arise regarding their intent. In formulating the rules, the NBIC Committee considers the needs and concerns of individuals and organizations involved in the safety of pressure-retaining items. The objective of the rules is to afford reasonably certain protection of life and property, so as to give a reasonably long, safe period of usefulness. Advancements in design and material and the evidence of experience are recognized.

The rules established by the NBIC Committee are not to be interpreted as approving, recommending, or endorsing any proprietary or specific design, or as limiting in any way an organization's freedom to choose any method that conforms to the NBIC rules.

The NBIC Committee meets regularly to consider revisions of existing rules, formulation of new rules, and respond to requests for interpretations. Requests for interpretation must be addressed to the NBIC Secretary in writing and must give full particulars in order to receive Committee consideration and a written reply. Proposed revisions to the code resulting from inquiries will be presented to the NBIC Committee for appropriate action.

Proposed revisions to the code approved by the NBIC Committee are submitted to the American National Standards Institute and published on the National Board web-site to invite comments from all interested persons. After the allotted time for public review and final approval, the new edition is published. The Foreword, Introduction, Personnel and Index Sections of the NBIC are provided for guidance and informational purposes only and shall not be considered a part of the Code. These sections are not approved by the NBIC Committee or submitted to the American National Standards Institute.

Organizations or users of pressure-retaining items are cautioned against making use of revisions that are less restrictive than former requirements without having assurance that they have been accepted by the Jurisdiction where the pressure-retaining item is installed.

The general philosophy underlying the NBIC is to parallel those provisions of the original code of construction, as they can be applied to post-construction activities. The NBIC does not contain rules to cover all details of post-construction activities. Where complete details are not given, it is intended that individuals or organizations, subject to the acceptance of the Inspector and Jurisdiction when applicable, provide details

for post-construction activities that will be as safe as otherwise provided by the rules in the original code of construction.

Activities not conforming to the rules of the original code of construction or the NBIC must receive specific approval from the Jurisdiction, who may establish requirements for design, construction, inspection, testing, and documentation.

There are instances where the NBIC serves to warn against pitfalls; but the code is not a handbook, and cannot substitute for education, experience, and sound engineering judgment. It is intended that this edition of the NBIC not be retroactive. Unless the Jurisdiction imposes the use of an earlier edition, the latest effective edition is the governing document.

PERSONNEL

The National Board of Boiler and Pressure Vessel Inspectors

Board of Trustees

J. Burpee
Chairman

J. Amato
First Vice Chairman

D. Cook
Second Vice Chairman

C. Cantrell
Member at Large

E. Creaser
Member at Large

A. Oda
Member at Large

M. Washington
Member at Large

D. Douin
Secretary/Treasurer

Advisory Committee

J. Pillow
Representing welding industries

C. Hopkins
Representing National Board stamp holders

H. Richards
Representing boiler and pressure vessel users

B. Berquist
Representing pressure vessel manufacturers

R. Wielgoszinski
Representing authorized inspection agencies
(insurance companies)

P. Molvie
Representing boiler manufacturers

National Board Members

Alabama	Marvin Byrum
Alaska	Kenneth Lane
Arizona	Randall Austin
Arkansas.....	Dennis Hannon
California	Donald Cook
Colorado	Steve Nelson
Delaware	John Esch
Florida	Andrew Frazier
Georgia.....	Benjamin Crawford
Hawaii.....	Julius Dacanay
Illinois.....	Michael Vogel
Indiana.....	Larry Parkey
Kansas.....	Robert Stimson
Kentucky.....	Mark Jordan
Louisiana	Joseph LeSage
Maine.....	John Burpee
Maryland.....	Karl Kraft
Massachusetts.....	Edward Kawa
Michigan	David Stenrose
Minnesota	Joel Amato
Mississippi	William Anderson
Missouri	Ronald Brockman
Nebraska	Christopher B. Cantrell
Nevada	David Sandfoss
New Hampshire.....	Darrell Mallory
New Jersey.....	Milton Washington
New York	Matthew Sansone
North Carolina	Clifford Dautrich
North Dakota	Trevor Seime
Ohio.....	John Sharier
Oklahoma	Thomas Granneman
Oregon	Mark Perdue
Pennsylvania	Nathaniel Smith
South Carolina.....	Ronald W. Spiker
South Dakota.....	Aaron Lorimor
Tennessee	Sam Chapman
Texas	Rob Troutt
Utah.....	Rick Sturm
Virginia.....	Edward Hilton
Washington.....	Tony Oda
West Virginia	John Porcella
Wisconsin	Terrence Waldbillig
Chicago, IL	Michael Ryan
Detroit, MI.....	Cortney Jackson
Los Angeles, CA	Cirilo Reyes
Milwaukee, WI	Jillian Klug
New York, NY	William McGivney
Seattle, WA.....	Larry Leet
Alberta	Michael Pohlmann
British Columbia	Anthony Scholl
Manitoba.....	Ryan DeLury
New Brunswick.....	Eben Creaser
Newfoundland & Labrador.....	Dennis Eastman
Northwest Territories.....	Matthias Mailman
Nova Scotia	Peter Dodge
Ontario.....	Michael Adams
Prince Edward Island.....	Steven Townsend
Quebec.....	Aziz Khssassi
Saskatchewan	Christopher Selinger

National Board Inspection Code Main Committee

D. Cook, Chair
State of California

R. Wielgoszinski, Vice Chair
*Hartford Steam Boiler Inspection and
Insurance Company*

B. Besserman, Secretary
National Board

J. Amato
State of Minnesota

R. Austin
State of Arizona

S. Cammeresi
Furmanite

P. Edwards
WECTEC

G. Galanes
Diamond Technical Services, Inc.

J. Getter
Worthington Industries

C. Hopkins
Seattle Boiler Works, Inc.

L. McManoman
Great Lakes Area Apprenticeship Program

M. Mooney
Liberty Mutual Insurance Company

B. Morelock
Eastman Chemical Company

V. Newton
XL Insurance

J. Pillow
Common Arc

M. Richards
Consultant

J. Riley
Phillips 66

J. Sekely
Consultant

K. Simmons
Pentair

S. Staniszewski Jr.
U.S. Department of Transportation

R. Troutt
State of Texas

M. Wadkinson
Fulton Boiler Works, Inc.

M. Webb
Xcel Energy Services

P. Welch
Arise Boiler Inspection and Insurance Company

**National Board Inspection Code
Subcommittee Installation (Part 1)**

H. Richards, Chair
Consultant

D. Patten, Vice Chair
Bay City Boiler

J. Bock, Secretary
National Board

R. Austin
State of Arizona

G. Halley
ABMA

S. Konopacki
NRG

B. Moore
*Hartford Steam Boiler Inspection and
Insurance Company*

P. Schuelke
Well-McLain

R. Smith
Authorized Inspection Associates

M. Wadkinson
Fulton Boiler Works, Inc.

E. Wiggins
Liberty Mutual Insurance Company

**National Board Inspection Code
Subcommittee Inspection (Part 2)**

M. Mooney, Chair
Liberty Mutual Insurance Company

S. Staniszewski, Vice Chair
US Department of Transportation

J. Metzmaier, Secretary
National Board

T. Barker
FM Global

E. Brantley
XL Insurance

D. Buechel
*Hartford Steam Boiler Inspection and
Insurance Company*

D. Ford
U.S. Department of Transportation

J. Getter
Worthington Cylinders

D. Graf
Air Products and Chemicals, Inc.

M. Horbaczewski
Diamond Technical Services

G. McRae
Trinity Industries, Inc.

V. Newton
XL Insurance

J. Riley
Phillips 66

M. Schwartzwalder
Stress Engineering Services

T. Vandini
Quality Steel Corporation

P. Welch
ARISE

**National Board Inspection Code
Subcommittee for Repairs and Alterations
(Part 3)**

G. Galanes, Chair
Diamond Technical Services, Inc.

J. Pillow, Vice Chair
Common Arc Corporation

W. Vallance, Secretary
National Board

J. Amato
State of Minnesota

B. Boseo
Graycor Services LLC

A. Bramucci
GE Renewable Energy

P. Edwards
WECTEC

C. Hopkins
Seattle Boiler Works, Inc.

W. Jones
Arise, Inc.

L. McManoman
Great Lakes Area Apprenticeship Program

R. Miletti
Babcock and Wilcox Construction Company, Inc.

L. Moedinger
Strasburg Railroad Company

K. Moore
Joe Moore Company

B. Morelock
Eastman Chemical Company

B. Schaefer
AEP

J. Sekely
Consultant

M. Toth
Boiler Supply Company, Inc.

R. Troutt
State of Texas

M. Webb
Xcel Energy

**National Board Inspection Code
Subcommittee Pressure Relief Devices
(Part 4)**

S. Cammeresi, Chair
Furmanite

A. Cox, Vice Chair
JAC Consulting

T. Beirne, Secretary
National Board

K. Beise
Dowco Valve Company, Inc.

M. Brodeur
International Valve & Instr. Corp.

D. DeMichael
Chemours Co.

R. Donalson
Pentair

B. Hart
FM Global

D. Marek
Mainthia Technologies

R. McCaffrey
Quality Valve

D. McHugh
Allied Valve, Inc.

B. Nutter
E.I. Dupont De Nemours & Co.

T. Patel
Farris Engineering

A. Renaldo
Praxair, Inc.

K. Simmons
Pentair

National Board Inspection Code Subgroup Installation (Part 1)

M. Wadkinson, Chair
Fulton Boiler Works, Inc.

D. Patten, Vice Chair
Bay City Boiler

J. Bock, Secretary
National Board

R. Austin
State of Arizona

T. Creacy
Zurich Services Corporation

G. Halley
ABMA

S. Konopacki
NRG Energy

J. Millette
UAB

B. Moore
*Hartford Steam Boiler Inspection and
Insurance Company*

H. Richards
Consultant

P. Schuelke
Well-McLain

R. Smith
Authorized Inspection Associates

M. Washington
State of New Jersey

E. Wiggins
Liberty Mutual Insurance Company

National Board Inspection Code Subgroup Inspection (Part 2)

J. Getter, Chair
Worthington Industries

M. Schwartzwalder, Vice Chair
AEP

J. Metzmaier, Secretary
National Board

T. Barker
FM Global

E. Brantley
XL Insurance America, Inc.

D. Ford
US Department of Transportation

D. Graf
Air Products and Chemicals, Inc.

B. Hart
Factory Mutual Insurance Company

M. Horbaczewski
Midwest Generation

G. McRae
Trinity Industries, Inc.

M. Mooney
Liberty Mutual Insurance

V. Newton
XL Insurance America

J. Riley
Phillips 66

S. Staniszewski
US Department of Transportation

T. Vandini
Quality Steel Corporation

P. Welch
Arise, Inc.

National Board Inspection Code Subgroup for Repairs and Alterations (Part 3)

A. Bramucci, Chair
GE Renewable Energy

W. Vallance, Secretary
National Board

J. Amato
State of Minnesota

B. Boseo
Graycor Services LLC

N. Carter
*Hartford Steam Boiler Inspection and
Insurance Company*

R. Cauthon
Alstom Power

P. Edwards
WECTEC

G. Galanes
Diamond Technical Services, Inc.

C. Hopkins
Seattle Boiler Works, Inc.

F. Johnson
PBF Energy

W. Jones
Arise, Inc.

D. Martinez
FM Global

L. McManoman
Great Lakes Area Apprenticeship Program

R. Miletti
Babcock and Wilcox Construction Company, Inc.

K. Moore
Joe Moore Company

B. Morelock
Eastman Chemical

J. Pillow
Common Arc Corporation

B. Schaefer
AEP

J. Sekely
Consultant

W. Sperko
Sperko Engineering Services

M. Toth
Boiler Supply Company, Inc.

R. Troutt
State of Texas

R. Valdez
ARB, Inc.

J. Walker
Hayes Mechanical

M. Webb
Xcel Energy

T. White
NRG Energy

National Board Inspection Code Subgroup Graphite

E. Soltow, Chair
SGL Carbon Technic

B. Besserman, Secretary
National Board

G. Becherer
CG Thermal

F. Brown
Consultant

C. Cary
Dow Corning

J. Clemens
Graphite Maintenance

K. Cummins
Louisville Graphite

B. Dickerson
Mersen

B. Jones
Mersen

R. Selvaraj
Mersen

D. Sholar
Mersen

A. Stupica
SGL Carbon Technic

A. Viet
CG Thermal

National Board Inspection Code Subgroup Fiber-Reinforced Pressure Vessels

B. Shelley, Chair
Chemours

B. Besserman, Secretary
National Board

F. Brown
Consultant

J. Bustillos
Bustillos and Associates

T. Cowley
FRP Consulting

D. Eisberg
Avista Technologies

M. Gorman
Digital Wave

D. Hodgkinson
Consultant

D. Keeler
The Dow Chemical Company

D. McCauley
Chemours

N. Newhouse
Hexagon Lincoln

A. Pollock
Mistras Group

J. Richter
Thorpe Plant Services

N. Sirosh
LightSail Energy

National Board Inspection Code Subgroup Locomotive Boilers

L. Moedinger, Chair
Strasburg Railroad

M. Janssen, Vice Chair
Vapor Locomotive Company

B. Ferrel, Secretary
National Board

S. Butler
Midwest Locomotive & Machine Works

D. Conrad
Valley Railroad Co.

R. Franzen
Steam Services of America

D. Griner
Arizona Mechanical Engineering

S. Lee
Union Pacific Railroad

D. McCormack
Consultant

G. Ray
Tennessee Valley Authority

R. Stone
ARVOS, Inc.

National Board Inspection Code Subgroup Historical Boiler

J. Amato, Chair
State of Minnesota

T. Dillon, Vice Chair
MSEA

B. Ferrell, Secretary
National Board

J. Getter
Worthington Industries

F. Johnson
PBF Energy

M. Jordan
State of Kentucky

D. Rose
T&T Inspections

D. Rupert
Consultant

R. Underwood
*Hartford Steam Boiler Inspection and
Insurance Company*

M. Wahl
WHSEA

PART 4, SECTION 1 PRESSURE RELIEF DEVICES — GENERAL AND ADMINISTRATIVE REQUIREMENTS

1.1 SCOPE

This Part provides guidelines and requirements for the installation, in-service inspection and testing, and repairs of pressure relief devices.

1.2 CONSTRUCTION STANDARDS FOR PRESSURE RELIEF DEVICES

- a) When the standard governing the original construction is the ASME Code, installation and repairs to pressure relief devices shall conform to the ASME Code section and edition most applicable to the work planned.
- b) If the pressure relief device was not constructed to the ASME Code, then installation, inspection and repair shall wherever possible reference the original code of construction most applicable to the work.
- c) If the pressure relief device was not constructed to any recognized construction code or standard, then installation, inspection, and repair shall reference a construction standard or specification most applicable to the work.
- d) Where this is not possible or practicable, it is permissible to use other codes, standards, or specifications, including the ASME Code, provided there is concurrence of the Inspector (if applicable) and the Jurisdiction where the pressure relief device is installed.

1.3 PRESSURE RELIEF DEVICES — DEFINITIONS

Refer to Section 9, *Glossary* for definitions relating to pressure relief devices.

1.3.1 ADDITIONAL DEFINITIONS RELATING TO PRESSURE RELIEF DEVICES

Unless otherwise specified in the NBIC, the definitions relating to pressure relief devices in Section 2 of ASME PTC-25 shall apply.

1.4 ACCREDITATION

- a) Organizations performing repairs to pressure relief valves shall be accredited as described in this section, as appropriate for the scope of work to be performed.
- b) Organizations performing repairs to pressure relief valves outside the scope of the NBIC may be accredited and shall meet any additional requirements of the Jurisdiction where the work is performed.

1.4.1 ACCREDITATION PROCESS

- a) The National Board administers accreditation programs for authorization of organizations performing repairs to pressure relief valves.
- b) Any organization may apply to the National Board to obtain a *Certificate of Authorization* for a requested scope of activities. A review shall be conducted to evaluate the organization's Quality System. The individual assigned to conduct the evaluation shall meet the qualification requirements prescribed by the National Board. Upon completion of the evaluation, any deficiencies within the organization's