



NECA/NACMA 120-2018

AN AMERICAN NATIONAL STANDARD



Standard for Installing

Installing Armored Cable (AC) and Metal-Clad Cable (MC)

Published by
National Electrical
Contractors Association



Jointly developed with
NACMA



NECA/NACMA 120-2018

Standard for

Installing Armored Cable (AC) and Metal-Clad Cable (MC)

**An American
National Standard**



Published by
National Electrical
Contractors Association



Jointly developed with
NACMA



Revision History	
NECA 120-2006	07-2006
NECA 120-2012	03-2013
NECA 120-2018	08-2018

NOTICE OF COPYRIGHT

This document is copyrighted by NECA

ISBN: 978-1-944148-25-3

©2016. Reproduction of these documents either in hard copy or soft (including posting on the web) is prohibited without copyright permission. For copyright permission to reproduce portions of this document, please contact NECA Standards & Safety at (301) 215-4549, or send a fax to (301) 215-4500.

CP

National Electrical Contractors Association
3 Bethesda Metro Center, Suite 1100
Bethesda, Maryland 20814
(301) 657-3110

Table of Contents

Foreword.....	v
1. Scope	1
1.1 Regulatory and Other Requirements	1
2. Definitions	2
3. Identification of Cables.....	3
3.1 Identification	3
4. Armored Cable (Type AC)	5
4.1 Description	5
4.2 Listed	5
4.3 Equipment Grounding.....	5
4.4 Uses Permitted, General.....	6
4.4.1 Uses Permitted, Special Occupancies.....	6
4.5 Uses Not Permitted	8
4.6 Connectors.....	8
5. Metal-Clad Cables (Type MC)	9
5.1 Description	9
5.2 Listed	9
5.3 Conductors	9
5.4 Special MC Cable Configurations.....	9
5.5 Equipment Grounding.....	11
5.5.1 Interlocking Metal Tape Sheath	11
5.5.2 Smooth or Corrugated Sheath	12
5.8 Connectors.....	14
5.8.1 Criteria for Selecting	14
5.8.2 Identification of Connector.....	14
5.8.3 Size of Connector.....	15
5.8.4 Suitable for Type of Cable or Location.....	15
5.8.5 Grounding.....	15
6. General Installation Procedures.....	16
6.1 General Procedures for Type AC and MC Cables	16
6.2 Planning for and Installation of Home Runs	18
6.2.1 Planning.....	18
6.2.2 Home Run Cables	18
6.2.3 Phasing of Circuit Conductors.....	18

6.2.4	Application of Adjustment Factors	19
6.2.4.1	When the Neutral Counts as Current-Carrying	19
6.3	Cutting AC and MC Cables	20
6.3.1	Rotary Armor Cutter	20
6.3.2	Hacksaw	20
6.3.3	Wire Cutters	20
6.3.4	Caution	20
6.4	Position of Cable in Connector	20
6.5	Overcurrent Protection and Derating	21
6.5.1	Type AC Cables	21
6.5.2	Type MC Cables	22
6.6	Fishing Cables	22
6.7	Installing Cables Through Fire-Rated Walls, Floors or Ceilings	23
7.	AC Cables—Specific Installation Procedures	24
7.1	Boxes and Fittings	24
7.2	Isolated Equipment Grounding	24
7.3	Health Care Facilities	24
7.3.1	Essential Electrical Systems in Health Care Facilities	25
8.	MC Cables—Specific Installation Procedures	26
8.1	Boxes and Fittings	26
8.2	Isolated Equipment Grounding	26
8.3	Health Care Facilities	26
8.3.1	Essential Electrical Systems in Health Care Facilities	27
8.4	Terminating Type MC Cable Containing Bare Aluminum Bonding/Grounding Conductor	28
8.5	Supporting Vertical Type MC Cables	28
9.	Type MC Cables in Hazardous (Classified) Locations	29
9.1	Class I Locations	29
9.2	Class II Locations	29
9.3	Seals in Hazardous (Classified) Locations	29
Annex A:	Reference Standards	31

(This foreword is not a part of the standard)

Foreword

National Electrical Installation Standards™ are designed to improve communication among specifiers, purchasers, and suppliers of electrical construction services. They define a minimum baseline of quality and workmanship for installing electrical products and systems. *NEIS*™ are intended to be referenced in contract documents for electrical construction projects. The following language is recommended:

Type AC and MC Cables shall be installed in accordance with NECA/NACMA 120, *Standard for Installing Armored Cable (AC) and Metal-Clad Cable (MC)* (ANSI).

Use of *NEIS*™ is voluntary, and neither the National Electrical Contractors Association nor the National Armored Cable Manufacturers Association assume any obligation or liability to users of this publication. Existence of a standard shall not preclude any member or non member of either organization from specifying or using alternate construction methods permitted by applicable regulations.

This publication is intended to comply with the edition of the National Electrical Code® (NEC) in effect at the time of publication. Because they are quality standards, *NEIS* may in some instances go beyond the minimum safety requirements of the NEC. It is the responsibility of users of this publication to comply with state and local electrical code when installing electrical products and systems.

Suggestions for revisions and improvements to this standard are welcome. They should be addressed to:

NECA Codes and Standards
3 Bethesda Metro Center, Suite 1100
Bethesda, MD 20814
(301) 215-4521
(703) 215-4500 Fax
www.neca-neis.org
neis@necanet.org

To purchase *National Electrical Installation Standards* contact the NECA Order Desk at (301) 215-4504 tel, (301) 215-4500 fax, or orderdesk@necanet.org. *NEIS* are also available in PDF download format at www.neca-neis.org/catalog.

Copyright © 2018, National Electrical Contractors Association. All rights reserved. Unauthorized reproduction prohibited.

National Electrical Installation Standards and *NEIS* are trademarks of the National Electrical Contractors Association. National Electrical Code and NEC are registered trademarks of the National Fire Protection Association, Quincy, Massachusetts.

*Photos courtesy of NACMA, except where noted.
Cover photo courtesy of General Cable.*

<This page intentionally left blank.>

1. Scope

This standard covers the identification, selection, and installation of Type AC and Type MC cables, which are used for electrical wiring for residential, commercial and industrial occupancies. It also includes information on fittings and other accessories necessary for a quality installation of these cable systems.

This standard is intended to enhance electrical safety by:

1. Ensuring that the proper cable is selected for the installation.
2. Describing proper installation methods for Type AC and MC cables.
3. Aiding installers in meeting the “neat and workmanlike” requirements of the NEC.
4. Creating an installation that will protect the wire conductors from physical damage.

1.1 Regulatory and Other Requirements

a) All information in this publication is intended to conform to the National Electrical Code (ANSI/

NFPA Standard 70). Installers should always follow the NEC, applicable state and local code, and manufacturers’ instructions when installing electrical products and systems.

b) Only qualified persons as defined in the NEC familiar with the construction and installation of Type AC and Type MC cables should perform the technical work described in this publication. Administrative functions and other tasks can be performed under the supervision of a qualified person. All work should be performed in accordance with NFPA 70E, *Standard for Electrical Safety in the Workplace*.

c) General requirements for installing electrical products and systems are described in NECA 1- 2015, *Standard for Good Workmanship in Electrical Construction* (ANSI). Other *National Electrical Installations Standards* provide guidance for installing particular types of electrical products and systems. A complete list of *NEIS* is provided in Annex A.