

NEMA BL 2-2007

---

# Energy Efficiency for Electronic Ballasts for T8 Fluorescent Lamps



**NEMA BL 2-2007**

**ENERGY EFFICIENCY FOR  
ELECTRONIC BALLASTS  
FOR T8 FLUORESCENT  
LAMPS**

Currently in preview, click buy full version

Currently in preview, click buy full version

**NEMA Standards Publication BL 2-2007**

*Energy Efficiency for Electronic Ballasts for T8 Fluorescent Lamps*

*Published by:*

**National Electrical Manufacturers Association**

1300 North 17th Street, Suite 1752

Rosslyn, Virginia 22209

[www.nema.org](http://www.nema.org)

© Copyright 2007 by the National Electrical Manufacturers Association. All rights, including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

## NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

The National Electrical Manufacturers Association (NEMA) standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensation, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, express or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no guaranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

## CONTENTS

Foreword.....	ii
1 Scope .....	1
2 Referenced documents.....	1
3 Definitions.....	1
3.1 Ballast .....	1
3.2 Ballast Efficacy Factor (BEF).....	1
3.3 Ballast Factor (BF) .....	1
3.4 Ballast Frequency .....	1
3.5 Power Factor.....	1
3.6 Lamp Lumens (lm) .....	2
4 General requirements.....	2
4.1 Ballast requirements.....	2
4.2 Multi-voltage ballasts.....	2
4.3 Test requirements .....	2
4.4 Ballast Efficacy Factor.....	2
5 Marking Requirement .....	3

## Foreword

This standard includes energy efficiency requirements for declaration as NEMA Premium rated products. All safety related requirements and energy efficiency requirements shall be met for NEMA Premium ratings.

In the preparation of this standards publication, input of users and other interested parties was sought and evaluated. Inquiries, comments, and proposed or recommended revisions should be submitted to the Ballast Subdivision of NEMA by contacting:

Vice President, Technical Services  
National Electrical Manufacturers Association  
1300 North 17th Street, Suite 1752  
Rosslyn, Virginia 22209

The standards or guidelines presented in a NEMA standards publication are considered technically sound at the time they are approved for publication. They are not a substitute for a product seller's or user's own judgment with respect to the particular product referenced in the standard or guideline, and NEMA does not undertake to guarantee the performance of any individual manufacturer's products by virtue of this standard or guide. Thus, NEMA expressly disclaims any responsibility for damages arising from the use, application, or reliance by others on the information contained in these standards or guidelines.

The Ballast Section developed this standard. Section approval of the standard does not necessarily imply that all section members voted for its approval or participated in its development. At the time the standard was approved, the Ballast Section was comprised of the following members:

Advance—Rosemont, IL  
Advanced Lighting Technologies, Inc.—Columbus, OH  
Aurora Lighting Inc.—Knoxville, TN  
Cooper Lighting—Vicksburg, MS  
GE Consumer & Industrial, Lighting Systems—East Flat Rock, NC  
Holophane—Newark, OH  
Lutron Electronics Company, Inc.—Coopersburg, PA  
OSRAM SYLVANIA Electronic Control Systems—Lake Zurich, IL  
Radionic Industries, Inc.—Chicago, IL  
Robertson Worldwide—Blue Island, IL  
Universal Lighting Technologies—Nashville, TN

## 1 Scope

This standard publication contains energy efficiency requirements for evaluating electronic ballasts designed for use with four-foot 32-watt T8 fluorescent lamps with a lumen output greater than or equal to 3100 lumens.

## 2 Referenced documents

The following standards contain provisions that through reference in this standard constitute applicable requirements. Since standards are subject to revision, the latest editions are to be consulted.

ANSI C82.2–2002, *American National Standard for Lamp Ballasts—Method of Measurement of Fluorescent Lamp Ballasts*

ANSI C82.11, Consolidated 2002, *American National Standard for High-Frequency Fluorescent Lamp Ballasts—Supplements*

UL 935–2001, *Standard for Fluorescent-lamp Ballasts*

## 3 Definitions

### 3.1 Ballast

An auxiliary device used with an electrical discharge lamp(s) to obtain the necessary circuit conditions (voltage, current, and wave form) for the proper starting and operation of a particular fluorescent lamp(s) from a particular line voltage and frequency.

### 3.2 Ballast Efficacy Factor (BEF)

The ratio of the ballast factor in percent to the total input power in watts. This number is used to compare the efficiency of different lighting systems.  $BEF = BF\% / \text{Total Input Power Watts}$

### 3.3 Ballast Factor (BF)

The percentage of light output produced when a fluorescent lamp(s) is energized from a commercially available ballast as compared to the light output produced when energized from a reference ballast.

### 3.4 Ballast Frequency

The frequency at which the ballast operates the lamp, measured in Hertz (Hz) or kilohertz (kHz).

### 3.5 Power Factor

The ratio of input wattage to the product of root-mean-square voltage and root-mean-square current. It represents the amount of current and voltage that a ballast actually uses as a fraction of what the utility supplies.