

NEMA BS 31015-2023

Residential Controls—ClimateTalk 2.1 CT-485 Physical Specifications

Published by:

National Electrical Manufacturers Association

Rosslyn, Virginia 22209

www.nema.org

© 2024 National Electrical Manufacturers Association. All rights, including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American copyright conventions.

Currently in preview, click buy full version

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

The National Electrical Manufacturers Association (NEMA) standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no warranty or warranty, expressed or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guideline.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health- or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

Currently in preview, click buy full version

Foreword

ClimateTalk is a universal language for innovative, cost-effective solutions that optimize performance, efficiency, and home comfort. The ClimateTalk Open Standards define a set of messages and commands to enable interoperability, enhanced user interface, and machine-to-machine control independent of the physical layer connecting the devices.

This document defines the Serial Hardware requirements for CT-485. Corresponding to OSI Layer 1, the Physical specification defines the electrical transmission requirements for implementing ClimateTalk over CT-485.

These standards are periodically reviewed by the Residential Controls Section of NEMA for any revisions necessary to keep them up to date with advancing technology. Proposed or recommended revisions should be submitted to:

NEMA Technical Operations Department
National Electrical Manufacturers Association
Rosslyn, Virginia 22209

This technical publication was developed by Emerson and copyright was transferred to NEMA. Section approval of the standard does not necessarily imply that all section members voted for its approval or participated in its development. At the time it was approved, the group was composed of the following members:

Apcom Inc.	Franklin, TN
Braeburn Systems LLC	Montgomery, IL
Emerson Automation Solutions	Rosemont, IL
Johnson Controls	Goode, VA
Resideo Technologies, Inc.	Golden Valley, MN
White-Rodgers/Copeland	St. Louis, MO

Contents

Foreword	i
History of Standards.....	iv
Section 1 General	1
1.1 Scope	1
1.2 References.....	2
1.3 Definitions	2
Section 2 Data Transmission Specification.....	6
2.1 Data Rate	6
2.2 Network Transmission Wire.....	6
2.3 Data Transmission—CT-485 Serial Circuits	7
2.4 Bill of Materials.....	8
Section 3 Additional Hardware Application Requirements	10
3.1 LED Indicators.....	10
3.2 Buttons	10
3.3 Non-Volatile Requirement	11
3.4 Diagnostic Port.....	11
Section 4 CT-485 4-Wire Configuration	14
4.1 System Control Voltage Tolerance	14
4.2 Transmission Bus Stability.....	14
4.3 Transmission Bus Specifications	14
4.4 Maximum Operating Lengths in 4-Wire CT Mode	15
Section 5 CT-485 3-Wire Configuration	16
5.1 System Control Voltage Tolerance	16
5.2 Transmission Bus Stability.....	16
5.3 Transmission Bus Specifications	17
5.4 Maximum Operating Lengths in 3-Wire CT Mode	18
Section 6 CT-485 2-Wire Configuration	19
6.1 System Control Voltage Tolerance	19
6.2 Transmission Bus Stability.....	19
6.3 Transmission Bus Specifications	19
6.4 Maximum Operating Lengths for 2-Wire CT Mode.....	20
Section 7 T-Taps and Local Devices.....	21
7.1 T-Taps.....	21
7.2 Wire Color Codes.....	21
Section 8 Serial Baud Rate and Byte Timing Calculations	23
8.1 Byte Timing	23
8.2 Maximum MTU Size.....	23
8.3 CT-485 Serial Pre-Drive Hold Time	23
8.4 CT-485 Serial Post-Drive Hold Time.....	23
8.5 CT-485 Serial Inter-Packet Delay (Transmission Method)	23
8.6 CT-485 Serial Inter-Character Delimiting (Receive Method)	24
8.7 CT-485 Serial Maximum Transmission Unit (MTU) Timing	25
Section 9 Annex	26
9.1 CT-485 Serial Converter	26
9.2 Troubleshooting Techniques.....	26
9.3 Silkscreen Naming Convention.....	27
9.4 HVAC Failure Modes	28
Bibliography	29

Figures

Figure 1	OSI Layers for a CT-485 Implementation	2
Figure 2	Single HVAC CT-485 Serial Network.....	6
Figure 3	CT-485 Serial Transmission Network Example Schematic Circuit	7
Figure 4	Indoor Termination/Bias Circuit.....	8
Figure 5	Outdoor Termination Circuit	8
Figure 6	Four-Pin RJ-11 Molex Connector—Part Number 95003-2641	11
Figure 7	Four-Pin RJ-11 PCB Footprint (Top View).....	12
Figure 8	Four-Pin RJ-11 Molex Plug—Part Number 90075-0027.....	12
Figure 9	Four-Pin RJ-11 Pin Assignment.....	13
Figure 10	4-Wire Color Code.....	15
Figure 11	R-C Network Between “C” and Earth Ground.....	17
Figure 12	3-Wire Color Code.....	17
Figure 13	2-Wire Color Code.....	19
Figure 14	CT-485 Wire Color Codes	22
Figure 15	Minimum Transmit Inter-Packet Timing Example	24
Figure 16	Invalid Minimum Transmit Inter-Packet Timing at Packet 1	24
Figure 17	Inter-Packet Delimiting Receive Method Example	25

Tables

Table 1	CT-485 Bill-of-Materials (BOM).....	9
Table 2	Diagnostic LED Codes	10
Table 3	4-Wire Configuration Maximum Operating Lengths	15
Table 4	3-Wire Configuration Maximum Operating Lengths	18
Table 5	2-Wire Configuration Maximum Operating Lengths	20
Table 6	Nominal CT-485 Serial Network Voltage Readings	26
Table 7	Nominal Electrical Connection Voltage Readings	26
Table 8	Nominal Resistance Readings	27
Table 9	Silkscreen PCB Convention	27

History of Standards

The Residential Controls Section of NEMA was formed in 1940 to promote the standardization of products within the scope of the section. NEMA standards are voluntary and are designed to eliminate misunderstandings between the purchaser and the manufacturer.

This publication is one of a series sponsored by the Residential Controls Section. Other publications in this series are identified as Pub. No. NEMA BS XX (followed by the year of issue).

The present publication, NEMA BS 31015-2023, is published in accordance with NEMA's policy of periodic review and revision to keep NEMA standards contemporary with industry needs and technological advancement.

Currently in preview, click buy full version

Section 1 General

1.1 Scope

ClimateTalk is a universal language for innovative, cost-effective solutions that optimize performance, efficiency, and home comfort. The ClimateTalk Open Standards define a set of messages and commands to enable interoperability, enhanced user interface, and machine-to-machine control independent of the physical layer connecting the devices.

The messages and commands defined by the ClimateTalk Information Model are the presentation and application layers as defined by the OSI Model.¹ ClimateTalk Applications are fully defined at Layer 7 of the OSI Model by a combination of a Device Specific Application Profile, an Application Specification, and the Command Reference.

Below the application layer, ClimateTalk messages can be carried over any physical medium following the OSI Model. CT-485 and CT-LWP are wired serial physical and network layers designed to support the formation of ClimateTalk networks and transport ClimateTalk messages, but other OSI-based protocols—including wireless transports—can be used as well.

CT-485 is a Physical, Data Link, and Networking set of specifications that define one of the physical media over which ClimateTalk messages are sent. CT-485 is a variant of EIA/TIA-485 standards with provisions against incorrect wiring and grounding requirements that meet the needs of residential systems.

This document defines the Serial Hardware requirements for CT-485, which corresponds to OSI Layer 1. The Physical Specification defines the electrical transmission requirements for implementing ClimateTalk over CT-485. All hardware is defined in this specification, and all devices must meet the requirements in this document to be certified as CT-485 devices. See Figure 1 for a diagram of relevant standards.

¹ http://www.iso.org/iso/catalogue/catalogue_tc/catalogue_detail.htm?csnumber=20269.