

NEMA ICS 2.4-2020

---

Standard for NEMA and  
IEC Devices for Motor  
Service— A Guide for  
Understanding  
the Differences



**NEMA Standards Publication ICS 2.4-2020**

*NEMA and IEC Devices for Motor Service—  
A Guide for Understanding the Differences*

*Published by:*

**National Electrical Manufacturers Association**

1300 North 17th Street, Suite 900

Falls Church, Virginia 22209

[www.nema.org](http://www.nema.org)

© 2020 National Electrical Manufacturers Association. All rights including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

## NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

The National Electrical Manufacturers Association (NEMA) Standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus Standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its Standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, expressed or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this Standard or guideline.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstance. Information and other Standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

## Foreword

This Standard was prepared by a technical committee of the NEMA Industrial Automation Control Products and Systems Section. It was approved in accordance with the bylaws of NEMA and supersedes the indicated NEMA Standard. This Standard supersedes ICS 2.4-2003 (R2012).

This Standard provides practical information concerning ratings, construction, test, performance, and manufacture of industrial control equipment. These Standards are used by the electrical industry to provide guidelines for the manufacture and proper application of reliable products and equipment and to promote the benefits of repetitive manufacturing and widespread product availability.

NEMA Standards represent the result of many years of research, investigation, and experience by the Members of NEMA, its predecessors, its Sections and Committees. They have been developed through continuing consultation among manufacturers, users, and national engineering societies and have resulted in improved serviceability of electrical products with economies to manufacturers and users.

One of the primary purposes of this Standard is to encourage the production of reliable control equipment which, in itself, functions in accordance with these accepted Standards. Some portions of these Standards, such as electrical spacings and interrupting ratings, have a direct bearing on safety; almost all of the items in this publication, when applied properly, contribute to safety in one way or another.

Properly constructed industrial control equipment is, however, only one factor in minimizing the hazards which may be associated with the use of electricity. The reduction of hazard involves the joint efforts of the various equipment manufacturers, the system designer, the installer, and the user. Information is provided herein to assist users and others in the proper selection of control equipment.

The industrial control manufacturer has limited or no control over the following factors which are vital to a safe installation:

- a. Environmental conditions
- b. System design
- c. Equipment selection and application
- d. Installation
- e. Operating practices
- f. Maintenance

This publication is not intended to instruct the user of control equipment with regard to these factors except insofar as suitable equipment to meet needs can be recognized in this publication, and some application guidance is given.

This Standard is necessarily confined to defining the construction requirements for industrial control equipment and to providing recommendations for proper selection for use under normal or certain specific conditions. Since any piece of industrial control equipment can be installed, operated, and maintained in such a manner that hazardous conditions may result, conformance with this publication does not by itself assure a safe installation. When, however, equipment conforming with these Standards is properly selected and is installed in accordance with the *National Electrical Code*<sup>®</sup> (NEC) and properly maintained, the hazard to persons and property will be reduced.

To continue to serve the best interests of users of industrial control and systems equipment, the Industrial Automation Control Products and Systems Section is actively cooperating with other standardization organizations in the development of simple and more universal metrology practices. In this publication, the U.S. customary units are gradually being supplemented by those of the modernized metric system known as the International Systems of Units (SI). This transition involves no changes in Standard dimensions, tolerances, or performance specifications.

NEMA Standards publications are subject to periodic review. They are revised frequently to reflect user input and to meet changing conditions and technical progress. Proposed revisions to this Standard should be submitted to:

NEMA Technical Operations Department  
National Electrical Manufacturers Association  
1300 North 17th Street  
Rosslyn, Virginia 22209

This Standards publication was developed by the Industrial Automation Control Products and Systems Section. Section approval of the Standard does not necessarily imply that all section Members voted for its approval or participated in its development. At the time it was approved, the section was composed of the following Members:

ABB, Inc.—Cary, NC  
ASCO Power Technologies—Florham Park, NJ  
Carlo Gavazzi, Inc.—Buffalo Grove, IL  
Cummins, Inc.—Minneapolis, MN  
Danfoss Drives—Chambersburg, PA  
Delta Electronics (Americas) Ltd.—Research Triangle Park, NC  
E+I Engineering US Corporation—Anderson, SC  
Eaton—Milwaukee, WI  
Electro Switch Corporation—Weymouth, MA  
Elliott Control Company, Ltd.—Willis, TX  
Franklin Control Systems—Hillsboro, OR  
Fuji Electric Corporation of America—Roanoke, VA  
Generac Power Systems—Waukesha, WI  
Hubbell Industrial Controls, Inc.—Archdale, NC  
Joslyn Clark Controls, Inc.—Elizabethtown, NC  
Master Controls Systems, Inc.—Lake Bluff, IL  
Mitsubishi Electric Automation, Inc.—Vernon Hills, IL  
NORD Gear Corporation—Waunakee, WI  
Phoenix Contact, Inc.—Middletown, PA  
Post Glover Resistors, Inc.—Erlanger, KY  
Reliance Controls Corporation—Racine, WI  
Rockwell Automation—Milwaukee, WI  
Schneider Electric—Lexington, KY  
SEW-Eurodrive, Inc.—Lyman, SC  
Siemens Industry, Inc.—Norcross, GA  
Software Motor Corporation—Sunnyvale, CA  
TE Connectivity—Harrisburg, PA  
Toshiba International Corporation USA—Houston, TX  
WAGO Corporation—Germantown, WI  
Weidmuller Inc.—Richmond, VA  
Yaskawa America, Inc. Drives and Motor Division—Waukegan, IL

## CONTENTS

Section 1 .....	1
General.....	1
1.1 Referenced Standards .....	1
1.2 Scope .....	1
1.3 Markings.....	2
1.3.1 Nameplate Markings .....	2
1.3.2 UL Markings .....	2
1.4 References.....	3
1.5 Conventions .....	3
1.6 Design Philosophies.....	4
1.6.1 Traditional NEMA Contactors .....	4
1.6.2 Traditional IEC Contactors .....	4
1.6.3 Nema Thermal Overload Relays.....	4
1.6.4 IEC Thermal Overload Relays .....	5
1.6.5 NEMA Motor Controllers .....	5
1.6.6 IEC Motor Controllers.....	5
Section 2 .....	8
Selection Considerations .....	8
2.1 Utilization Categories .....	8
2.2 Contactor Electrical Life .....	9
2.2.1 Electrical Life Test Parameters .....	9
2.2.2 How to Use Electrical Life Curves.....	9
2.3 Mixed Operation Life for Contactors Using IEC Procedure .....	11
2.4 How to Use Contactor Ratings.....	12
2.5 Environmental Effects .....	12
Section 3 .....	14
Terminal Marking and Wiring Conventions .....	14
3.1 General .....	14
3.2 North American Convention.....	14
Section 4 .....	16
Comparison .....	16
4.1 Physical Characteristics .....	16
4.2 Electrical Life .....	16
4.3 Overcurrent Protection .....	16
4.3.1 Overload Relay Class Applications .....	16

4.3.2	Motor Acceleration Time .....	16
4.3.3	Short-Circuit Current Rating .....	17
4.4	Terminal Temperature Rise .....	17
4.5	Construction .....	17

Currently in preview, click buy full version

## Section 1 General

### 1.1 Referenced Standards

In this publication, reference is made, in part or in full, to the Standards listed below. Copies are available from the indicated source.

#### International Electrotechnical Commission

1 Rue de Varembe  
Geneva, Switzerland

- IEC 60204-1:2016 *Safety of machinery—Electrical equipment of machines—Part 1: General requirements*
- IEC 60947-1 2007 *Low Voltage Switchgear and Controlgear, Part 1: General Rules*
- IEC 60947-4-1 2009 *Low Voltage Switchgear and Controlgear, Part 4-1: Contactors and Motor-Starters*

#### National Electrical Manufacturers Association

1300 North 17th Street  
Rosslyn, Virginia 22093

- ICS 1-2000  
(R2005, R2008) *Industrial Control and Systems, General Requirements*
- ICS 2-2000  
(R2005, 2008, 2015) *Industrial Control and Systems, Controllers, Contactors, and Overload Relays*

#### Underwriters Laboratories Inc.

333 Pfingsten Road  
Northbrook, IL 60062

- UL 489-2016 *Molded-Case Circuit Breakers, Molded-Case Switches, and Circuit-Breaker Enclosures (13th Edition)*
- UL 60947-4-1 *Low-Voltage Switchgear and Controlgear—Part 4-1: Contactors and Motor-Starters - Electromechanical Contactors and Motor-Starters*

### 1.2 Scope

The features, conventions, characteristics, and attributes identified in this guide are those of magnetic contactors and thermal overload relays. These are components that may be used alone or combined with other components, to serve as full-voltage or reduced-voltage, reversing or non-reversing, single-speed or multi-speed motor controllers. Control products compared or contrasted in this guide are those with equivalent electrical ratings; such ratings are expressed via nameplates, catalogs, or technical literature.