

NEMA PB 2.2-2014

---

# Application Guide for Ground Fault Protective Devices for Equipment



**NEMA Standards Publication PB 2.2-2014**

*Application Guide for Ground Fault  
Protective Devices for Equipment*

*Published by:*

**National Electrical Manufacturers Association**

1300 North 17th Street, Suite 100

Rosslyn, Virginia 22209

[www.nema.org](http://www.nema.org)

© 2014 National Electrical Manufacturers Association. All rights, including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American copyright conventions.

## NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

The National Electrical Manufacturers Association (NEMA) standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, expressed or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstance. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

## Foreword

This Standards Publication is intended to provide a basis of common understanding within the electrical community. User needs have been considered throughout the development of this publication. Proposed or recommended revisions should be submitted to:

Vice President, Technical Services  
National Electrical Manufacturers Association  
1300 N 17<sup>th</sup> Street, Suite 900  
Rosslyn, VA 22209

This Standards Publication was developed by the Panelboard and Distribution Board Section. Section approval of the standard does not necessarily imply that all section members voted for its approval or participated in its development. At the time it was approved, the Section was composed of the following members:

ABB Inc.—New Berlin, WI  
Eaton Cooper Bussmann—Ellisville, MO  
Eaton Electrical Inc.—Pittsburgh, PA  
GE—Plainville, CT  
Hubbell, Inc.—Bridgeport, CT  
Milbank Manufacturing Company—Kansas City, MO  
Penn Panel & Box Company—Collingdale, PA  
Post Glover Resistors, Inc.—Erlanger, KY  
Reliance Controls Corporation—Racine, WI  
Siemens Industry, Inc.—Norcross, GA  
Schneider Electric—Lexington, KY  
The Durham Company—Lebanon, MO  
Z Power & Distribution Inc.—Orange, CA

**This page intentionally left blank.**

Currently in preview, click buy full version

## CONTENTS

Foreword .....	i
Section 1 GENERAL .....	1
1.1 Scope .....	1
1.2 Referenced Standards .....	1
1.2.1 Other References .....	2
Section 2 INTRODUCTION .....	4
2.1 Arcing Ground Faults .....	4
2.2 Need for Ground Fault Protection .....	4
2.3 Standards .....	4
2.4 Application—General .....	5
2.5 Relay Setting Selections—General .....	5
2.5 Methods of GFP Device Selectivity .....	5
2.7 Damage Levels .....	5
Section 3 POWER CIRCUIT .....	6
3.1 Voltage .....	6
3.2 Frequency .....	6
3.3 Current Rating .....	6
3.4 Location of GFS Devices .....	6
3.4.1 Ground Return Method .....	6
3.4.2 Outgoing Circuit Method (Residual or Zero-Sequence) .....	6
3.5 Ground Connections .....	6
3.6 Mounting and Connection of GFS Devices .....	7
3.7 Delta-Connected Systems .....	7
3.8 Neutrals and Grounding .....	7
3.9 Need for Complete System Information .....	7
3.10 Systems Containing Transformers .....	8
3.11 System Design .....	8
Section 4 CONTROL CIRCUIT .....	9
4.1 Control Power .....	9
4.2 AC Control Power .....	9
4.3 DC Control Power .....	9
4.4 Control Circuit Protection .....	9
4.5 Control Wiring .....	9
4.6 Indication and Test Circuits .....	9
4.7 Compatibility of GFP Devices .....	10
Section 5 TYPICAL APPLICATION DIAGRAMS .....	11
5.1 General .....	11
5.1.1 Abbreviations .....	11
5.2 Ground Fault Protection on Main Disconnect Only—Ground Return Type .....	11
5.3 Ground Fault Protection on Main Disconnect Only—Outgoing Circuit Type .....	12

5.4	Ground Fault Protection on Main and Feeder Disconnects—Ground Return Type on Main .....	13
5.5	Ground Fault Protection on Main and Feeder Disconnects—Outgoing Circuit Type on Main .....	14
5.6	Ground Fault Protection on Main and Feeder Disconnects with Zone-Selective Interlocking—Ground Return Type on Main .....	15
5.7	Ground Fault Protection on Main, Feeders, and Selected Branch Disconnects with Zone-Selective Interlocking—Outgoing Circuit Type on Main .....	16
5.8	Double-Ended System with Ground Fault Protection on Mains, Tie, and Feeder Disconnects—Ground Return Type on Mains .....	13
<b>Section 6 TIME AND CURRENT SETTINGS .....</b>		<b>20</b>
6.1	Application of GFP Systems for Coordinated Ground Fault Tripping .....	20
6.2	Types of Coordinated Ground Fault Tripping Systems .....	20
6.3	Time-Current Band Selective System .....	20
6.4	Zone-Selective System .....	20
6.5	Coordination of Low-Voltage Disconnects with the High-Voltage Side of a System .....	21
6.6	Coordination with Downstream Overcurrent Devices Not Equipped with Ground Fault Protection .....	21
6.7	Typical Settings .....	21
6.7.1	Single-Zone GFP on Main Disconnect Only .....	22
6.7.2	Multiple-Zone Time-Current Band Selective System—GFP on Mains, Feeders, and Branch Circuits .....	24
6.7.3	Zone-Selective System—Ground Fault Protection on Mains and Feeders .....	25
<b>Section 7 TYPICAL COORDINATED SYSTEMS .....</b>		<b>27</b>
7.1	Coordinated Protection .....	27
7.2	Examples .....	27
7.2.1	GFP on Main Disconnect Only .....	27
7.2.2	GFP on Main Disconnect and Feeders .....	28
7.2.3	Fully Coordinated Multiple-Zone GFP Systems .....	28
<b>Section 8 TESTING OF GFS AND GFI EQUIPMENT .....</b>		<b>29</b>
8.1	Design Tests .....	29
8.2	Production Tests .....	29
8.3	Tests on Assembled Equipment .....	29
8.4	Preparation for Field Testing .....	29
8.5	Field Testing .....	30
<b>Annex A ARCING FAULT DAMAGE LEVELS .....</b>		<b>31</b>
A.1	Approximate Arcing Fault Damage Levels for 480Y/277 Volt Systems .....	31
A.2	Arcing Fault Current .....	31
A.3	Assumed Tolerable Damage Levels .....	31
A.4	Probable Amount of Damage .....	32
<b>Annex B SYSTEM DESIGN CONSIDERATIONS .....</b>		<b>35</b>
B.1	General .....	35
B.2	Power System .....	35
B.3	Ground Fault Current Paths .....	35

B.4	Ground Fault Protective Devices and Settings.....	35
B.5	Control Power .....	35

**Figures**

Figure 5-1	Ground Fault Protection on Main Disconnect Only (Ground Return Type).....	12
Figure 5-2	Ground Fault Protection on Main Disconnect Only (Outgoing Circuit Type).....	13
Figure 5-3	Ground Fault Protection on Main and Feeder Disconnects (Ground Return Type on Main) .....	14
Figure 5-4	Ground Fault Protection on Main and Feeder Disconnects (Outgoing Circuit Type on Main) .....	15
Figure 5-5	Ground Fault Protection on Main and Feeder Disconnects with Zone-Selective Interlocking (Ground Return Type on Main).....	16
Figure 5-6	Ground Fault Protection on Main, Feeders, and Selected Branch Disconnects with Zone-Selective Interlocking (Outgoing Circuit Type on Main) .....	17
Figure 5-7	Double-Ended System with Ground Fault Protection on Mains and on Tie and Feeder Disconnects (Ground Return Type on Mains) .....	19
Figure 6-1	Typical Ground Fault Protection on Main Disconnect Only.....	23
Figure 6-2	Typical Ground Fault Protection on Main Disconnect and Feeders.....	24
Figure 6-3	Typical Fully Coordinated Multizone GFP System .....	25
Figure 6-4	Typical Fully Coordinated Multizone GFP System with Zone-Selective Interlocking.....	26
Figure A-1	Assumed Tolerable Damage Levels .....	33

**Tables**

Table A-1	Short Time or Instantaneous Trip Settings (Recommended Calculated Maximum Current Settings in Kiloamperes).....	34
-----------	---	----

**This page intentionally left blank.**

Currently in preview, click buy full version

## Section 1 GENERAL

### 1.1 SCOPE

This publication is a guide of practical information containing instructions for the safe and proper application of ground fault protective devices (hereafter referred to as GFP devices).

GFP devices include current sensing devices (GFS), relaying equipment (GFR), combinations of G-S and GFR equipment, or other equivalent protective equipment that will operate to cause a disconnecting means to open all ungrounded conductors at predetermined values of ground fault current and time. GFP devices are intended to protect equipment only against extensive damage from ground faults.

GFP devices are intended to operate circuit breakers or fusible switches equipped with electrically actuated tripping means. These devices may be supplied as an integral portion of the disconnecting means or as separate devices operating in conjunction with the disconnecting means. GFP devices may or may not require external control power for proper tripping operation.

GFP devices are designed to be used primarily on solidly grounded distribution systems rated up to a maximum of 600 volts ac to provide for rapid clearing of ground faults. The *National Electrical Code*<sup>®</sup> (*NEC*) requires ground fault protection in certain instances. In other situations, ground fault protection is added at the request of the customer. This application guide does not cover all possible applications of these devices.

GFP systems described in this publication are intended for equipment protection only. They cannot provide protection for personnel. A GFR system designed for protecting equipment cannot protect personnel against electric shock hazards because personnel protective devices, such as ground-fault circuit-interrupters, require a sensitivity in the milliampere range. The systems used to meet the requirements of Article 230-Services and Article 517-Health Care Facilities of the *NEC* have a sensitivity in the multi-ampere range. *This application guide does not contain information on ground fault protection for personnel (GFCI).*

### 1.2 REFERENCED STANDARDS

In this publication, reference is made to the standards listed below. Copies are available from the indicated sources.

#### **National Fire Protection Association**

Batterymarch Park  
Quincy, MA 02269

NFPA 70

*National Electrical Code*<sup>®</sup>

#### **National Electrical Manufacturers Association**

1300 North 17<sup>th</sup> Street, Suite 900  
Rosslyn, VA 22209

NEMA AB 1 (UL 489)

*Molded Case Circuit Breakers and Molded Case Switches*