

NEMA SG 10-2019

Guide to OSHA and
NFPA 70E Safety
Requirements When
Servicing and
Maintaining
Medium-Voltage
Switchgear, Circuit
Breakers, and Medium-
Voltage Controllers
Rated above 1000 V



NEMA Standards Publication SG 10-2019

*Guide to OSHA and NFPA 70E Safety Requirements
When Servicing and Maintaining Medium-Voltage Switchgear, Circuit Breakers,
and Medium-Voltage Controllers Rated above 1000 V*

Published by

National Electrical Manufacturers Association
1600 North 17th Street, Suite 900
Rosslyn, Virginia 22209

www.nema.org

© 2020 National Electrical Manufacturers Association. All rights, including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literacy and Artistic Works, and the International and Pan American copyright conventions.

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

NEMA Standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus Standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its Standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, express or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this Standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other Standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health- or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

Foreword

This guide was written to emphasize basic principles and guidance for safety when performing inspection, operation, and maintenance of medium-voltage switchgear, circuit breakers, and medium-voltage controllers rated above 1000 V. It also draws the reader's attention to important OSHA and NFPA safety Standards. Proposed or recommended revisions should be submitted to:

NEMA Technical Operations Department
National Electrical Manufacturers Association
1300 North 17th Street, Suite 900
Rosslyn, VA 22209

This guide was developed by the Switchgear Section of the Power Equipment Division. Section approval of the guide does not necessarily imply that all section Members voted for its approval or participated in its development. At the time this guide was approved, the Section was composed of the following Members:

Organization Name	City	State
ABB Inc.	Cary	NC
Eaton	Cleveland	OH
Federal Pacific	Bristol	VA
G&W Electric Company	Bolingbrook	IL
GE Grid Solutions	Charleroi	PA
Hubbell Incorporated	Shelton	CT
Mersen USA Newburyport-MA, LLC	Newburyport	MA
Mitsubishi Electric Power Products, Inc.	Warrendale	PA
S&C Electric Company	Chicago	IL
Schneider Electric	Boston	MA
Siemens Industry, Inc.	Norcross	GA
Toshiba International Corporation USA	Houston	TX
Z Power & Distribution Inc.	Anaheim	CA

CONTENTS

Foreword	i
Section 1 General	1
1.1 Scope.....	1
1.2 Purpose	1
1.3 General Considerations.....	1
1.4 Safety.....	2
1.5 References	3
Section 2 Definitions	5
2.1 Qualified Persons	5
2.2 Approach Boundaries	5
Section 3 Training.....	6
Section 4 Job Plan.....	7
4.1 Job Plan Creation	7
4.2 Job Briefing	7
Section 5 Emergency Plan.....	8
Section 6 Area Security.....	9
Section 7 Removing Equipment from Service	10
7.1 Voltage Detection	10
7.2 Grounding	10
7.3 Lockout/Tagout Procedures	11
Section 8 Returning Equipment to Service	12
Section 9 Recordkeeping and Responsibilities of Individuals	13
9.1 Recordkeeping	13
9.2 Responsibilities of Individuals	13
Appendix A Job Plan Example	14

Section 1 General

1.1 Scope

The main objective of this guide is to enhance electrical safety awareness and mitigate electrical hazards to Members of the workforce assigned to servicing and maintaining switchgear, owners, and users of the equipment, and the public. The goal of this guide is to ensure the adoption of OSHA and NFPA 70E safety-related practices for electrical work and requirements of electrical safety.

Provisions contained herein are applicable to all Members of the workforce who are engaged in testing, servicing, maintaining, and decommissioning switchgear, circuit breakers, and controllers rated above 1000 V.

This guide emphasizes OSHA and NFPA 70E safety requirements when servicing and maintaining equipment covered in, but not limited to, the following Standards:

- a. Medium-voltage metal-clad switchgear assemblies (rated 1000 through 38,000 V) in accordance with ANSI/IEEE C37.20.2, *Standard for Metal-Clad Switchgear*
- b. Medium-voltage metal-enclosed switchgear assemblies (rated 1000 through 38,000 V) in accordance with ANSI/IEEE C37.20.3, *Standard for Metal-Enclosed Interrupter Switchgear*
- c. Circuit breakers rated above 1000 V in accordance with ANSI/IEEE C37.04, *Standard Rating Structure for AC High-Voltage Circuit Breakers*
- d. Medium-voltage controllers in accordance with UL 347, *Medium-Voltage AC Contactors, Controllers, and Control Centers*
- e. Medium-voltage pad-mounted switchgear (rated 1,000 through 38,000 V) in accordance with IEEE C37.74, *Standard Requirements for Subsurface, Vault, and Pad-Mounted Load-Interrupter Switchgear and Fused Load-Interrupter Switchgear for Alternating Current Systems Up to 38 kV*.
- f. C37.60, IEEE/IEC International Standard—High-voltage switchgear and controlgear—Part 111: Automatic circuit reclosers and fault interrupters for alternating current systems up to 38kV

For convenience, this equipment will be called switchgear assemblies. Switchgear assemblies and controller assemblies may contain but are not limited to devices such as power circuit breakers, contactors, interrupter switches, selector switches, power fuses, controls, instrumentation, metering, and other protective equipment. These assemblies may be part of unit substations.

1.2 Purpose

The provisions of the *National Electric Code*® (NEC), *Standard for Electrical Safety in the Workplace*, NFPA 70E, *National Electric Safety Code* (NESC), and OSHA Standards contained in this guide should be complied with at all user-controlled premises. These guidelines have specific requirements that apply to installations, servicing, and maintaining switchgear regardless of when they were designed or installed and are considered essential for ensuring workplace safety.

1.3 General Considerations

Working on or around electrical equipment is potentially dangerous, and accidents in the course of maintaining and servicing electrical equipment can lead to death or serious injury. These accidents do not have to happen. Almost all accidents can be avoided if OSHA and NFPA Standards, as well as the operation and maintenance instructions for the equipment, are carefully followed. Read and understand them fully before work is started! A few examples by which maintenance and service personnel might avoid serious injury or death when working around electrical equipment: