

NEMA TCB 2-2017

Guidelines for the Selection and Installation of Underground Nonmetallic Raceways





NEMA Standards Publication TCB 2-2017

Guidelines for the Selection and Installation of Underground Nonmetallic Raceways

Published by

National Electrical Manufacturers Association
1700 North 17th Street, Suite 900
Rosslyn, Virginia 22209
www.nema.org

© 2017 National Electrical Manufacturers Association. All rights, including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

NEMA standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, expressed or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

Foreword

These guidelines are intended to assist in obtaining the most appropriate and satisfactory installation of rigid nonmetallic conduit (RNC) or raceway systems.

These guidelines are in no way intended to assume or replace any responsibilities of engineers, customer representatives, owners, or other persons in establishing engineering design practices and procedures best suited to individual job conditions.



Typical Installation Using Spacers

NEMA TCB 2 was approved by the NEMA Polymer Raceway Products Section. Approval does not necessarily imply that all members of the Section voted for its approval. At the time of approval, the Section consisted of the following members:

Anamet Electrical, Inc., Mattoon, IL, www.anacondasealtite.com
AFC Cable Systems, a part of Atkore International, New Bedford, MA, www.afcweb.com
Allied Tube and Conduit, a part of Atkore International, Harvey, IL, www.alliedtube.com
Champion Fiberglass, Inc., Spring TX, www.championfiberglass.com
Electri-Flex Company, Roselle, IL, www.electriflex.com
FRE Composites, St. Andre-d'Armenteuil, PQ, Canada, www.frecomposites.com
Hubbell Incorporated, Shelton, CT, www.hubbell.com
IPEX Group, Mississauga, ON, Canada, www.ipexinc.com
Legrand North America, West Hartford, CT, www.legrand.us
Panduit Corporation, Tinley Park, IL, www.panduit.com
Royal Building Products, Shelby Township, MI, www.royalbuildingproducts.com
Southern Pipe, Inc., New London, NC, www.southern-pipe.com
Southwire Corporation, Carrollton, GA, www.southwire.com
Thomas & Betts, a member of the ABB Group, Memphis, TN, www.tnb.com,
Underground Devices, Inc., Northbrook, IL, www.udevices.com
United Fiberglass of America, Springfield, OH, www.unitedfiberglass.com

The NEMA Polymer Raceway Products Section will periodically review this standard and revise it as necessary.

Proposed or recommended revisions can be submitted to:

Senior Technical Director, Operations
National Electrical Manufacturers Association
1300 North 17th Street, Suite 900
Rosslyn, Virginia 22209

CONTENTS

1	Scope	1
2	Nomenclature	1
3	Reference Publications	1
4	Selection of Conduit and Duct.....	2
4.1	Types of Raceway.....	2
4.1.1	Raceway Designed for Encased Burial (EB) in Concrete.....	2
4.1.2	Raceway Designed for Direct Burial (DB).....	2
4.2	Pipe Stiffness	3
5	Handling and Storage of Conduit and Duct.....	3
5.1	Handling.....	3
5.2	Storage.....	4
5.2.1	Framed Units.....	4
5.2.2	Coils and Reels.....	4
5.2.3	Bulk Storage.....	5
5.2.4	Elbows and Sweeps.....	5
5.2.5	Fittings, Spacers, and Accessories.....	5
5.2.6	Cleaners, Primers, Cements, and Adhesives	5
5.2.7	Inventories.....	5
5.3	Handling on the Jobsite.....	5
5.3.1	Conduit and Duct	5
5.3.2	Coils and Reels	5
5.3.3	Solvent Products	5
6	Installation of Conduit and Duct	6
6.1	Proper Installation	6
6.2	Trench Excavation	6
6.2.4	Trench Wall	7
6.2.5	Trench Bottom.....	7
6.3	Conduit and Duct Separation.....	7
6.3.1	Raceway Supports	7
6.3.2	Power Duct Banks.....	8
6.3.3	Communication Duct Banks.....	9
6.3.4	Combined Power and Communication Duct Banks.....	9
6.3.5	Spacer Specifications.....	9
6.4	Joining of Raceway	9
6.5	Encased Burial (EB) of Rigid Nonmetallic Conduit (RNC).....	9
	Example of Concrete Encasement.....	9
6.5.1	Conduit and Duct Laying.....	10
6.5.2	Spacers	10
6.5.3	Sequence of Laying	10
6.5.4	Closure of Run between Manholes.....	10
6.5.5	Temperature.....	10
6.5.6	Anchoring	11
6.5.7	Concrete Pour	11
6.5.8	Backfilling	11
6.6	Direct Burial (DB) of Rigid Nonmetallic Conduit (RNC)	12
6.6.1	Conduit and Duct Laying.....	12
6.6.2	Temperature.....	12
6.6.3	Elbows or Bends for Grade Changes.....	12
6.6.4	Raceway Embedment and Final Backfill.....	12
6.6.5	Compaction	13
6.7	Expansion Fittings.....	13
6.8	Field Bending	14
6.9	Short-Radius Elbows.....	14
6.10	Conduit and Duct Repairs.....	14
6.10.1	Conductors and Cabling.....	14

6.10.2	PVC Raceway and RTRC (Cables de-energized and removed)	14
		18
6.10.4	High Density Polyethylene (HDPE)	18
6.11	Connections to Conduit Systems of Other Materials	18
6.12	Conduit Rodding (Fishing)	18
6.13	Mandrelling	18
ANNEX A	Field Bending Procedures For Pvc Conduit	21
A.1	Joining	21
A.2	Trench Preparation	22
A.3	Procedures for Installation of Conduits for Field Bends	22
ANNEX B	Joining of RTRC	25
B.1	General Recommended Joining Procedures	25
B.1.1	Cutting the Conduit	25
B.1.2	Cleaning Joint Surfaces	25
B.2	Specific Joining Types and Procedures	25
B.2.1	RTRC Adhesive Joints	25
B.2.2	RTRC Gasket Joints	25
B.2.3	RTRC inside Tapered Bell and Spigot Joint Installation (with or without Adhesive)	26
B.2.4	RTRC Adhesive Straight Bell and Spigot Joint Installation	26
B.3	Joint Cleaning and Adhesive Instructions	27
B.3.1	Joint Cleaning	27
B.3.4	Adhesive Work Life	28
B.3.5	Adhesive Curing Time	29
B.4	RTRC Coupling Joints	29

< This page left intentionally blank. >

1 Scope

This guideline covers recommendations for the selection, handling and installation of underground single bore rigid nonmetallic conduit (RNC) or raceway for power, lighting, signaling, and communications applications. For this guideline, RNC refers to PE, PVC or RTRC conduit and duct. Corrugated coilable utility duct is not covered in this guideline; details on storage, handling, and installation are covered in NEMA TCB 3.

Guidelines for HDPE conduit are covered in NEMA TCB 4.

Although not specifically mentioned in this guideline, variations of the products discussed may occasionally be specified. Users should follow installation recommendations of the manufacturer.

2 Nomenclature

Abbreviations for nonmetallic materials referenced in this guideline include the following:

EPEC	Electrical Polyethylene Conduit
HDPE	High-Density Polyethylene
PVC	Polyvinyl Chloride
RTRC	Reinforced Thermosetting Resin Conduit (fiberglass)

Abbreviations for burial type include:

DB	Direct burial—refers to duct buried without concrete encasement
EB	Encased burial—refers to duct buried with concrete encasement

Abbreviations for stiffness include:

DS	Duct stiffness
PS	Pipe stiffness

Abbreviations for conduit type include:

EPC 40	PVC conduit (Schedule 40)
EPC 80	PVC conduit (Schedule 80)
RNC	Rigid nonmetallic conduit

Abbreviations for wall type include:

HW	Heavy wall—refers to HW RTRC
TW	Thin wall—refers to TW RTRC
SW	Standard wall—refers to SW RTRC
XW	Extra heavy wall—refers to XW RTRC

3 Reference Publications

ASTM D2412 *Standard Test Method for Determination of External Loading Characteristics of Plastic Pipe by Parallel-Plate Loading*

ASTM D2564 *Standard Specification for Solvent Cements for Poly (Vinyl Chloride) (PVC) Plastic Piping Systems*

ASTM D2657 *Standard Practice for Heat Fusion Joining of Polyolefin Pipe and Fittings*

ASTM D2855 *Standard Practice for Making Solvent-Cemented Joints with Poly (Vinyl Chloride) (PVC) Pipe and Fittings*