

NEMA Standards Publication WD 7-2011 (R2016, R2021)

Occupancy Motion Sensors Standard

Published by

National Electrical Manufacturers Association
1300 N. 17th Street
Rosslyn, Virginia 22209

www.nema.org

© 2021 National Electrical Manufacturers Association. All rights including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

The National Electrical Manufacturers Association (NEMA) Standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus Standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its Standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, express or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this Standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other Standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

Contents

CONTENTS	i
FOREWORD	ii
Section 1 GENERAL	1
1.1 Scope	1
1.2 Definitions	1
Section 2 ILLUSTRATIONS	3
2.1 General	3
2.2 Minimum Illustration	3
2.3 Format of Illustration	3
Section 3 TESTING	5
3.1 Operating Conditions for Coverage Area Testing	5
3.1.1 Indoor Products	5
3.1.2 Outdoor Products	5
3.1.3 Test Setup	5
3.2 Major Motion Testing	6
3.2.1 Test Subject	6
3.2.2 Test Environment	6
3.3 Minor Motion Testing	6
3.3.1 Test Apparatus	6
3.3.2 Test Environment	6
3.3.3 Direction of Motion	6
3.3.4 Setup and Test Procedure	7
ANNEX A	A-1

FOREWORD

The purpose of this Standard is to promote uniformity for the definition and measurement of characteristics relevant to the use and application of occupancy motion sensors. The Standard is not intended to set performance levels.

In the preparation of this Standard, input from users and other interested parties has been sought and evaluated. Inquiries, comments, and proposed or recommended revisions should be submitted to the concerned NEMA product subdivision by contacting the:

NEMA Technical Operations Department
National Electrical Manufacturers Association
1300 North 17th Street, Suite 900
Rosslyn, Virginia 22209

This is the first edition of this Standard. It was developed from a former technical guide under the same designation.

The Standards or guidelines presented in a NEMA Standards publication are considered technically sound at the time they are approved for publication. They are not a substitute for a product seller's or user's own judgment with respect to the particular product referenced in the Standard or guideline, and NEMA does not undertake to guarantee the performance of any individual manufacturer's products by virtue of this Standard or guideline. Thus, NEMA expressly disclaims any responsibility for damages arising from the use, application, or reliance by others on the information contained in these Standards or guidelines.

This Standard was developed by the NEMA Wiring Device Section. Section approval of the guide does not necessarily imply that all section Members voted for its approval or participated in its development. At the time it was approved, the NEMA Wiring Device Section was composed of the following Members:

Eaton Residential & Wiring Devices Division	Peachtree City	GA
Enerlites Inc.	Irvine	CA
Hubbell Incorporated	Shelton	CT
Interpower Corporation	Ames	IA
Legrand, North America	Syracuse	NY
Leviton Manufacturing Co., Inc.	Melville	NY
Leviton Manufacturing of Canada Ltd.	Pointe-Claire	QC
Lutron Electronics Company, Inc.	Coopersburg	PA
NEMA	Dobbins	CA
Schneider Electric	Knightdale	NC
Signify North America Corporation	Rosemont	IL
Sky Technologies	Alpharetta	GA
Snap Power	Vineyard	UT
Software Company	Largo	FL
ULC Canada ULC	Markham	ON
Titan3 Technology LLC	Tempe	AZ

Section 1 GENERAL

1.1 SCOPE

This Standard publication covers the definition and measurement of field of view and coverage characteristics relevant to the use and application of vacancy and occupancy sensors using individual or any combination of passive infrared, ultrasonic, or microwave technology. These sensors are used in systems for control of lighting, heating, ventilating, and air conditioning (HVAC), and other devices.

1.2 DEFINITIONS

The definitions below apply to terms used in this guide publication or in manufacturers' specification sheets and product literature, or both. Where the terms are used in this guide publication or in a manufacturer's specification sheet or other product literature, the following definitions apply.

bypass: the means of forcing loads into "ON" or "OFF" condition by circumventing the device.

cell: a 3 foot by 3 foot section of the grid.

coverage area: the area in which the sensor can detect motion, comprised of the horizontal and vertical fields of view.

energy consumption: total consumption in milliwatts for 1 hour with the controlled load "ON" for 30 minutes and "OFF" for 30 minutes.

grid: the area in which the sensor is tested divided into 3 foot by 3 foot sections.

horizontal field of view: the area of coverage on a horizontal plane to the sensor while the sensor is mounted in the orientation recommended by the manufacturer. The height of the horizontal field is at a level of 36 ± 1 inches above the ground.

immunity to false activation: the ability to ignore external events which are not intended to activate the product.

initial trigger motion detection: the condition when the sensor is operating in an unoccupied coverage area.

line of sight coverage: the ability to detect motion when there is not any object(s) between the motion and sensor or to obscure or to block the detection of motion.

maintained motion detection: the condition when the sensor is operating in an occupied coverage area.

motion: movement of a person walking into or through an area.

measurement units:

- degrees for viewing angles
- feet (m) for distance
- feet and inches (m) for mounting height
- feet per second (m/s) for velocity
- square feet (m²) for coverage area