



PROCESS
INDUSTRY
PRACTICES

TECHNICAL REVISION
June 2021

Insulation

**PIP INSA1000
Acoustic Insulation System Specification**

Currently in preview, click buy full version

PURPOSE AND USE OF PROCESS INDUSTRY PRACTICES

In an effort to minimize the cost of process industry facilities, this Practice has been prepared from the technical requirements in the existing standards of major industrial users, contractors, or standards organizations. By harmonizing these technical requirements into a single set of Practices, administrative, application, and engineering costs to both the purchaser and the manufacturer should be reduced. While this Practice is expected to incorporate the majority of requirements of most users, individual applications may involve requirements that will be appended to and take precedence over this Practice. Determinations concerning fitness for purpose and particular matters or application of the Practice to particular project or engineering situations should not be made solely on information contained in these materials. The use of trade names from time to time should not be viewed as an expression of preference but rather recognized as normal usage in the trade. Other brands having the same specifications are equally correct and may be substituted for those named. All Practices or guidelines are intended to be consistent with applicable laws and regulations including OSHA requirements. To the extent these Practices or guidelines should conflict with OSHA or other applicable laws or regulations, such laws or regulations must be followed. Consult an appropriate professional before applying or acting on any material contained in or suggested by the Practice.

This Practice is subject to revision at any time.

© Process Industry Practices (PIP), Construction Industry Institute, The University of Texas at Austin, 3925 West Braker Lane (F-700), Austin, Texas 78759. PIP member companies and subscribers may copy this Practice for their internal use. Changes or modifications of any kind are not permitted within any PIP Practice without the express written authorization of PIP. Authorized Users may attach addenda or overlays to clearly indicate modifications or exceptions to specific sections of PIP Practices. Authorized Users may provide their clients, suppliers and contractors with copies of the Practice solely for Authorized Users' purposes. These purposes include, but are not limited to the procurement process (e.g., as attachments to requests for quotation / purchase orders or requests for proposals/contracts) and preparation and issue of design engineering deliverables for use on a specific project by Authorized User's client. PIP's copyright notices must be clearly indicated and unequivocally incorporated in documents where an Authorized User desires to provide any third party with copies of the Practice.

REVISION HISTORY

March 2001	Issued	May 2008	Editorial Revision	June 2021	Technical Revision
June 2006	Complete Revision	July 2012	Reaffirmation with Editorial Revision		
February 2007	Editorial Revision	April 2015	Technical Revision		

Not printed with State funds



PIP INSA1000 Acoustic Insulation Systems Specification

Table of Contents

1. Scope2

2. References2

2.1 Process Industry Practices2

2.2 Industry Codes and Standards.....2

3. Definitions2

4. Requirements3

4.1 Acoustic Insulation - General Design Information3

4.2 Installation of the Absorptive Layer ..4

4.3. Installation of the Barrier Layer5

4.4 Data Sheets.....6

4.5 Inspection6

4.6 Documentation6

List of Details

- INSA1001** – Various Acoustic Insulation Configurations
- INSA1002** – Piping - Layer Staggering & Overlapping of Absorptive Barrier
- INSA1003** – Piping - Sheet and Mastic Barrier Layer Attachment
- INSA1004** – General Arrangement - Piping Insulation
- INSA1005** – Piping - Flange Insulation
- INSA1006** – Valves without Extended Bonnets

Data Form

- INSA1000-D001** – Documentation Requirements Sheet

1. Scope

This Practice describes the requirements for the design, application, and extent of acoustic insulation on piping and equipment operating at high and low temperatures. Systems requiring additional insulation specifications beyond PIP Practices, such as *ISO 15665*, shall be covered by purchaser's documentation.

Listing of or reference to supporting documents within this Practice does not imply suitability for specific designs.

Comment: Use of this Practice for contractual purposes requires the purchaser to make specific choices and assemble additional supporting documents.

2. References

Applicable parts of the following Practices and industry codes and standards should be considered an integral part of this Practice. The edition in effect on the date of contract award should be used, except as otherwise noted. Short titles will be used herein where appropriate.

2.1 Process Industry Practices (PIP)

- PIP INEG1000 - *Insulation Design Guide*
- PIP INTG1000 - *Insulation Inspection Checklist*
- PIP INSC1000 - *Cold Service Insulation Materials and Installation Specification*
- PIP INSH1000 - *Hot Service Insulation Materials and Installation Specification*

2.2 Industry Codes and Standards

- International Organization for Standardization (ISO)
 - ISO 15565 - *Acoustics - Acoustic Insulation for Pipes, Valves and Flanges*

3. Definitions

absorptive layer: Porous resilient, low-density 48 to 128 kg/m³ (3 to 8 lb/ft³) material such as glass or mineral fiber applied to a sound-radiating surface to absorb sound

acoustic insulation: Insulation that attenuates acoustic energy radiating from surfaces by absorption and containment. Acoustic insulation can be used to reduce surface radiation from many different types of piping and equipment and to comply with regulatory requirements. Acoustic insulation is composed of a resilient sound-absorptive layer and an outer-barrier layer applied to noise-radiating surfaces.

Noise Reduction (NR): Difference in noise, also known as sound pressure level, at a given point before and after acoustic treatment, measured in dBA

outer barrier layer: Impermeable, dense material such as loaded vinyl, elastomer, or mastic installed over the absorptive layer to provide a sound barrier

transmission loss: Reduction in magnitude between the incident and transmitted sound for a given acoustic material