



PROCESS
INDUSTRY
PRACTICES

COMPLETE REVISION
September 2016

Machinery

PIP REEE003
Guidelines for General Purpose
Non-Lubricated Flexible Couplings

Currently in preview, click buy full version

PURPOSE AND USE OF PROCESS INDUSTRY PRACTICES

In an effort to minimize the cost of process industry facilities, this Practice has been prepared from the technical requirements in the existing standards of major industrial users, contractors, or standards organizations. By harmonizing these technical requirements into a single set of Practices, administrative, application, and engineering costs to both the purchaser and the manufacturer should be reduced. While this Practice is expected to incorporate the majority of requirements of most users, individual applications may involve requirements that will be appended to and take precedence over this Practice. Determination concerning fitness for purpose and particular matters or application of the Practice to particular project or engineering situations should not be made solely on information contained in these materials. The use of trade names from time to time should not be viewed as an expression of preference but rather recognized as normal usage in the trade. Other brands having the same specifications are equally correct and may be substituted for those named. All Practices or guidelines are intended to be consistent with applicable laws and regulations including OSHA requirements. To the extent these Practices or guidelines should conflict with OSHA or other applicable laws or regulations, such laws or regulations must be followed. Consult an appropriate professional before applying or acting on any material contained in or suggested by the Practice.

This Practice is subject to revision at any time.

© Process Industry Practices (PIP), Construction Industry Institute, The University of Texas at Austin, 3925 West Braker Lane (R4500), Austin, Texas 78759. PIP Member Companies and Subscribers may copy this Practice for their internal use. Changes or modifications of any kind are not permitted within any PIP Practice without the express written authorization of PIP. Authorized Users may attach addenda or overlays to clearly indicate modifications or exceptions to specific sections of PIP Practices. Authorized Users may provide their clients, suppliers and contractors with copies of the Practice solely for Authorized Users' purposes. These purposes include but are not limited to the procurement process (e.g., as attachments to requests for quotation/purchase orders or requests for proposals/contracts) and preparation and issue of design engineering deliverables for use on a specific project by Authorized User's client. PIP's copyright notices must be clearly indicated and unequivocally incorporated in documents where an Authorized User desires to provide any third party with copies of the Practice.

PUBLICATION HISTORY

April 1998	Issued as PIP RESE003
March 2000	Complete Revision of PIP RESE003
August 2011	Complete Revision
March 2016	Complete Revision

Not printed with State funds



PIP REEE003
Guidelines for General Purpose
Non-Lubricated Flexible Couplings

Table of Contents

1. Scope.....	2
2. References	3
2.1 Industry Codes and Standards.....	3
3. Definitions	2
4. Type and Size Considerations...3	3
4.1 Data Requirements	3
4.2 Coupling Type.....	3
4.3 Coupling Sizing	4
5. Materials and Design.....4	4
5.1 Disc Coupling	4
5.2 Elastomeric Couplings.....	5
6. Balance.....	6
7. Speed Rating.....	6
8. Shaft Attachment.....	6
9. Documentation	7

1. Scope

This Practice describes guidelines for selecting non-lubricated flexible couplings for general purpose applications for most types of rotating equipment. General purpose coupling applications include loads with steady, non-fluctuating torque characteristics within the power and speed ranges defined in this Practice.

This Practice does not include guidelines for diaphragm couplings.

This Practice does not cover coupling applications for rotating equipment having any of the following characteristics:

- a. Rotational speeds greater than 3,600 rpm
- b. Driver-rated power greater than 2,000 horsepower
- c. Non-steady (fluctuating) torque characteristic
- d. Couplings covered by *API 671*, Special Purpose Couplings for Petroleum, Chemical and Gas Industry Services

2. References

Applicable parts of the following industry codes and standards shall be considered an integral part of this Practice. The latest edition in effect on the date of contract award shall be used, except as otherwise noted. Short titles are used herein where appropriate.

2.1 Industry Codes and Standards

- American National Standards Institute (ANSI)
 - ANSI/AGMA 9000-290 - *Flexible Couplings - Potential Unbalance Classification*
 - ANSI/AGMA 9000-286 - *Bores and Keyways for Flexible Couplings (Inch Series)*
- American Petroleum Institute (API)
 - *API 671 - Special Purpose Couplings for Petroleum, Chemical, and Gas Industry Services*
- Occupational Safety and Health Administration (OSHA)
 - OSHA 1910.219 - *Mechanical power-transmission apparatus*

3. Definitions

Diaphragm coupling: Type of flexible coupling consisting of one or more flexible elements that are attached to the outside diameter of one flange and that transfer torque through the diaphragm to its inside diameter attachment (i.e., a spacer or another flange). This type of coupling is considered a special purpose device and is not covered in this Practice.

disc coupling: Type of flexible coupling consisting of several flexible elements that are alternately attached with bolts to the opposite flanges. This type of coupling may be applied on either general purpose or special purpose machines.