



PROCESS
INDUSTRY
PRACTICES

TECHNICAL REVISION
January 2020

Machinery

PIP RESP003V
Specification for High Power
Vertical Centrifugal Pumps for Water Service

Currently in preview, click buy full version

PURPOSE AND USE OF PROCESS INDUSTRY PRACTICES

In an effort to minimize the cost of process industry facilities, this Practice has been prepared from the technical requirements in the existing standards of major industrial users, contractors, or standards organizations. By harmonizing these technical requirements into a single set of Practices, administrative, application, and engineering costs to both the purchaser and the manufacturer should be reduced. While this Practice is expected to incorporate the majority of requirements of most users, individual applications may involve requirements that will be appended to and take precedence over this Practice. Determination concerning fitness for purpose and particular matters or application of the Practice to a particular project or engineering situations should not be made solely on information contained in these materials. The use of trade names from time to time should not be viewed as an expression of preference but rather recognized as normal usage in the trade. Other brands having the same specifications are equally correct and may be substituted for those named. All Practices or guidelines are intended to be consistent with applicable laws and regulations including OSHA requirements. To the extent these Practices or guidelines should conflict with OSHA or other applicable laws or regulations, such laws or regulations must be followed. Consult an appropriate professional before applying or acting on any material contained in or suggested by the Practice.

This Practice is subject to revision at any time.

© Process Industry Practices (PIP), Construction Industry Institute, The University of Texas at Austin, 3925 West Braker Lane (R4500), Austin, Texas 78759. PIP Member Companies and Subscribers may copy this Practice for their internal use. Changes or modifications of any kind are not permitted within any Practice without the express written authorization of PIP. Authorized Users may attach addenda or overlays to clearly indicate modifications or exceptions to specific sections of PIP Practices. Authorized Users may provide their clients, suppliers and contractors with copies of the Practice solely for Authorized Users' purposes. These purposes include but are not limited to the procurement process (e.g., as attachments to requests for quotation / purchase orders or requests for proposals / contracts) and preparation and issuance of design engineering deliverables for use on a specific project by Authorized User's client. PIP's copyright notices must be clearly indicated and unequivocally incorporated in documents where an Authorized User desires to provide any third party with copies of the Practice.

PUBLISHING HISTORY

<i>October 1997</i>	<i>Issued</i>	<i>October 2010</i>	<i>Editorial Revision</i>	<i>January 2020</i>	<i>Technical Revision</i>
<i>February 2004</i>	<i>Complete Revision</i>	<i>December 2010</i>	<i>Editorial Revision</i>		
<i>February 2010</i>	<i>Complete Revision</i>	<i>October 2013</i>	<i>Complete Revision</i>		

Part printed with State funds



PIP RESP003V Specification for High Power Vertical Centrifugal Pumps for Water Service

Table of Contents

1. Scope	2
2. References	2
2.1 Process Industry Practices.....	2
2.2 Industry Codes and Standards.....	3
3. Definitions	4
4. Requirements	6
4.1 Basic Design	6
4.2 Accessories	18
4.3 Inspection and Testing	20
4.4 Preparation for Shipment	20
4.5 Documentation	22
Table 1. Recommended Spare Parts	22
Appendix A – Selection of Pump Materials of Construction	23
Table A. Application of Material Classes to Water Services	23
Appendix B – Pump Material Classes Designations	25
Table B. Material Classes.....	25

Data Forms

- RESP003V-D – Vertical Centrifugal Pumps for Water Service (U.S. Customary Units)
- RESP003V-DM – Vertical Centrifugal Pumps for Water Service (SI Units)

1. Scope

This Practice provides requirements for design and manufacture of vertical centrifugal pumps of 150 kW (200 HP) or greater used for water services.

Comment: Water services include condensate, cooling water, demineralized water, utility water, produced water, treated water, etc.

Comment: General water services include condensate, cooling water, demineralized water, utility water, produced water, treated water, etc.

This Practice describes manufacturing and performance requirements for vertical centrifugal pumps and their accessories.

This Practice covers pumps with service conditions within the following limits:

- | | |
|--------------------------------|--------------------|
| a. Maximum discharge pressure | 35 Barg (500 psig) |
| b. Minimum pumping temperature | 0°C (32°F) |
| c. Maximum pumping temperature | 150°C (300°F) |
| d. Maximum rotational speed | 3,600 rpm |

Comment: For services outside these conditions and those that fall within the capabilities of ANSI/ASME pumps, it is recommended that *PIP RESP73V* be used for purchase of pumps.

Comment: For services within the capabilities of ANSI/ASME pumps, use *PIP RESP73V*.

Pumps covered by this Practice are classified as diffuser-and-volute, separate discharge cantilevered, and vertical can.

Vertical in-line and submersible pumps have special design characteristics and are not included in the scope of this Practice.

Fire water pumps are covered by *NFPA 20* and are not covered by this Practice.

2. References

Applicable parts of the following Practices and industry codes and standards shall be considered an integral part of this Practice. The edition in effect on the date of contract award shall be used, except as otherwise noted. Short titles are used herein where appropriate.

2.1 Process Industry Practices (PIP)

- PIP REDP003 - *Documentation Requirements for Centrifugal Pumps for Water Service*
- PIP REEE003 - *Guidelines for General Purpose Non-Lubricated Flexible Couplings*
- PIP REEP006 - *Pump Selection Guidelines*