

Technical Specification

**Information technology —
Telecommunications cabling
requirements for remote powering
of terminal equipment (ISO/IEC TS
29125:2017, MOD)**

STANDARDS
Australia



SA TS 29125:2019

This Australian Technical Specification was prepared by CT-001, Communications Cabling. It was approved on behalf of the Council of Standards Australia on 3 May 2019.

This Technical Specification was published on 24 May 2019.

The following are represented on Committee CT-001:

- Australian Chamber of Commerce and Industry
- Australian Council of Trade Unions
- Australian Digital and Telecommunications Industry Association
- Australian Industry Group
- Australian Information Industry Association
- BICSI South Pacific (Australia)
- Energy Networks Australia
- Engineers Australia
- KNX National Group
- National Electrical and Communications Association
- Telstra Corporation

This Technical Specification was issued in draft form for comment as DR SA TS 15071 C 29125:2018.

Keeping Standards up-to-date

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

www.standards.org.au

ISBN 978 1 76072 475 7

Technical Specification

Information technology — Telecommunications cabling requirements for remote powering of terminal equipment (ISO/IEC TS 29125:2017, MOD)

Origin: technical specification AS/NZS ISO/IEC 29125:2012.
Revised and redesignated as SA TS 29125:2019.

COPYRIGHT

© ISO/IEC 2019 — All rights reserved
© Standards Australia Limited 2019

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth).

Preface

This Technical Specification was prepared by the Australian members of the Joint Standards Australia/Standards New Zealand Committee CT-001, Communications Cabling, to supersede AS/NZS ISO/IEC 29125:2012, *Telecommunications cabling requirements for remote powering of data terminal equipment*.

The objective of this Technical Specification is to—

- (a) address the support of safety extra low voltage and limited power source applications that provide remote power over balanced cabling in accordance with the reference implementations of AS/NZS ISO/IEC 11801 series standards using currents per conductor of up to 500 mA and target the support of applications that provide remote power over balanced cabling to terminal equipment;
- (b) cover the transmission and electrical parameters needed to support remote power over balanced cabling;
- (c) cover various installation scenarios and how these may impact the capability of balanced cabling to support remote powering; and
- (d) specify design and configuration of cabling as specified in AS/NZS ISO/IEC 11801-1.

This Technical Specification includes a mathematical model to predict the behaviour of different bundle sizes, various cabling constructions, and installation conditions for different current capacities.

Safety (e.g. electrical safety and protection and fire) and electromagnetic compatibility (EMC) requirements are outside the scope of this Technical Specification, and are covered by other Standards and regulations. However, information given by this Technical Specification can be of assistance.

This Technical Specification is an adoption with national modifications, and has been reproduced from, ISO/IEC TS 29125:2017 *Information technology — Telecommunications cabling requirements for remote powering of terminal equipment*. The modifications are additional requirements and are set out in Appendix ZZ, which has been added at the end of the source text.

[Appendix ZZ](#) lists the variations to ISO/IEC TS 29125:2017 for the application of this Technical Specification in Australia.

As this document has been reproduced from an International Technical Specification, a full point substitutes for a comma when referring to a decimal marker.

Australian or Australian/New Zealand Standards and Technical Specifications that are identical adoptions of international normative references may be used interchangeably. Refer to the online catalogue for information on specific Standards and Technical Specifications.

The terms “normative” and “informative” are used in Technical Specifications to define the application of the appendices or annexes to which they apply. A “normative” appendix or annex is an integral part of a Technical Specification, whereas an “informative” appendix or annex is only for information and guidance.

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references.....	7
3 Terms, definitions and abbreviated terms.....	7
3.1 Terms and definitions.....	7
3.2 Abbreviated terms.....	8
4 Conformance.....	8
5 Cabling selection and performance.....	
6 Installation conditions.....	9
6.1 General.....	9
6.2 Ambient temperature.....	9
6.3 Temperature rise and current capacity.....	9
6.4 Factors affecting temperature increase.....	11
6.4.1 General.....	11
6.4.2 Installation near equipment.....	11
6.4.3 Cable count within a bundle.....	11
6.4.4 Reducing temperature increase.....	12
6.4.5 Cable bundle suspended in air.....	13
6.4.6 Administration.....	14
7 Remote power delivery over balanced cabling.....	14
8 Connecting hardware.....	15
Annex A (informative) Mitigation considerations for installed cabling.....	17
A.1 General.....	17
A.2 Minimum cabling class.....	17
A.3 Bundle size and location.....	17
A.4 Mitigation options.....	17
Annex B (informative) Modelling temperature rise for cable types, bundle sizes and installation conditions.....	18
B.1 Model basics.....	18
B.2 Power dissipated (P).....	18
B.3 Temperature difference from ambient temperature to bundle surface (ΔT_U).....	19
B.3.1 Model equations.....	19
B.3.2 Typical values for constant ρ_U	19
B.4 Temperature difference from bundle surface to bundle centre (ΔT_{th}).....	19
B.4.1 Model equations.....	19
B.4.2 Typical values for constant ρ_{th}	19
B.5 Temperature variation within the bundle ($\Delta T(x)$).....	20
B.6 Alternative presentation of the model.....	20
B.7 Adaptation model used to derive temperature rise vs. cables in a bundle.....	20
B.8 Calculations.....	21
B.9 Example.....	21
B.10 Coefficients for air and conduit.....	22
Annex C (informative) Transmission parameters related to remote powering.....	23
C.1 DC loop resistance.....	23

C.2	DC resistance unbalance (within pair)	23
C.3	DC resistance unbalance (pair to pair)	24
Annex D (informative)	Illustrations of heating of various bundle sizes and configurations	26
D.1	Limiting cable bundle size	26
D.2	Separating into smaller bundles	27
Annex E (informative)	Test protocol	28
E.1	Background	28
E.2	Test set-up	28
Annex F (informative)	Detailed test procedure	30
F.1	General	30
F.2	Test set-up	30
F.2.1	Thermocouple placement	30
F.2.2	Measurement of cable bundle in air	31
F.2.3	Measurement of cable bundle in conduit	32
Bibliography	34
Figure 1	– Examples of end point powering systems using signal pairs (top) and spare pairs (bottom)	14
Figure 2	– Examples of mid-span powering systems	15
Figure B.1	– Temperature rise profile	18
Figure D.1	– 91-cable bundle	26
Figure D.2	– Three bundles of 37 cables	26
Figure D.3	– Three bundles of 37 cables with separation	27
Figure E.1	– 37-cable bundle and temperature location	28
Figure E.2	– "Perfect bundle" and thermocouple configuration	29
Figure E.3	– Conductor configuration	29
Figure F.1	– Placement of thermocouple	30
Figure F.2	– Securing of the thermocouple	31
Figure F.3	– Test set-up for cable bundles in air	32
Figure F.4	– Test set-up for cable bundles in conduit	33
Table 1	– Maximum current per conductor versus temperature rise in a 37-cable bundle in air and conduit (all 4 pairs energized)	10
Table 2	– Calculated worst case current per conductor versus temperature rise in a bundle of 37 4-pair cables (all pairs energized)	11
Table 3	– Temperature rise versus cable bundle size (500 mA per conductor)	12
Table 4	– Temperature rise for a type of cable versus the number of energized pairs in a 37-cable bundle (500 mA per conductor)	13
Table B.1	– Bundling coefficients for different types of cables and cords (all 4 pairs energized)	22
Table C.1	– Maximum DC loop resistance of channels	23
Table C.2	– DC resistance unbalance of cables, connecting hardware and channels	24
Table C.3	– DC resistance unbalance (pair to pair)	25

INFORMATION TECHNOLOGY –
TELECOMMUNICATIONS CABLING REQUIREMENTS
FOR REMOTE POWERING OF TERMINAL EQUIPMENT

FOREWORD

- 1) ISO (the International Organization for Standardization) and IEC (the International Electrotechnical Commission) form the specialized system for worldwide standardization. National bodies that are members of ISO or IEC participate in the development of International Standards through technical committees established by the respective organization to deal with particular fields of technical activity. ISO and IEC technical committees collaborate in fields of mutual interest. Other international organizations, governmental and non-governmental, in liaison with ISO and IEC, also take part in the work. In the field of information technology, ISO and IEC have established a joint technical committee, ISO/IEC JTC 1.
- 2) The formal decisions or agreements of IEC and ISO on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees and ISO member bodies.
- 3) IEC, ISO and ISO/IEC publications have the form of recommendations for international use and are accepted by IEC National Committees and ISO member bodies in that sense. While all reasonable efforts are made to ensure that the technical content of IEC, ISO and ISO/IEC publications is accurate, IEC or ISO cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees and ISO member bodies undertake to apply IEC, ISO and ISO/IEC publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any ISO, IEC or ISO/IEC publication and the corresponding national or regional publication should be clearly indicated in the latter.
- 5) ISO and IEC do not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marking of conformity. ISO or IEC are not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or ISO or its directors, employees, servants or agents including individual experts and members of their technical committees and IEC National Committees or ISO member bodies for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication of, use of, or reliance upon, this ISO/IEC publication or any other IEC, ISO or ISO/IEC publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this ISO/IEC publication may be the subject of patent rights. ISO and IEC shall not be held responsible for identifying any or all such patent rights.

The main task of the joint technical committee is to prepare International Standards. In exceptional circumstances, the joint technical committee may propose the publication of a Technical Specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- when the subject is still under technical development or where, for any other reason, there is the future but not immediate possibility of an agreement on an International Standard.

Technical Specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

ISO/IEC TS 29125, which is a Technical Specification, has been prepared by subcommittee 25: Interconnection of information technology equipment, of ISO/IEC joint technical committee 1: Information technology.

This first edition cancels and replaces ISO/IEC TR 29125:2010. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) extension of the current per conductor from 300 mA to 500 mA;
- b) provision of additional details of installation conditions that were not described in ISO/IEC TR 29125:2010;
- c) inclusion of guidelines for cords;
- d) inclusion of a model to calculate temperature rise in different bundle sizes.

This Technical Specification has been approved by vote of the member bodies, and the voting results may be obtained from the address given on the second title page.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

This document specifies the use of generic balanced cabling for customer premises, as specified in the ISO/IEC 11801 series, for remote powering of terminal equipment. It provides guidance on new cabling installations and renovations. The customer premises may encompass one or more buildings or may be within a building that contains more than one organization. The cabling may be installed prior to the selection of remote powering equipment or powered terminal equipment.

ISO/IEC 11801-1 specifies a structure and performance requirements for cabling subsystems that support a wide range of applications. They provide appropriate equipment interfaces to the cabling infrastructure in equipment rooms, telecommunications rooms and work areas.

A growing number of organizations employ equipment at locations that require the provision of remote powering. This document was created to provide supplementary information to ISO/IEC 11801-1 to implement remote powering over generic balanced cabling as specified in ISO/IEC 11801-1.

This document provides additional guidance for remote powering on the use of balanced cabling systems as specified in ISO/IEC 11801-1 and guidance on different installation conditions that require special considerations:

- information to bring together all the considerations about remote powering in a single document;
- guidance on mating and un-mating of connectors that convey remote power.

This document does not include requirements from national or local safety standards and regulations.

This document was developed based on a number of contributions describing remote powering over telecommunications cabling under different installation conditions. The relevant safety standards and regulations, application standard, and equipment manufacturers give guidance on factors that should be taken into account during design of the generic balanced cabling that supports the distribution of remote powering.

This document extends the current per conductor specified in ISO/IEC TR 29125:2010 from 300 mA to 500 mA. This document covers additional details of installation conditions that are not described in ISO/IEC TR 29125:2010. This document includes guidelines for cords.

INFORMATION TECHNOLOGY –
TELECOMMUNICATIONS CABLING REQUIREMENTS
FOR REMOTE POWERING OF TERMINAL EQUIPMENT

1 Scope

This document

- a) addresses the support of safety extra low voltage (SELV) and limited power source (LPS) applications that provide remote power over balanced cabling in accordance with the reference implementations of ISO/IEC 11801 series standards using current per conductor of up to 500 mA and targets the support of applications that provide remote power over balanced cabling to terminal equipment,
- b) covers the transmission and electrical parameters needed to support remote power over balanced cabling,
- c) covers various installation scenarios and how these may impact the capability of balanced cabling to support remote powering,
- d) specifies design and configuration of cabling as specified in ISO/IEC 11801-1.

NOTE SELV requirements specify a maximum voltage of 60 V DC and LPS is understood in the applications referenced to be up to 100 W supplied within 4-pair cabling.

This document includes a mathematical model to predict the behaviour of different bundle sizes, various cabling constructions, and installation conditions for different current capacities.

Safety (e.g. electrical safety and protection and fire) and electromagnetic compatibility (EMC) requirements are outside the scope of this document, and are covered by other standards and regulations. However, information given by this document can be of assistance.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO/IEC 11801-1, *Information technology – Generic cabling for customer premises – Part 1: General requirements*

ISO/IEC 14763-2, *Information technology – Implementation and operation of customer premises cabling – Part 2: Planning and installation*

ISO/IEC TR 24746, *Information technology – Generic cabling for customer premises – Mid-span DTE power insertion*

3 Terms, definitions and abbreviated terms

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO/IEC 11801-1, ISO/IEC 14763-2 and the following apply.