

Specifier's Guide for Determining Containment Class and Environmental Monitoring Strategies for Lead Paint Removal Projects

©2022 Association for Materials Protection and Performance (AMPP). All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted, in any form or by any means (electronic, mechanical, photocopying, recording, or otherwise) without the prior written permission of AMPP.

Specifier's Guide for Determining Containment Class and Environmental Monitoring Strategies for Lead Paint Removal Projects

This AMPP Guide represents a consensus of those individual members who have reviewed this document, its scope, and provisions. Its acceptance does not in any respect preclude anyone, whether he or she has adopted the Guide or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not in conformance with this Guide. Nothing contained in this AMPP Guide is to be construed as granting any right, by implication or otherwise, to manufacture, sell, or use in connection with any method, apparatus, or product covered by another's patent, or as indemnifying or protecting anyone against liability for infringement of letters patent. This Guide represents minimum requirements and should in no way be interpreted as a restriction on the use of better procedures or materials. Neither is this Guide intended to apply in all cases relating to the subject. Unpredictable circumstances may negate the usefulness of this Guide in specific instances. AMPP assumes no responsibility for the interpretation or use of this Guide by other parties and accepts responsibility for only those official AMPP interpretations issued by AMPP in accordance with its governing procedures and policies which preclude the issuance of interpretations by individual volunteers.

Users of this AMPP Guide are responsible for reviewing appropriate health, safety, environmental, and regulatory documents and for determining their applicability in relation to this Guide prior to its use. This AMPP Guide may not necessarily address all potential health and safety problems, or environmental hazards associated with the use of materials, equipment, and/or operations detailed or referred to within this Guide. Users of this AMPP Guide are also responsible for establishing appropriate health, safety, and environmental protection practices, in consultation with appropriate regulatory authorities, if necessary, to achieve compliance with any existing applicable regulatory requirements prior to the use of this Guide.

CAUTIONARY NOTICE: Guides may be revised or withdrawn at any time in accordance with AMPP standards committee procedures. The user is cautioned to obtain the latest edition. Purchasers of AMPP Guides may receive current information on all AMPP publications by contacting the AMPP Customer Support Department, 15835 Park Ten Place, Houston, TX 77084-5145 (Tel: 281-228-6200, email: customersupport@ampp.org).

Document History

2022-06-10: Reaffirmed by AMPP Standards Committee (SC) 24, Environmental Health and Safety/Regulatory
2015-05-15: Editorial Revisions by SSPC C.5.3.A
2008-02-01: Approved by SSPC C.5.3.A, Containment of Hazardous Debris

AMPP values your input. To provide feedback on this guide, please contact: standards@ampp.org

SSPC-Guide 18-2022

©2022 Association for Materials Protection and Performance (AMPP). All rights reserved.

Specifier’s Guide for Determining Containment Class and Environmental Monitoring Strategies for Lead Paint Removal Projects

Section 1: Scope.....	4
Section 2: Description	4
Section 3: Information Resources	4
Section 4: Steps for Gathering and Ordering Information.....	4
References	13
Appendix A: Field Data Collection and Project Design Form (Nonmandatory)	14
Charts and Tables	
Chart 1. Determination of Relative Risk to Public Health	5
Chart 2. Determination of Relative Risk to Adjacent Workers.....	6
Chart 3: Determination of Potential Environmental Impact.....	7
Chart 4: Selection of Project-Specific Emission Control Level.....	7
Table 1: Category 1 Very High Emissions Potential	9
Table 2: Category 2 High Emissions Potential.....	10
Table 3: Category 3 Moderate Emissions Potential.....	11
Table 4: Category 4 Low Emissions Potential	12

Section 1: Scope

This Guide describes a six-step process to assist in determining the type of containment system and the level of environmental monitoring that should be specified on a project-specific basis when removing coatings that contain lead. The selection of the containment and monitoring strategies is based on an assessment of the type of paint removal method that will be used and the potential impact of the operations on the public, other workers in the area, and the environment. Note that local and state codes and regulations must be reviewed and take precedence to any guidance provided in this document.

The guidance provided in this document also applies to coatings containing other hazardous metals such as cadmium and chromium; however, the recommended analytical monitoring is often based on an analysis for lead. Paint chip sampling and testing for lead and other hazardous metals should be undertaken to properly characterize the paint being removed.

This Guide does not cover the selection of paint removal methods, or design of containment/ventilation systems.

Section 2: Description

This Guide is intended to assist those who specify, design, construct, or monitor the effectiveness of containments and environmental monitoring procedures on projects where lead-containing coatings are being disturbed. It provides users with a series of steps for gathering and organizing information about a specific lead paint removal operation in order to select the type of containment and the environmental monitoring strategy that will result in the least risk to the public and the environment.

Section 3: Information Resources

Much of the information contained in the Guide has been extracted from *Project Design*,¹ which also provides additional details on the design process for lead-paint removal projects. Additional sources of information that the reader should consult for the proper use of this guide are SSPC-Guide 6, "Guide for Containing Debris Generated During Paint Removal Operations,"² and SSPC-TU 7, "Conducting Ambient Air, Soil, and Water Sampling During Surface Preparation and Paint Disturbance Activities."³

Section 4: Steps for Gathering and Ordering Information

Step 1 – Identify the Emissions Potential of the Selected Paint Removal Method(s)

The various methods of paint removal will create differing amounts of emissions. The particle size distribution (PSD) of emissions may range from a few large paint chips and little airborne dust in the case of hand scraping, to large amounts of smaller particles, debris, and airborne dust in the case of abrasive blast cleaning. The small particle sizes will be carried further by the wind, placing the removal method into a higher "Paint Removal Emissions Category." For the purpose of this guide, four "Paint Removal Emissions Categories" are defined based on the general number of emissions created, whether the emissions are wet or dry.

NOTE: No relationship is being implied between the emission category and the amount of lead that may be present in the emission. For example, open power tool cleaning is classified "moderate emissions potential," whereas water jetting is classified as "high emissions potential." However, the actual amount of lead in the dust surrounding the power tool operation may be greater than the amount of lead in the mist of water surrounding the water jetting operation.

Paint Removal Emissions Categories:

- Category 1 — Very High Emissions Potential: The paint removal methods in this category include open abrasive blast cleaning with expendable or recyclable abrasives.
- Category 2 — High Emissions Potential: The paint removal methods in this category involve the use of