

## Technical Report

### Electromagnetic compatibility (EMC)

#### Part 3.7: Limits—Assessment of emission limits for the connection of fluctuating installations to MV, HV and EHV power systems



## **TR IEC 61000.3.7:2012**

This Joint Australian/New Zealand Technical Report was prepared by Joint Technical Committee EL-034, Power Quality. It was approved on behalf of the Council of Standards Australia on 20 March 2012 and on behalf of the Council of Standards New Zealand on 2 April 2012.

This Technical Report was published on 24 April 2012.

---

The following are represented on Committee EL-034:

Australian Chamber of Commerce and Industry  
Australian Industry Group  
Australian Information Industry Association  
Bureau of Steel Manufacturers of Australia  
Consumer Electronics Suppliers Association  
Consumers Federation of Australia  
Electrical Regulatory Authorities Council  
Electricity Engineers Association, New Zealand  
Energy Networks Association  
Engineers Australia  
Lighting Council of Australia  
Ministry of Economic Development, New Zealand  
National Measurement Institute  
New Zealand Coordinating Committee on Power and Telecommunication Systems  
New Zealand Electric Fence Energiser Manufacturers Standards WG  
Telstra Corporation  
University of Canterbury, New Zealand  
University of Wollongong

---

### **Keeping Standards up-to-date**

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at [www.saiglobal.com.au](http://www.saiglobal.com.au) or Standards New Zealand web site at [www.standards.co.nz](http://www.standards.co.nz) and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

---

## Technical Report

### Electromagnetic compatibility (EMC)

#### Part 3.7: Limits—Assessment of emission limits for the connection of fluctuating installations to MV, HV and EHV power systems

Originally in Australia as AS 2279.4—1985.  
Previous edition AS/NZS 61000.3.7:2001.  
Second edition 2012.

#### **COPYRIGHT**

© Standards Australia Limited/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

Jointly published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001 and by Standards New Zealand, Private Bag 2439, Wellington 6140.

## PREFACE

This Technical Report was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-034, Power Quality, to supersede AS/NZS 61000.3.7:2001, *Electromagnetic compatibility (EMC)—Part 3.7: Limits—Assessment of emission limits for fluctuating loads in MV and HV power systems (IEC 61000-3-7:1996, MOD)*. AS/NZS 61000.3.7:2001 will be made available superseded.

The objective of this Technical Report is to provide guidance on principles that can be used to determine the requirements for the connection of fluctuating installations to MV, HV and EHV public power systems.

This Technical Report is identical with, and has been reproduced from IEC TR 61000-3-7, Ed.2.0 (2008), *Electromagnetic compatibility (EMC)—Part 3-7: Limits—Assessment of emission limits for the connection of fluctuating installations to MV, HV and EHV power systems*. The IEC processes related to development and approval of a Technical Report are subject to a more moderate level of transparency and consensus than the processes related to developing and approving a normative Standard.

As this Technical Report is reproduced from an International Technical Report, the following applies:

- (a) Its number appears on the cover and title page while the International Technical Report number appears only on the cover.
- (b) A full point substitutes for a comma when referring to a decimal marker.

The normative reference in the source document has not been adopted as an Australian or Australian/New Zealand Standard.

The term ‘informative’ has been used in this Technical Report to define the application of the annex to which it applies. An ‘informative’ annex is only for information and guidance.

## CONTENTS

	<i>Page</i>
1 Scope.....	9
2 Normative references .....	10
3 Terms and definitions .....	10
4 Basic EMC concepts related to voltage fluctuations .....	13
4.1 Compatibility levels .....	14
4.2 Planning levels .....	14
4.2.1 Indicative values of planning levels.....	14
4.2.2 Assessment procedure for evaluation against planning levels .....	15
4.3 Illustration of EMC concepts.....	16
4.4 Emission levels .....	17
5 General principles .....	18
5.1 Stage 1: simplified evaluation of disturbance emission .....	18
5.2 Stage 2: emission limits relative to actual system characteristics.....	18
5.3 Stage 3: acceptance of higher emission levels on a conditional basis.....	19
5.4 Responsibilities .....	19
6 General guidelines for the assessment of emission levels .....	19
6.1 Point of evaluation.....	19
6.2 Definition of flicker emission level .....	20
6.3 Assessment of flicker emission levels .....	20
6.4 Declared system short circuit power or impedance .....	21
6.4.1 Short-circuit power or impedance for pre-connection assessment of emission levels .....	21
6.4.2 Short-circuit power or impedance for assessing actual emission levels.....	21
6.5 General guidelines for assessing the declared system impedance.....	21
7 General summation law .....	21
8 Emission limits for fluctuating installations connected to MV systems .....	22
8.1 Stage 1: simplified evaluation of disturbance emission .....	22
8.2 Stage 2: emission limits relative to actual system characteristics.....	23
8.2.1 Global emission to be shared between the customers.....	23
8.2.2 Individual emission limits .....	24
8.3 Stage 3: acceptance of higher emission levels on a conditional basis.....	25
8.4 Summary diagram of the evaluation procedure .....	26
9 Emission limits for fluctuating installations connected to HV or EHV systems .....	28
9.1 Stage 1: simplified evaluation of disturbance emission .....	28
9.2 Stage 2: emission limits relative to actual system characteristics.....	28
9.2.1 Assessment of the total available power .....	28
9.2.2 Individual emission limits .....	29
9.3 Stage 3: acceptance of higher emission levels on a conditional basis.....	30
10 Rapid voltage changes .....	31
10.1 General considerations.....	31
10.2 Compatibility level .....	32

	<i>Page</i>
10.3 Planning levels .....	32
10.4 Emission limits .....	33
10.5 Assessment procedure for evaluation against planning levels & emission limits .....	33
Annex A (informative) $P_{st} = 1$ curves and numerical data for 230 V and 120 V applications .....	34
Annex B (informative) Guidelines on the assessment of flicker transfer coefficient.....	36
Annex C (informative) Example of reallocation of global contributions and planning levels considering transfer coefficients.....	37
Annex D (informative) The use of the severity indicators $A_{st}$ and $A_{lt}$ to simplify calculations.....	39
Annex E (informative) Pre-connection and post-connection assessment of emission for $P_{st}$ .....	40
Annex F (informative) Addition of $P_{st}$ from different busbars.....	49
Annex G (informative) Examples of case studies .....	51
Annex H (informative) List of symbols and subscripts .....	62
Bibliography.....	64
Figure 1 – Illustration of basic voltage quality concepts with time/ location statistics covering the whole system.....	17
Figure 2 – Illustration of basic voltage quality concepts with time statistics relevant to one site within the whole system.....	17
Figure 3 – Example of a system for sharing global contributions at MV .....	23
Figure 4 – Diagram of evaluation procedure.....	27
Figure 5 – Determination of $S_t$ for a simple HV or EHV system.....	28
Figure 6 – Determination of $S_t$ for a meshed HV or EHV system .....	29
Figure 7 – Equivalent circuit and vector diagram for simple assessments .....	31
Figure 8 – Example rapid voltage change associated with motor starting .....	31
Figure 9 – Example rapid voltage change associated with capacitor switching .....	32
Figure A.1 – $P_{st} = 1$ curve for regular rectangular voltage changes [13].....	34
Figure E.1 – Shape factor curve for pulse and ramp changes .....	41
Figure E.2 – Shape factor curves for double-step and double-ramp changes .....	42
Figure E.3 – Shape factor curves for sinusoidal and triangular changes.....	42
Figure E.4 – Shape factor curves for aperiodic changes .....	43
Figure E.5 – Accounting for network loading .....	45
Figure E.6 – System for flicker emission assessment.....	47
Figure E.7 – Assessment of emission level using current measurements .....	48
Figure F.1 – Example of two loads fed from different busbars .....	49
Figure G.1 – Example of effect from a rolling mill.....	51
Figure G.2 – Example of effect of multiple spot welder load .....	53
Figure G.3 – Example profile of winder reactive power levels.....	57
Figure G.4 – Normal system configuration .....	58
Figure G.5 – Busbars coupled.....	59

	<i>Page</i>
Figure G.6 – "n-1" system configuration .....	60
Figure G.7 – Operation without SVC .....	61
Table 1 – Compatibility levels for flicker in low voltage systems reproduced from IEC 61000-2-2 .....	14
Table 2 – Indicative values of planning levels for flicker in MV, HV and EHV power systems .....	15
Table 3 – Stage 1 limits for the relative changes in power as a function of the number of changes per minute .....	22
Table 4 – Minimum emission limits at MV .....	25
Table 5 – Minimum emission limits at HV-EHV .....	30
Table 6 – Indicative planning levels for rapid voltage changes as a function of the number of such changes in a given period .....	33
Table A.1 – Input relative voltage fluctuation $\Delta V/V$ for $P_{St}=1,0$ at output [3] .....	34
Table B.1 – Example of flicker transfer coefficients .....	36
Table D.1 – Compatibility levels for $A_{St}$ and $A_{ft}$ in LV and MV power systems .....	39
Table D.2 – Indicative values of planning levels for $A_{St}$ and $A_{ft}$ in MV, HV and EHV power systems .....	39
Table G.1 – Flicker measurements for example G.5, flicker effects, normal operation .....	56

## FOREWORD

This Technical Report forms Part 3-7 of IEC 61000. It has the status of a basic EMC publication in accordance with IEC Guide 107 [17].<sup>1</sup>

This second edition cancels and replaces the first edition published in 1996 and constitutes a technical revision.

This new edition is significantly more streamlined than the original technical report (Edition 1), and reflects the experiences gained in the application of the first edition. This technical report has also been harmonised with IEC/TR 61000-3-6 [18] and IEC/TR 61000-3-13 [19].

---

<sup>1</sup> Figures in square brackets refer to the bibliography.

## TECHNICAL REPORT

### Electromagnetic compatibility (EMC)

#### Part 3.7:

#### Limits—Assessment of emission limits for the connection of fluctuating installations to MV, HV and EHV power systems

##### 1 Scope

This part of IEC 61000 provides guidance on principles which can be used as the basis for determining the requirements for the connection of fluctuating installations to MV, HV and EHV public power systems (LV installations are covered in other IEC documents). For the purposes of this report, a fluctuating installation means an installation (which may be a load or a generator) that produces voltage flicker and / or rapid voltage changes. The primary objective is to provide guidance to system operators or owners on engineering practices which will facilitate the provision of adequate service quality for all connected customers. In addressing installations, this document is not intended to replace equipment standards for emission limits.

This report addresses the allocation of the capacity of the system to absorb disturbances. It does not address how to mitigate disturbances, nor does it address how the capacity of the system can be increased.

Since the guidelines outlined in this report are necessarily based on certain simplifying assumptions, there is no guarantee that this approach will always provide the optimum solution for all flicker situations. The recommended approach should be used with flexibility and engineering judgment as far as engineering is concerned, when applying the given assessment procedures in full or in part.

The system operator or owner is responsible for specifying requirements for the connection of fluctuating installations to the system. The fluctuating installation is to be understood as the customer's complete installation (i.e. including fluctuating and non fluctuating parts).

Problems related to voltage fluctuations fall into two basic categories:

- Flicker effect from light sources as a result of voltage fluctuations;
- Rapid voltage change, even within the normal operational voltage tolerances are considered as a disturbing phenomenon.

The report gives guidance for the coordination of the flicker emissions between different voltage levels in order to meet the compatibility levels at the point of utilisation. This report primarily focuses on controlling or limiting flicker, but a clause is included to address the limitation of rapid voltage changes.

NOTE The boundaries between the various voltage levels may be different for different countries (see IEC 60071-01-28) [16]. This report uses the following terms for system voltage:

- low voltage (LV) refers to  $U_n \leq 1 \text{ kV}$ ;
- medium voltage (MV) refers to  $1 \text{ kV} < U_n \leq 35 \text{ kV}$ ;
- high voltage (HV) refers to  $35 \text{ kV} < U_n \leq 230 \text{ kV}$ ;
- extra high voltage (EHV) refers to  $230 \text{ kV} < U_n$ .

In the context of this report, the function of the system is more important than its nominal voltage. For example, a HV system used for distribution may be given a "planning level" which is situated between those of MV and HV systems.